



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-12 Curb
CBISCSAV1518**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: June 24, 2021
Project Number: PV2103

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-52.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES



- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.

**VIBRATION ISOLATION ROOF CURBS
SUNCHOICE UNITS**



PROVENT P/N	A	B	EST. WEIGHT
CBISCSAV151818**	8"	18"	556 Lbs
CBISCSAV151821**	11"	21"	606 Lbs
CBISCSAV151824**	14"	24"	656 Lbs

**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-12

DATE:
6/23/2021


PART NUMBER:
-

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SAV1518	4 @ 37.21" O.C.	3 @ 35.31" O.C.
SAV28	3 @ 70" O.C.	2 @ 68.6" O.C.

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

ROOF ANCHORAGE DETAIL


CBISC Series	ISCAL Series	CBKD Series	CBWC Series
SAV1518			
	SAV28	SAV28	SAV28

ASSUMES:

CONC SLAB
f_c= 4000PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/8" Ø HAS THREADED RODS IN HILTI HIT-HY 200 EPOXY, MIN. 4" EMBED INTO CONCRETE.


NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SAV1518	10 @ 12.4" O.C.	7 @ 11.77" O.C.
SAV28	4 @ 46.7" O.C.	3 @ 34.3" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 3 1/2" SIMPSON SDS OR EQUIVALENT SCREWS W/ 2 1/4" EMBED. INTO WOOD FRAMING

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SAV1518	15 @ 8.26" O.C.	10 @ 8.29" O.C.
SAV28	9 @ 18" O.C.	8 @ 10.4" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-52

DATE:
6/17/2021

REV:
3

DRAWN BY:
ALL




Client:	ProVent PV2103
Project:	CBISC-12 Iso Curb CBISCSAV1518 Upper curb rail
Unit:	Sunchoice 15-18

Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	121.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTcurb =	97 lbs	(Weight of curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGTunit =	1921.5 lbs	(Oper. Weight of Unit + 5%)
Wtmax =	538 lbs	(Maximum corner weight)
Wtmin =	408 lbs	(Minimum corner weight)
Hunit =	49.25 in	(Height of unit above curb)
Hcm =	24.625 in	(Height to center of mass)
Lunit =	129.75 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	6900 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 7248 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _h ASD trans =	1673 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _h ASD long =	1145 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert} ASD =	2141 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	3712 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3479 lbs	= Comp _{SEISMIC} -[0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	89 lbs	= [F _h transASD*Hcm+2*0.6*Wtmax*wcurb-F _{vert} ASD*wcurb/2]/wcurb
Tension _{WIND} =	1078 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	2994 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	2761 lbs	= Comp _{SEISMIC} -[0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	-192 lbs	= [F _h transASD*Hcm+2*0.6*Wtmax*Lcurb-F _{vert} ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	796 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 3712 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3479 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2994 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2761 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 [14 Gauge]
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in (Distance between centroid and web centerline)	
Ix = 2.424 in (Moment of Inertia about X-Axis)	
Iy = 0.109 in (Moment of Inertia about Y-Axis)	
A = 0.59 in ²	
rx = 2.03 in	
ry = 0.432 in	
rmin = 0.432 in	



Axial Compression

Pu = 3.450 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 4.075 k		
Fe = 14.24 ksi		
λc = 1.87		
Fn = 12.49 ksi		
Ly = 77.13 in	Lateral unbraced length	
kyLy/ry = 143	(assume k=0.8)	

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{0.877}{\lambda_c^2} F_y \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	CR = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.12	
Ωw = 1.75	N/h = 1.273 ≤ 2.0	Ch = 0.048	
Pn = 1.947 k	R/t = 1.50 ≤ 12.0		

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Long side: PuTrans = 1.237 k **web stiffener REQ'D** # clips = 3

Short side: PuLong = 1.497 k **web stiffener REQ'D** # clips = 2

Check Web Stiffener

16Ga x 1 3/16in x 7in (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 [16 Gauge]
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys	Ωc = 1.70
w/ts = 118.675	
1.28v(E/Fys) = 31.091	--> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc	
Pwc = 1.947 k	Ae = 0.380 in ²
Pn = 14.669 k	
Pn/Ωc = 8.629 k	O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1725 lbs	Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1739 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.7	
# of Bolts required for Shear = 1.6	
# of Bolts Used = 2.0	***If combined fails: USE --> 3.0
Check Combined Stress in Bolts & Inserts: 1.141 N.G.	StressComb = 0.761 O.K.

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in Pn/Ω = 1/Ω * 0.75tLu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu

Lreq'd = 1.176 in




Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.4$	$F_{u1} = 65$ ksi
$t_2 = 0.1017$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	

For $t_2/t_1 \leq 1.0$:	$P_{ns} = 2377$ #	For $t_2/t_1 \geq 2.5$:	$P_{ns} = 2377$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$	3.86 k	$P_{ns} = 2.7t_1dF_{u1}$	2.38 k
$P_{ns} = 2.7t_1dF_{u1}$	2.38 k	$P_{ns} = 2.7t_2dF_{u2}$	3.39 k
$P_{ns} = 2.7t_2dF_{u2}$	3.39 k		
$P_{ns}/\Omega = 792$ #			
$P_{ss}/\Omega = 540$ # <- Controls		$P_{not} = 0.85t_c d F_{u2}$	
Tension: $P_{not} = 1.068$ k (screw pull-out strength)		$t_c = \min(t_1, t_2)$	
$P_{nov} = 2.607$ k (screw pull-over strength)		$P_{nov} = 1.5t_1 d_w F_{u1}$	
$P_{ts}/\Omega = 356$ # <- Controls			
$P_{ts}/\Omega = 820$ #	(full tensile screw capacity)		

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.450	3	1.15	540 #	4	2.00 in
Short side:	3.450	2	1.73	540 #	4	2.00 in

clip width (in) = 7.00 in
min spacing = 0.57 in
clip height = 2.5 in
edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²



Curb Loads [copied from above]


Transverse: (on long edge)	Comp _{MAX} = 3712 lbs
	Tens _{MAX} = 3479 lbs
	Shear _{MAX} = 6900 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2994 lbs
	Tens _{MAX} = 2761 lbs
	Shear _{MAX} = 6900 lbs

Loads at each Isolator Type: OSA

Transverse loading: (on long edge)**	Comp _{MAX} = 1237.3 lbs
	Tens _{MAX} = 1159.7 lbs
# isolators: 3	Shear _{MAX} = 690.0 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1497.0 lbs
	Tens _{MAX} = 1380.6 lbs
# isolators: 2	Shear _{MAX} = 690.0 lbs

Max compression force on isolator: 1.497 k ≤ 1.660 k **O.K.**
 Max uplift on isolator: 1.381 k ≤ 1.660 k **O.K.**
 Max shear on isolator: 0.690 k ≤ 0.800 k **O.K.**

**assumes capacity of 1/4 holddown from each adjacent edge



Forces on top bolt:

Tension = 1.381 k $d_b = 0.375$
 Shear = 0.690 k $d = 0.190$ in

Shear on curb rail:

$P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
Shear O.K. $P_n/\Omega = 6.611$ k $e = 1.0$ in

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 7.117$ k $A_n = 0.165$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.975$ k $d/t = 3.69$

Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 12.50$ ksi $f_v = 6.25$ ksi **O.K.**
 $F'_{nt} = 27.35$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.342$ k **No Good - Use Welds**

Longitudinal weld loading:

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$
 If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ in $P_n/\Omega = 2.153$ k

Transverse weld loading:

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $P_n/\Omega = 1.972$ k




Client:	ProVent PV2101	Previous:	PV1805
Project:	CBISC-12 Iso Curb	CBISCSAV1518	Base curb
Unit:	Sunchoice 15-18		

Curb Information

Hcurb =	14	in	(Height of curb)
Lcurb =	123.625	in	(Length of curb)
wcurb =	82.625	in	(Width of curb)
WGTCurb =	559	lbs	(Weight of curb)
# Springs long side =	3		
# Springs short side =	2		

Unit Information

WGUnit =	1921.5	lbs	(Oper. Weight of Unit + 5%)
Wtmax =	538	lbs	(Maximum corner weight)
Wtmin =	408	lbs	(Minimum corner weight)
Hunit =	49.25	in	(Height of unit above curb)
Hcm =	24.625	in	(Height to center of mass)
Lunit =	129.75	in	(Length of unit)
Wunit =	88.75	in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	7248 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 9256 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	*** Exposure Category C ***
Kzt =	1.00	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kd =	0.85	(Max. assumed topographic factor)
Ke =	1.00	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	110	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
GCr _(horiz) =	1.9	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	1933 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	1322 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2141 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	3752 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3519 lbs	= Comp _{SEISMIC} - [0.6-0.14*S _{DS}]*WGTunit
Compression _{WIND} =	151 lbs	= [F _{h transASD} *Hcm + 2*0.6*Wtmax*wcurb - F _{vertASD} *wcurb/2]/wcurb
Tension _{WIND} =	1139 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	3035 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	2802 lbs	= Comp _{SEISMIC} - [0.6-0.14*S _{DS}]*WGTunit
Compression _{WIND} =	-162 lbs	= [F _{h transASD} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vertASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	827 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate opposite load.

Governing Reactions:


Transverse:	Comp _{MAX} =	3752 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} =	3519 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	3035 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} =	2802 lbs	----> Along short edge of curb.

----> Negative values indicate opposite load.



Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**



Calculate Section Properties of Curb

A' = 14.000 in	a = 13.492 in = A' - (2r + t)
B' = 1.500 in	a' = 13.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 0.992 in = B' - [r + t/2 + a(r + t/2)]
a = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 1.398 in = B' - [t/2 + at/2]
R = 0.1525 (Inside bend radius)	c = 0.746 in = a[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = a[C' - t/2]
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.239 in (Distance between centroid and web centerline)	
I _x = 42.880 in ⁴	r _x = 4.81 in
I _y = 0.420 in ⁴	r _y = 0.476 in
A = 1.86 in ²	r _{min} = 0.476 in

Axial Compression

P_u = 3.624 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 6.734 k
F_e = 7.45 ksi λ_c = 2.59 λ_c = √(F_y/F_e) F_e = π²E / (kl/r)²
λ_c = 2.59 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 6.53 ksi If λ_c > 1.5; F_n = 0.877 / λ_c² F_y
L_y = 117.63 in Lateral unbraced length
k_yL_y/r_y = 198 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 137.66 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.5 ≤ 2.0	C _h = 0.02	
P _n = 4.578 k	R/t = 1.50 ≤ 9.0		

P_n/Ω_w = 2.616 k
Long side: P_{uTrans} = 1.251 k **O.K.** # clips = 3
Short side: P_{uLong} = 1.518 k **O.K.** # clips = 2

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

N/A
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28V_e/F_y Ω_c = 1.70
w/t_s = 118.675
1.28V_e(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.578 k
P_n = 16.511 k
P_n/Ω_c = 9.712 k **Not Req'd**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 1812 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1759 lbs (Max Ten/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs

of Bolts required for Tension = 0.7
of Bolts required for Shear = 1.5
of Bolts Used = 2.0

***If combined fails:
USE --> 3.0

Check Combined Stress in Bolts & Inserts: 1.094 **N.G.** StressComb = 0.729 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in P_n/Ω = 1/Ω * 0.75tL F_u ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u
L_{req'd} = 0.834 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 3712 lbs Tens _{MAX} = 3479 lbs Shear _{MAX} = 6900 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2994 lbs Tens _{MAX} = 2761 lbs Shear _{MAX} = 6900 lbs

Max compression force on isolator: 1.497 k ≤ 1.660 k **O.K.**
 Max uplift on isolator: 1.381 k ≤ 1.660 k **O.K.**
 Max shear on isolator: 0.690 k ≤ 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.690 k / bolt
 Shear = 0.345 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 3.966$ k

$d/t = 4.92$

$C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²

$P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$

$P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.03$ ksi $f_v = 1.76$ ksi

$F'_{nt} = 45.00$ ksi

$F_{nv}/\Omega = 11.25$ ksi

$P'_{nt}/\Omega = 3.927$ k

Combined Not Applicable -> F'nt = Fnt

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14SDS)D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 5860 lbs	Shear _{MAX} = 4628 lbs
Compression _{SEISMIC} =	6161 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}
Tension _{SEISMIC} =	5860 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	577 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*w _{curb} -F _{vertASD} *w _{curb}]/w _{curb}
Tension _{WIND} =	1230 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*w _{curb} +F _{vertASD} *w _{curb}]/w _{curb}
Longitudinal:	Uplift _{MAX} = 4425 lbs	Shear _{MAX} = 4628 lbs
Compression _{SEISMIC} =	4726 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}
Tension _{SEISMIC} =	4425 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	87 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*L _{curb} -F _{vertASD} *L _{curb}]/L _{curb}
Tension _{WIND} =	740 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*L _{curb} +F _{vertASD} *L _{curb}]/L _{curb}

Wood Attachment: **1/4"φ x 3.5" Simpson SDS screw: w/ 2.25" threaded emt** (SG_{min} = 0.43)



Transverse:	Tall _{metal} = 1397 lbs	Vall _{metal} = 1230 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	9.51	COMBINED LOADING: 0.910 O.K.
# of Screws Req'd for Shear =	6.89	Req'd Min Spacing = 8.3 in o.c.
Total # of screws required =	15	

Use 15 - 1/4"φ x 3.5" Simpson SDS screws @ 8.3 in o.c. along long side of curb w/ 2.25" threaded embed

Loads at each Isolator Type: **OSA**

Transverse loading: (on long edge)**	Comp _{MAX} = 1237.3 lbs Tens _{MAX} = 1159.7 lbs Shear _{MAX} = 690.0 lbs
# isolators: 3	
Longitudinal loading: (on short edge)	Comp _{MAX} = 1497.0 lbs Tens _{MAX} = 1380.6 lbs Shear _{MAX} = 690.0 lbs
# isolators: 2	

**assumes capacity of 1/4 holddown from each adjacent edge



O.K.



Longitudinal:

of Screws Req'd for Uplift = 7.18 COMBINED LOADING: 0.994 O.K.
 # of Screws Req'd for Shear = 6.89 Screw Spacing = 8.3 in o.c.
 Total # of screws required = 10

Use 10 - 1/4" φ x 3.5" Simpson SDS screws @ 8.3 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
 Tall_{metal} = 2975 lbs Vall_{metal} = 3072 lbs
 # of Bolts Req'd for Uplift = 1.97 COMBINED LOADING: 0.792 O.K.
 # of Bolts Req'd for Shear = 2.10 Bolt Spacing = 37.2 in o.c.
 Total # of bolts required = 4

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 37.2 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.49 COMBINED LOADING: 0.671 O.K.
 # of Bolts Req'd for Shear = 2.10 Bolt Spacing = 35.3 in o.c.
 Total # of bolts required = 3

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 35.3 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.0)

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
 Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)

Transverse: Uplift_{MAX} = 10187 lbs Shear_{MAX} = 9256 lbs

Compression_{SEISMIC} = 10488 lbs = [2.0 * FpmaxASD * (Hcm + Hcurb) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * wcurb] / wcurb
 Tension_{SEISMIC} = 10187 lbs = Comp_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})
 Shear_{SEISMIC} = 9256 lbs = 2.0 * FpmaxASD/2

Min Bolts Req'd Uplift = 8.89 spacing = 13.95 in o.c. T_{applied} = 1018.7 lbs
 Min Bolts Req'd Shear = 3.48 spacing = 37.21 in o.c. V_{applied} = 544.5 lbs

Try using 10 bolts spaced at 12.40 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.09$

Use 10 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 12.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 7317 lbs Shear_{MAX} = 9256 lbs

Compression_{SEISMIC} = 7618 lbs = [2.0 * FpmaxASD * (Hcm + Hcurb) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * Lcurb] / Lcurb
 Tension_{SEISMIC} = 7317 lbs = Comp_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})
 Shear_{SEISMIC} = 9256 lbs = 2.0 * FpmaxASD/2

Min Bolts Req'd Uplift = 6.39 spacing = 11.77 in o.c. T_{applied} = 1045.3 lbs
 Min Bolts Req'd Shear = 3.48 spacing = 23.54 in o.c. V_{applied} = 544.5 lbs

Try using 7 bolts spaced at 11.77 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12$

Use 7 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 11.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-12 CBISCAV1518	Unit: Sunchoice 15-18
UPPER CURB RAIL THICKNESS: 0.1017 in		12 Gauge	
UNIT CLIP THICKNESS: 0.0713 in		14 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: OSA		Top stud diameter: 3/8	(3) - OSA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16	(2) - OSA Isolators short side
BASE CURB THICKNESS: 0.1017 in		12 Gauge	***Must weld top of OSA***
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use minimum 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	<u>WOOD</u>	<u>STEEL</u>	<u>CONCRETE</u>
	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	15 @ 8.26 in o.c.	4 @ 37.21 in o.c.	10 @ 12.4 in o.c.
SHORT DIRECTION	10 @ 8.29 in o.c.	3 @ 35.31 in o.c.	7 @ 11.77 in o.c.