



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBISC-02 Series**  
**CBISCLXL\*\* SERIES**




**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: August 23, 2023**  
**Project Number: PV2312**

# WELDMENT AND BOLTING DETAIL

\* OPTIONAL  
WELD I.L.O.  
BOLTED STUD



**BASE CURB SUPPORT**

Note: \* - INDICATES WELD REQUIRED I.L.O.  
BOLTED STUD FOR THE FOLLOWING CURBS:


- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM  
BUMPER FOR:  
ISCALSLU180  
ISCALSLM1830

FOR JQA/CQA:  
 $\frac{9}{16}$ "  $\varnothing$  HOLE USE  $\frac{1}{2}$ "  $\varnothing$  A307 BOLT  
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:  
 $\frac{1}{16}$ "  $\varnothing$  HOLE USE  $\frac{5}{8}$ "  $\varnothing$  A307 BOLT  
WITH FLAT WASHER AND NUT

HOLE FOR ISOLATOR STUD,  
W/ FLAT WASHER REQUIRED  
UNDER NUT  
7/16" FOR JQA/CQA  
9/16" FOR JQB/JQBX  
11/16" FOR JQE/JQF



**FOR BOLT ON ISOLATORS**



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CB-61


DATE:  
08/14/23

REV:  
2

DRAWN BY:  
FMM

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.




#### NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

### ASSUMES:

CONC SLAB  
 $f_c = 4000$ PSI MINIMUM  
6" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 9-1/8" EDGE DISTANCE.

### CONCRETE ATTACHMENT



Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SAV1518
SAV2025
SAV28

#### NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



#### NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-62

DATE:  
6/28/2023

REV:  
4

DRAWN BY:  
FMM

For wood, concrete and steel attachment see  
Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are  
standard. For bolted spring housing,  
neoprene pads and spring cups see  
Weldment and Bolting Detail, Form No. CB-61

## STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR LX SERIES LARGE CHASSIS UNITS



P\*\*\*B CABINET

### FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROFILE DETAIL

PROVENT P/N	A	B	EST. WEIGHT
CBISCLXL18**	8"	18"	205 Lbs.
CBISCLXL21**	11"	21"	224 Lbs.
CBISCLXL24**	14"	24"	239 Lbs.

\*\*Note: Spring configuration must be added to part number at time of order

Weight of upper portion supported by spring isolators= 130 Lbs.

Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_

COMPANY: \_\_\_\_\_

JOB NAME: \_\_\_\_\_

EQUIPMENT: \_\_\_\_\_

NOTES: \_\_\_\_\_

FORM NO:

CBISC-02

DATE:

8/14/2023

PART NUMBER:

-

REV:

5

DRAWN BY:

FMM




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-02	Iso Curb	CBISCLXL
Unit:	ALL P***B CABINET		

### Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	46.5	in	(Length of upper curb)
wcurb =	41	in	(Width of upper curb)
WGTupper =	130	lbs	(Weight of upper curb)
# Clips long side =	1		
# Clips short side =	1		

### Unit Information

WGTunit =	656	lbs	(Weight of Unit)
Wtmax =	197	lbs	(Maximum corner weight)
Wtmin =	139	lbs	(Minimum corner weight)
Hunit =	55	in	(Height of unit above curb)
Hcm =	27.5	in	(Height to center of mass)
Lunit =	51.25	in	(Length of unit)
Wunit =	45.75	in	(Width of unit)



### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	2356	lbs
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	2823	lbs
	(unit + upper rail)	

### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr (horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr (vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	730	lbs
Fh ASD long =	652	lbs
Fvert ASD =	436	lbs
	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup>	(Eq. 26.10-1 ASCE 7-16)
	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb)	(Eq. 29.4-2)
	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)	
	= 0.6*qz*GCr*Lunit*Wunit	(Eq. 29.4-3)

### Upper Curb Loading

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	2099	lbs
Tension <sub>SEISMIC</sub> =	1502	lbs
Compression <sub>WIND</sub> =	508	lbs
Tension <sub>WIND</sub> =	541	lbs

---> Negative values indicate opposite load.

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	1912	lbs
Tension <sub>SEISMIC</sub> =	1315	lbs
Compression <sub>WIND</sub> =	404	lbs
Tension <sub>WIND</sub> =	436	lbs

---> Negative values indicate opposite load.

### Governing Reactions:

<b>Transverse:</b>		
Comp <sub>MAX</sub> =	2099	lbs
(on long edge)	Tens <sub>MAX</sub> =	1502
Longitudinal:	Comp <sub>MAX</sub> =	1912
(on short edge)	Tens <sub>MAX</sub> =	1315

---> Negative values indicate opposite load.




## Curb Design

Fy =	50 ksi	Fu =	65 ksi
E =	29500 ksi	t =	0.0713 <span style="border: 1px solid black; padding: 2px;">14 Gauge</span>

## Calculate Section Properties of Curb

A' =	5.500 in	a =	5.144 in = A' - (2r + t)
B' =	1.000 in	a' =	5.429 in = A' - t
C' =	0.000 in (0 if no lips)	b =	0.822 in = B' - [r + t/2 + α(r + t/2)]
α =	0.000 (0 - no Lip; 1 w/ lip)	b' =	0.964 in = B' - (t/2 + αt/2)
R =	0.1069 (Inside bend radius)	c =	0.000 in = α[C' - (r + t/2)]
t =	0.0713 in	c' =	0.000 in = α(C' - t/2)
r' =	0.143 in = R + t/2	u =	0.224 in = πr/2
x =	0.129 in (Distance between centroid and web centerline)		
Ix =	1.899 in <sup>4</sup>	rx =	1.92 in
Iy =	0.034 in <sup>4</sup>	ry =	0.257 in
A =	0.52 in <sup>2</sup>	rmin =	0.257 in



## Axial Compression

Pa =	1.178 k	(Max Axial Comp)	Ω <sub>c</sub> =	1.80
Pn/Ω <sub>c</sub> =	4.964 k			
Fe =	19.75 ksi	$P_n = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$	$F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ <sub>c</sub> =	1.59	If λ <sub>c</sub> ≤ 1.5; F <sub>n</sub> = (0.658 <sup>λ<sub>c</sub>²</sup> ) F <sub>y</sub>		
Fn =	17.32 ksi	If λ <sub>c</sub> > 1.5; F <sub>n</sub> = $\frac{0.877}{\lambda_c^2} F_y$		
Ly =	39.00 in	Lateral unbraced length		
k <sub>y</sub> L <sub>y</sub> /r <sub>y</sub> =	121	(assume k=0.8)		

Compression Check = **O.K.**

## Check Web Crippling

h =	5.5 in	-- Check limits:	C = 7.50	
t =	0.0713 in	h/t =	77.14 ≤ 260	C <sub>R</sub> = 0.08
N =	7.00	N/t =	98.18 ≤ 210	C <sub>N</sub> = 0.12
Ω <sub>w</sub> =	1.75	N/h =	1.273 ≤ 2.0	C <sub>h</sub> = 0.048
P <sub>n</sub> =	1.947 k	R/t =	1.50 ≤ 12.0	
P <sub>n</sub> /Ω <sub>w</sub> =	1.112 k			
Long side: P <sub>Utrans</sub> =	2.099 k	<b>web stiffener REQ'D</b>	# clips =	1
Short side: P <sub>ULong</sub> =	1.912 k	<b>web stiffener REQ'D</b>	# clips =	1

$$P_n = C t^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$$

## Check Web Stiffener

	16Ga x 3/4 in x 7 in (C-channel)	P <sub>n</sub> =	0.7(P <sub>wc</sub> + A <sub>e</sub> F <sub>y</sub> ) ≥ P <sub>wc</sub>
width of stiffener =	7.000 in	ts =	0.0566 <span style="border: 1px solid black; padding: 2px;">16 Gauge</span>
web of stiff. w =	6.717 in	Rs =	0.0849 in
***Check w/ts ≤ 1.28vE/F <sub>y</sub>		Ω <sub>c</sub> =	1.70
w/ts =	118.675		
1.28v(E/F <sub>y</sub> ) =	31.091	--> w/ts over limit	Use C3.7.2
		Pn/Ω <sub>c</sub> =	8.629 k

**O.K.**

## Corner Connections

### 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax =	706 lbs	Max(F <sub>pmaxASD</sub> /4 -OR- F <sub>hASDtrans</sub> /4 corner connections)	
Vcrnmax =	1050 lbs	Max(Tens/2 -OR- Comp/2 corner connections per side)	
Bolt:	Tall = <span style="border: 1px solid black; padding: 2px;">2480</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1208</span> lbs	
Threaded Insert:	Tall = <span style="border: 1px solid black; padding: 2px;">2860</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1096</span> lbs	

# of Bolts required for Tension = 0.3

# of Bolts required for Shear = 1.0

# of Bolts Used = 2.0

Check Combined Stress in Bolts & Inserts: 0.621 **O.K.**

## Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

$$\text{Assume } L/t > 25: 25 \cdot t = 1.783 \text{ in} \quad P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req} \quad L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

$$L_{req'd} = 0.710 \text{ in}$$



**Connection Unit to Curb Clip** #10 SMS screw  $\Omega = 3.0$

$t_1 = 0.0713$  in (clip thickness)  $t_2/t_1 = 1.0$   $F_{u1} = 65$  ksi  
 $t_2 = 0.0713$  in (unit base rail thickness)  $F_{u2} = 65$  ksi  
 $d = 0.190$  in (screw diameter)  $d_w = 0.375$  in (nom. washer diameter)


For  $t_2/t_1 \leq 1.0$ :  $P_{ns} = 2266$  # For  $t_2/t_1 \geq 2.5$ :  $P_{ns} = 2377$  #

**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$  2.27 k  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  
**Tension:**  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  $P_{ns} = 2.7t_2dF_{u2}$  2.38 k  
 $P_{ns}/\Omega = 755$  #  
 $P_{ss}/\Omega = 540$  # <- Controls  
 $P_{not} = 0.748$  k (screw pull-out strength)  $P_{not} = 0.85t_c d F_{u2}$   
 $P_{nov} = 2.607$  k (screw pull-over strength)  $t_c = \min(t_1, t_2)$   
 $P_{ts}/\Omega = 249$  # <- Controls  $P_{nov} = 1.5t_1 d_w F_{u1}$   
 $P_{ts}/\Omega = 820$  # (full tensile screw capacity)

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	1.178	1	1.18	540 #	4	2.00 in
Short side:	1.178	1	1.18	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in  
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)  
Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies  
 $F_y = 50$  ksi  $\Omega = 2.22$  bolt/screw connection  
 $A_{gv} = 0.463$  in<sup>2</sup>  $A_{nv} = 0.416$  in<sup>2</sup>  $A_{nt} = 0.082$  in<sup>2</sup>  
 $R_n/\Omega = 8.674$  k  $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$  (AISI Sect. E5.3)

**BSR O.K.**



**Curb Loads** (copied from above)

<b>Transverse:</b>	Comp <sub>MAX</sub> = 2790 lbs
(on long edge)	Tens <sub>MAX</sub> = 2161 lbs
	Shear <sub>MAX</sub> = 2823 lbs
<b>Longitudinal:</b>	Comp <sub>MAX</sub> = 2522 lbs
(on short edge)	Tens <sub>MAX</sub> = 1893 lbs
	Shear <sub>MAX</sub> = 2823 lbs

**Loads at each Isolator**

Type: CQA

<b>Transverse loading:</b>	Comp <sub>MAX</sub> = 1395.1 lbs
(on long edge)	Tens <sub>MAX</sub> = 1080.7 lbs
# isolators: 2	Shear <sub>MAX</sub> = 470.4 lbs
<b>Longitudinal loading:</b>	Comp <sub>MAX</sub> = 2521.5 lbs
(on short edge)	Tens <sub>MAX</sub> = 1892.7 lbs
# isolators: 1	Shear <sub>MAX</sub> = 470.4 lbs

Max compression force on isolator: 2.522 k  $\leq 3.176$  k **O.K.**  
Max uplift on isolator: 1.893 k  $\leq 3.176$  k **O.K.**  
Max shear on isolator: 0.470 k  $\leq 1.163$  k **O.K.**

**Forces on top bolt:**

Tension = 1.893 k  $d_b = 0.375$  in  
Shear = 0.470 k upper rail,  $t = 0.0713$  in

**Shear on curb rail:**

$P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)

**Shear O.K.**

$P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**

$P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**

$P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**

$C = 3.00$   $m_f = 1.00$

**Shear and tension in bolt:**

(Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>

$P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 17.14$  ksi  $f_v = 4.26$  ksi **O.K.**  
 $F'_{nt} = 35.40$  ksi  $F_{nv}/\Omega = 10.00$  ksi

$P'_{nt}/\Omega = 1.738$  k **No Good - Use Welds**

**Longitudinal weld loading:**

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$

If  $L/t < 25$ :  $L/t = 21.04$   $t = 0.0713$   $P_n/\Omega = 2.153$  k

**Transverse weld loading:**

$t = 0.0713$   $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$

$L = 1$   $F_u = 65$  ksi  $P_n/\Omega = 1.972$  k





Client:	ProVent	PV2312	Base curb
Project:	CBISC-02	Iso Curb	CBISCLXL
Unit:	ALL P***B CABINET		

#### Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	50.5	in	(Length of base curb)
wcurb =	45	in	(Width of base curb)
WGTbase =	109	lbs	(Weight of base curb)
# Springs long side =	2		# Springs short side = 1

#### Unit Information

WGUnit =	656	lbs	(Weight of Unit)
Wt'max =	229	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	172	lbs	(Wtmin+1/4*WGUpper)
Hunit =	55	in	(Height of unit above curb)
H'cm =	37.5	in	(Hcm+10"(upper+spring))
Lunit =	51.25	in	(Length of unit)
Wunit =	45.75	in	(Width of unit)
WGUnit+upper+base =	895	lbs	(Total weight)

#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2823 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 3214 lbs (unit + upper rail + base curb)

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1086 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	970 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	436 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

#### Base Curb Loading

##### Transverse:

Compression <sub>SEISMIC</sub> =	2957 lbs	= [FpmaxASD*H'cm+2*(1+0.14S <sub>DS</sub> )*Wt'max*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	2256 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*wcurb]/wcurb
Compression <sub>WIND</sub> =	963 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	917 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

##### Longitudinal:


Compression <sub>SEISMIC</sub> =	2701 lbs	= [FpmaxASD*H'cm+2*(1+0.14*S <sub>DS</sub> )*Wt'max*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	1999 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	777 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	732 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

#### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	2957	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	2256	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	2701	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	1999	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.








## Curb Design

Fy = 50 ksi Fu = 65 ksi  
E = 29500 ksi t = 0.0713 14 Gauge

## Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in	rx = 8.00 in
Iy = 0.218 in	ry = 0.329 in
A = 2.01 in <sup>2</sup>	rmin = 0.329 in



## Axial Compression

Pu = 1.411 k (Max Axial Comp) Ωc = 1.80  
Pn/Ωc = 18.917 k  
Fe = 19.29 ksi  
λc = 1.61  
Fn = 16.91 ksi  
Ly = 50.50 in  
kyLy/r<sub>y</sub> = 123

If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658<sup>λ<sub>c</sub><sup>2</sup></sup>) F<sub>y</sub>  
If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length (assume k=0.8)

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$   $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Compression Check = O.K.

## Check Web Crippling

h = 25 in -- Check limits: C = 4.00  
t = 0.0713 in h/t = 350.63 ≤ 260 C<sub>R</sub> = 0.14  
N = 7.00 N/t = 98.18 ≤ 210 C<sub>N</sub> = 0.35  
Ω<sub>w</sub> = 1.75 N/h = 0.28 ≤ 2.0 C<sub>h</sub> = 0.02  
P<sub>n</sub> = 2.105 k R/t = 1.50 ≤ 9.0  
P<sub>n</sub>/Ω<sub>w</sub> = 1.203 k  
Long side: P<sub>U</sub>Trans = 1.479 k web stiffener REQ'D # clips = 2  
Short side: P<sub>U</sub>Long = 2.701 k web stiffener REQ'D # clips = 1

$P_n = Ct^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$

\*\*\*h/t > 260; use web stiffeners

## Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)  
width of stiffener = 7.000 in ts = 0.0566 16 Gauge  
web of stiff. w = 6.717 in Rs = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28VE/Fys Ωc = 1.70  
w/ts = 118.675  
1.28V(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>  
P<sub>wc</sub> = 2.105 k Ae = 0.380 in<sup>2</sup>  
P<sub>n</sub> = 14.780 k  
P<sub>n</sub>/Ωc = 8.694 k O.K.

## Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 803 lbs Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
Vcrnmax = 1479 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: Tall = 2480 lbs Vall = 1208 lbs  
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs  
# of Bolts required for Tension = 0.3  
# of Bolts required for Shear = 1.3  
# of Bolts Used = 3.0  
Check Combined Stress in Bolts & Inserts: 0.558 O.K.

## Check 1/8" welded connection

USE WELD

Ω = 2.35

Assume L/t > 25: 25\*t = 1.783 in  
Lreq'd = 1.000 in  
 $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$   $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$



## Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp <sub>MAX</sub> =	2790	lbs
	Tens <sub>MAX</sub> =	2161	lbs
	Shear <sub>MAX</sub> =	2823	lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> =	2522	lbs
	Tens <sub>MAX</sub> =	1893	lbs
	Shear <sub>MAX</sub> =	2823	lbs

Max compression force on isolator: 2.522 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 1.893 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 0.470 k ≤ 1.163 k **O.K.**

## Forces on bottom bolts:

$d_b = 0.5$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 0.946 k / bolt  
 Shear = 0.235 k / bolt

Shear on base curb:  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n / \Omega = 4.635$  k  $e = 1.0$  in

**Shear O.K.**

Net section rupture:  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n / \Omega = 5.909$  k  $A_n = 0.107$  in

**N.S.R. O.K.**

Bolt Bearing Strength:  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n / \Omega = 2.781$  k  $d/t = 7.01$

**Bearing O.K.**

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)  
 Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt} / \Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$   
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv} / \Omega = 2.209$  k **Bolt shear O.K.** **\*\*\* (Table E3.4-1, AISI) \*\*\***

## Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 9.64$  ksi  $f_v = 1.20$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv} / \Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt} / \Omega = 3.927$  k **Combined Not Applicable ->  $F'_{nt} = F_{nt}$**

## Connection of Curb to Supporting Structure

**Roof Loading** SEISMIC:  $(0.6 - 0.14 S_{DS}) D + 0.7 E$

WIND:  $0.6 D + W$

Transverse:	Uplift <sub>MAX</sub> =	4338	lbs	Shear <sub>MAX</sub> =	1607	lbs
-------------	-------------------------	------	-----	------------------------	------	-----

Compression<sub>SEISMIC</sub> = 5054 lbs  $= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$   
 Tension<sub>SEISMIC</sub> = 4338 lbs  $= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$   
 Compression<sub>WIND</sub> = 1559 lbs  $= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$   
 Tension<sub>WIND</sub> = 1458 lbs  $= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$

Longitudinal:	Uplift <sub>MAX</sub> =	3852	lbs	Shear <sub>MAX</sub> =	1607	lbs
---------------	-------------------------	------	-----	------------------------	------	-----

Compression<sub>SEISMIC</sub> = 4568 lbs  $= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$   
 Tension<sub>SEISMIC</sub> = 3852 lbs  $= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$   
 Compression<sub>WIND</sub> = 1251 lbs  $= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$   
 Tension<sub>WIND</sub> = 1150 lbs  $= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$

**Wood Attachment:** 1/4"  $\phi$  x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

	Tall <sub>metal</sub> =	997	lbs	Vall <sub>metal</sub> =	1097	lbs
Transverse:	Tall <sub>wood</sub> =	760	lbs	Vall <sub>wood</sub> =	672	lbs

# of Screws Req'd for Uplift = 5.71



COMBINED LOADING: 0.986 O.K.

# of Screws Req'd for Shear = 2.39

Req'd Min Spacing = 7.08 in o.c.

Total # of screws required = 7

Use 7 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 7.1 in o.c. along long side of curb w/ 2.75" threaded embed





Longitudinal:

# of Screws Req'd for Uplift = 5.07  
# of Screws Req'd for Shear = 2.39  
Total # of screws required = 7

COMBINED LOADING: 0.895 O.K.  
Screw Spacing = 6.17 in o.c.

Use 7 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 6.2 in o.c. along short side of curb w/ 2.75" threaded embed

**Steel Deck Attachment: 1/2"  $\phi$  A307 Bolts to steel angle below deck**

Transverse: Tall<sub>bolt</sub> = 3927 lbs Vall<sub>bolt</sub> = 2209 lbs  
Tall<sub>metal</sub> = 2086 lbs Vall<sub>metal</sub> = 2192 lbs  
# of Bolts Req'd for Uplift = 2.08  
# of Bolts Req'd for Shear = 0.73  
Total # of bolts required = 3

COMBINED LOADING: 0.840 O.K.  
Bolt Spacing = 19.25 in o.c.

Use 3 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 19.3 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 1.85  
# of Bolts Req'd for Shear = 0.73  
Total # of bolts required = 2

COMBINED LOADING: 0.762 O.K.  
Bolt Spacing = 33.00 in o.c.

Use 2 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 33 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>o</sub> E  $\Omega_o = 2.5$

**Concrete Attachment: 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed**

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c$  = 4000 psi  
h = 6 in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
h<sub>ef</sub> = 4 in (effective embedment)  
d<sub>a</sub> = 0.625 in (anchor diameter) d<sub>o</sub> = 0.75 in (hole diameter)  
n = 5 (number of dummy anchors to check capacity with spacing effect)  
s = 14 in (initial spacing estimate)  
tk<sub>cr</sub> / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)  
tk<sub>cr</sub> / uncr = 1226 2327 psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
c<sub>Na</sub> = 9.0625 in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**

Bond strength  
\*\*\*Bond strength  
will govern over  
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1343.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs} \quad N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$N_{ag} = 38995 \text{ lbs (group)} \quad \lambda_a = 1.0$$

$$\phi N_{ag} = 19010 \text{ lbs (group)} \quad \text{CONTROLS} \quad \lambda_a = 1.0 \text{ for normal weight conc; 0.6 for lightw}$$

**Breakout strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nc0}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b \quad N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 816 \text{ in}^2 \quad N_b = 8601 \text{ lbs} \quad \phi_{conc} = 0.75$$

$$A_{Nc0} = 144 \text{ in}^2 \quad kc = 17 \quad \phi_{bond} = 0.65$$

$$N_{cbg} = 48741 \text{ lbs (group)} \quad \phi_{seis} = 0.75$$

$$\phi N_{cbg} = 27417 \text{ lbs (group)} \quad \phi_{steel} = 0.65$$

**Shear:**

Steel strength

$$V_{sa,eq} = \underline{7865} \text{ (from ESR4868, Table 11)} \quad \alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 3802 \text{ lbs (anchor)} \quad Vall_{LRFD} = 3067 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD}/\alpha = 2225 \text{ lbs} \quad Vall_{ASD} = Vall_{LRFD}/\alpha = 1795 \text{ lbs} \quad D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift<sub>MAX</sub> = 5751 lbs Shear<sub>MAX</sub> = 4017 lbs

$$\text{Compression}_{SEISMIC} = 6485 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 5751 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 4017 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$


$$\text{Min Bolts Req'd Uplift} = 2.58 \text{ spacing} = 19.25 \text{ in o.c.} \quad \text{Tapplied} = 1437.9 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.24 \text{ spacing} = 19.25 \text{ in o.c.} \quad \text{Vapplied} = 573.9 \text{ lbs}$$

Try using 4 bolts spaced at 12.83 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.97$ O.K.
---	---

Use 4 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 12.8 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift<sub>MAX</sub> = 5111 lbs Shear<sub>MAX</sub> = 4017 lbs





# MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
(619)727-4800  
Page 8 of 8

$$\begin{aligned} \text{Compression}_{\text{SEISMIC}} &= 5845 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Tension}_{\text{SEISMIC}} &= 5111 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Shear}_{\text{SEISMIC}} &= 4017 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\ \text{Min Bolts Req'd Uplift} &= 2.30 \text{ spacing} = 16.50 \text{ in o.c.} &\text{Applied} = 1703.7 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.24 \text{ spacing} = 16.50 \text{ in o.c.} &\text{Applied} = 573.9 \text{ lbs} \\ \text{Try using } 3 \text{ bolts spaced at } 16.50 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.09 \text{ O.K.} \end{aligned}$$

Use 3 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 16.5 in o.c. max. along short side of curb w/ 4in embed

<b>CURB DESIGN SUMMARY:</b>		CBISC-02	CBISCLXL	<b>Unit:</b>	ALL P***B CABINET
<b>UPPER CURB RAIL THICKNESS:</b>		0.0713 in	14 Gauge		
<b>UNIT CLIP THICKNESS:</b>		0.0713 in	14 Gauge		
<b># OF CLIPS (LONG SIDE)</b> - 1 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b># OF CLIPS (SHORT SIDE)</b> - 1 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b>VIBRATION ISOLATOR TYPE:</b> CQA		Top stud diameter:		3/8	(2) - CQA Isolators long side
Anchor bolt diameter:		1/2	Anchor hole diamter:		9/16
					(1) - CQA Isolators short side
<b>BASE CURB THICKNESS:</b>		0.0713 in	14 Gauge	***Must weld top of CQA***	
<b>WEB STIFFENER:</b> 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
<b>CORNER CONNECTION:</b> Use minimum 3 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
<b>CURB ANCHORAGE</b>	<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>
	1/4" $\phi$ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" $\phi$ A307 Bolts to steel angle below deck		0.625in $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed
<u>LONG DIRECTION</u>	7 @ 7.08 in o.c.		3 @ 19.25 in o.c.		4 @ 12.83 in o.c.
<u>SHORT DIRECTION</u>	7 @ 6.17 in o.c.		2 @ 33 in o.c.		3 @ 16.5 in o.c.