



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBISC-01 Series**  
**CBISCLXS\*\* SERIES**




**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: August 23, 2023**  
**Project Number: PV2312**

# WELDMENT AND BOLTING DETAIL

\* OPTIONAL  
WELD I.L.O.  
BOLTED STUD



**BASE CURB SUPPORT**

Note: \* - INDICATES WELD REQUIRED I.L.O.  
BOLTED STUD FOR THE FOLLOWING CURBS:


- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM  
BUMPER FOR:  
ISCALSLU180  
ISCALSLM1830

FOR JQA/CQA:  
 $\frac{9}{16}$ "  $\varnothing$  HOLE USE  $\frac{1}{2}$ "  $\varnothing$  A307 BOLT  
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:  
 $\frac{1}{16}$ "  $\varnothing$  HOLE USE  $\frac{5}{8}$ "  $\varnothing$  A307 BOLT  
WITH FLAT WASHER AND NUT

HOLE FOR ISOLATOR STUD,  
W/ FLAT WASHER REQUIRED  
UNDER NUT  
7/16" FOR JQA/CQA  
9/16" FOR JQB/JQBX  
11/16" FOR JQE/JQF



**FOR BOLT ON ISOLATORS**



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CB-61

DATE:  
08/14/23

REV:  
2

DRAWN BY:  
FMM

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.

WELDED CURB

SHEATHING WHERE OCCURS

METAL DECK

STEEL ANGLE SUPPORT BY OTHERS

#### NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

### ASSUMES:

CONC SLAB  
 $f'_c = 4000$ PSI MINIMUM  
6" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 9-1/8" EDGE DISTANCE.

### CONCRETE ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE.  
SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø THREADED ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4" EMBED

#### NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



#### NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-62

DATE:  
6/28/2023

REV:  
4

DRAWN BY:  
FMM

For wood, concrete and steel attachment see  
Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are  
standard. For bolted spring housing,  
neoprene pads and spring cups see  
Weldment and Bolting Detail, Form No. CB-61

## STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR LX SERIES SMALL CHASSIS UNITS

P\*\*\*A CABINET

PROVENT P/N	A	B	EST. WEIGHT
CBISCLXS18*	8"	18"	180 Lbs.
CBISCLXS21**	11"	21"	195 Lbs.
CBISCLXS24**	14"	24"	210 Lbs.

\*\*Note: Spring configuration must be added to  
part number at time of order

Weight of upper portion supported by spring  
isolators= 111 Lbs.



Meets seismic requirements for the following  
codes:  
CBC 2022  
IBC 2021

### FEATURES



- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROFILE DETAIL



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBISC-01

DATE:  
7/28/2023

PART NUMBER:  
-

REV:  
5

DRAWN BY:  
JG




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-01	Iso Curb	CBISCLXS
Unit:	ALL P***A CABINET		

#### Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	46.5	in	(Length of upper curb)
wcurb =	31	in	(Width of upper curb)
WGtupper =	111	lbs	(Weight of upper curb)
# Clips long side =	1		
# Clips short side =	1		

#### Unit Information

WGtunit =	521	lbs	(Weight of Unit)
Wtmax =	156	lbs	(Maximum corner weight)
Wtmin =	111	lbs	(Minimum corner weight)
Hunit =	49	in	(Height of unit above curb)
Hcm =	24.5	in	(Height to center of mass)
Lunit =	51.25	in	(Length of unit)
Wunit =	35.75	in	(Width of unit)



#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	(0.4*ap*Sds*Ip)*Wp/3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	1871	lbs
	(unit only)	
FpmaxASD =	2270	lbs
	(unit + upper rail)	

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr (horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr (vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	658	lbs
Fh ASD long =	459	lbs
Fvert ASD =	341	lbs

#### Upper Curb Loading

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	1891	lbs
Tension <sub>SEISMIC</sub> =	1416	lbs
Compression <sub>WIND</sub> =	537	lbs
Tension <sub>WIND</sub> =	557	lbs

---> Negative values indicate opposite load.

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	1398	lbs
Tension <sub>SEISMIC</sub> =	924	lbs
Compression <sub>WIND</sub> =	259	lbs
Tension <sub>WIND</sub> =	279	lbs

---> Negative values indicate opposite load.

#### Governing Reactions:

<b>Transverse:</b>		
Comp <sub>MAX</sub> =	1891	lbs
(on long edge)	Tens <sub>MAX</sub> =	1416
	lbs	
<b>Longitudinal:</b>		
Comp <sub>MAX</sub> =	1398	lbs
(on short edge)	Tens <sub>MAX</sub> =	924
	lbs	

---> Negative values indicate opposite load.




**Curb Design**

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

**Calculate Section Properties of Curb**

A' = 5.500 in	a = 5.144 in = A' - (2r + t)
B' = 1.000 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 0.822 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 0.964 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.129 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 1.899 in <sup>4</sup>	rx = 1.92 in
I <sub>y</sub> = 0.034 in <sup>4</sup>	ry = 0.257 in
A = 0.52 in <sup>2</sup>	r <sub>min</sub> = 0.257 in



**Axial Compression**

P<sub>a</sub> = 0.935 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80

P<sub>n</sub>/Ω<sub>c</sub> = 7.976 k

Fe = 35.72 ksi       $\lambda_c = \frac{F_y}{F_e}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$

λ<sub>c</sub> = 1.18       $\Omega_c = \frac{F_n A}{F_e A}$       If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>

F<sub>n</sub> = 27.83 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$

Ly = 29.00 in      Lateral unbraced length

k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 90      (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 5.5 in      -- Check limits:      C = 7.50

t = 0.0713 in      h/t = 77.14 ≤ 260      C<sub>R</sub> = 0.08

N = 7.00      N/t = 98.18 ≤ 210      C<sub>N</sub> = 0.12

Ω<sub>w</sub> = 1.75      N/h = 1.273 ≤ 2.0      C<sub>h</sub> = 0.048

P<sub>n</sub> = 1.947 k      R/t = 1.50 ≤ 12.0

P<sub>n</sub>/Ω<sub>w</sub> = 1.112 k       $P_n = C t^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$

Long side: P<sub>Utrans</sub> = 1.891 k      **web stiffener REQ'D**      # clips = 1

Short side: P<sub>ULong</sub> = 1.398 k      **web stiffener REQ'D**      # clips = 1

(See table C3.4.1-2, fastened to support, two flange, end loading)

**Check Web Stiffener**

16Ga x 3/4in x 7in (C-channel)      P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>

width of stiffener = 7.000 in      ts = 0.0566 16 Gauge      P<sub>wc</sub> = 1.947 k

web of stiff. w = 6.717 in      Rs = 0.0849 in      P<sub>n</sub> = 14.669 k

\*\*\*Check w/ts ≤ 1.28√E/F<sub>y</sub>      Ω<sub>c</sub> = 1.70      A<sub>e</sub> = 0.380 in<sup>2</sup>

w/ts = 118.675

1.28√(E/F<sub>y</sub>) = 31.091      --> w/ts over limit      Use C3.7.2      P<sub>n</sub>/Ω<sub>c</sub> = 8.629 k      **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

T<sub>crnmax</sub> = 567 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)

V<sub>crnmax</sub> = 946 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs      Vall = 1208 lbs

Threaded Insert: Tall = 2860 lbs      Vall = 1096 lbs

# of Bolts required for Tension = 0.2

# of Bolts required for Shear = 0.9

# of Bolts Used = 2.0

Check Combined Stress in Bolts & Inserts: 0.546 **O.K.**

**Check 1/8" welded connection**


<--- USE WELD      Ω = 2.35

Assume L/t > 25: 25\*t = 1.783 in       $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$        $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

L<sub>req'd</sub> = 0.639 in



<b>Connection Unit to Curb Clip</b>		#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi	
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi	
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)		
<b>For <math>t_2/t_1 \leq 1.0</math>:</b>		<b>For <math>t_2/t_1 \geq 2.5</math>:</b>	
<b>Shear:</b> $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$	$P_{ns} = 2266$ #	$P_{ns} = 2377$ #	
<b>Tension:</b> $P_{ns} = 2.7t_1dF_{u1}$	$P_{ns} = 2.38$ k	$P_{ns} = 2.7t_1dF_{u1}$	$2.38$ k
$P_{ns} = 2.7t_2dF_{u2}$	$2.38$ k	$P_{ns} = 2.7t_2dF_{u2}$	$2.38$ k
$P_{ns}/\Omega = 755$ #			
$P_{ss}/\Omega = 540$ # <- Controls		$P_{not} = 0.85t_c d F_{u2}$	
$P_{not} = 0.748$ k (screw pull-out strength)		$t_c = \min(t_1, t_2)$	
$P_{nov} = 2.607$ k (screw pull-over strength)		$P_{nov} = 1.5t_1 d_w F_{u1}$	
$P_{ts}/\Omega = 249$ # <- Controls			
$P_{ts}/\Omega = 820$ #	(full tensile screw capacity)		
	Shear (k)	# clips	$V_{clip}$ (k)
<b>Long side:</b>	0.935	1	0.94
<b>Short side:</b>	0.935	1	0.94
			$V_{allow}$ (lb)
			540 #
			# screws
			4
			spacing
			2.00 in
			2.00 in
	clip width (in) = 7.00		clip height = 2.5 in
	min spacing = 0.57 in		edge distance = 0.5 in (min. 1.5d)
<b>Check Block shear rupture:</b> O.K.		thinnest part = 0.0713	AISI BSR applies
$F_y = 50$ ksi		$\Omega = 2.22$ bolt/screw connection	
$A_{gv} = 0.463$ in <sup>2</sup>		$A_{nv} = 0.416$ in <sup>2</sup>	$A_{nt} = 0.082$ in <sup>2</sup>
$R_n/\Omega = 8.674$ k		$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$	(AISI Sect. E5.3)
<b>BSR O.K.</b>			



## Curb Loads (copied from above)

<b>Transverse:</b>	$Comp_{MAX} = 2613$ lbs
(on long edge)	$Tens_{MAX} = 2108$ lbs
	$Shear_{MAX} = 2270$ lbs
<b>Longitudinal:</b>	$Comp_{MAX} = 1881$ lbs
(on short edge)	$Tens_{MAX} = 1375$ lbs
	$Shear_{MAX} = 2270$ lbs

## Loads at each Isolator

Type: CQA

<b>Transverse loading:</b>	$Comp_{MAX} = 2613.2$ lbs
(on long edge)	$Tens_{MAX} = 2107.6$ lbs
# isolators: 1	$Shear_{MAX} = 567.4$ lbs
<b>Longitudinal loading:</b>	$Comp_{MAX} = 1881.1$ lbs
(on short edge)	$Tens_{MAX} = 1375.5$ lbs
# isolators: 1	$Shear_{MAX} = 567.4$ lbs

Max compression force on isolator: 2.613 k  $\leq 3.176$  k **O.K.**  
 Max uplift on isolator: 2.108 k  $\leq 3.176$  k **O.K.**  
 Max shear on isolator: 0.567 k  $\leq 1.163$  k **O.K.**

## Forces on top bolt:

Tension = 2.108 k  $d_b = 0.375$  in  
 Shear = 0.567 k upper rail,  $t = 0.0713$  in

**Shear on curb rail:**  $P_n = teF_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)

**Shear O.K.**  $P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**

$C = 3.00$   $m_f = 1.00$

## Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>

$P_{nt}/\Omega = 1.988$  k **No Good**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

## Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 19.08$  ksi  $f_v = 5.14$  ksi **O.K.**  
 $F'_{nt} = 31.84$  ksi  $F_{nv}/\Omega = 10.00$  ksi

$P'_{nt}/\Omega = 1.563$  k **No Good - Use Welds**

Longitudinal weld loading:  $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left( 1 - \frac{0.01L}{t_2} \right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$   
 If  $L/t < 25$ :  $L/t = 21.04$   $t = 0.0713$   $P_n/\Omega = 2.153$  k

Transverse weld loading:  $t = 0.0713$   $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$   
 $L = 1$   $F_u = 65$  ksi  $P_n/\Omega = 1.972$  k





Client:	ProVent	PV2312	Base curb
Project:	CBISC-01	Iso Curb	CBISCLXS
Unit:	ALL P***A CABINET		

#### Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	50.5	in	(Length of base curb)
wcurb =	35	in	(Width of base curb)
WGTbase =	128	lbs	(Weight of base curb)
# Springs long side =	1		# Springs short side = 1

#### Unit Information

WGUnit =	521	lbs	(Weight of Unit)
Wt'max =	184	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	138	lbs	(Wtmin+1/4*WGUpper)
Hunit =	49	in	(Height of unit above curb)
H'cm =	34.5	in	(Hcm+10"(upper+spring))
Lunit =	51.25	in	(Length of unit)
Wunit =	35.75	in	(Width of unit)
WGUnit+upper+base =	760	lbs	(Total weight)

#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	2270	lbs
	(unit + upper rail)	
ap =	2.5	
Rp =	2	
FpmaxASD =	2729	lbs
	(unit + upper rail + base curb)	

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf
Fh ASD trans =	1014	lbs
Fh ASD long =	707	lbs
Fvert ASD =	341	lbs

#### Base Curb Loading

##### Transverse:

Compression <sub>SEISMIC</sub> =	2723	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S <sub>DS</sub> ) * Wt'max * wcurb] / wcurb
Tension <sub>SEISMIC</sub> =	2159	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S <sub>DS</sub> ) * Wt'min * wcurb] / wcurb
Compression <sub>WIND</sub> =	1050	lbs	= [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb
Tension <sub>WIND</sub> =	1004	lbs	= [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb

---> Negative values indicate opposite load.

##### Longitudinal:


Compression <sub>SEISMIC</sub> =	2036	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S <sub>DS</sub> ) * Wt'max * Lcurb] / Lcurb
Tension <sub>SEISMIC</sub> =	1473	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S <sub>DS</sub> ) * Wt'min * Lcurb] / Lcurb
Compression <sub>WIND</sub> =	534	lbs	= [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb
Tension <sub>WIND</sub> =	487	lbs	= [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb

---> Negative values indicate opposite load.

#### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	2723	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	2159	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	2036	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	1473	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.








## Curb Design

F<sub>y</sub> = 50 ksi  
E = 29500 ksi  
F<sub>u</sub> = 65 ksi  
t = 0.0713 14 Gauge

## Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 128.737 in	r <sub>x</sub> = 8.00 in
I <sub>y</sub> = 0.218 in	r <sub>y</sub> = 0.329 in
A = 2.01 in <sup>2</sup>	r <sub>min</sub> = 0.329 in



## Axial Compression

P<sub>u</sub> = 1.135 k (Max Axial Comp) Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 18.917 k  
F<sub>e</sub> = 19.29 ksi  
λ<sub>c</sub> = 1.61  
F<sub>n</sub> = 16.91 ksi  
L<sub>y</sub> = 50.50 in  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 123

If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>)F<sub>y</sub>  
If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$

λ<sub>c</sub> =  $\sqrt{\frac{F_y}{F_e}}$  F<sub>e</sub> =  $\frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

## Check Web Crippling

h = 25 in -- Check limits: C = 4.00  
t = 0.0713 in h/t = 350.63 ≤ 260 C<sub>R</sub> = 0.14  
N = 7.00 N/t = 98.18 ≤ 210 C<sub>N</sub> = 0.35  
Ω<sub>w</sub> = 1.75 N/h = 0.28 ≤ 2.0 C<sub>h</sub> = 0.02  
P<sub>n</sub> = 2.105 k R/t = 1.50 ≤ 9.0  
P<sub>n</sub>/Ω<sub>w</sub> = 1.203 k  
Long side: P<sub>uTrans</sub> = 2.723 k web stiffener REQ'D # clips = 1  
Short side: P<sub>uLong</sub> = 2.036 k web stiffener REQ'D # clips = 1

\*\*\*h/t > 260; use web stiffeners

$P_n = Ct^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, one flange, end loading)

## Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)  
width of stiffener = 7.000 in ts = 0.0566 16 Gauge  
web of stiff. w = 6.717 in Rs = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28VE/F<sub>y</sub> Ω<sub>c</sub> = 1.70  
w/ts = 118.675  
1.28V(E/F<sub>y</sub>) = 31.091 --> w/ts over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>  
P<sub>wc</sub> = 2.105 k Ae = 0.380 in<sup>2</sup>  
P<sub>n</sub> = 14.780 k  
P<sub>n</sub>/Ω<sub>c</sub> = 8.694 k O.K.

## Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 682 lbs Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 1361 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: T<sub>all</sub> = 2480 lbs V<sub>all</sub> = 1208 lbs  
Threaded Insert: T<sub>all</sub> = 2860 lbs V<sub>all</sub> = 1096 lbs  
# of Bolts required for Tension = 0.3  
# of Bolts required for Shear = 1.2  
# of Bolts Used = 3.0  
Check Combined Stress in Bolts & Inserts: 0.506 O.K.

## Check 1/8" welded connection

USE WELD

Ω = 2.35

Assume L/t > 25: 25\*t = 1.783 in  
L<sub>req'd</sub> = 0.920 in  
P<sub>n</sub>/Ω =  $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$  L<sub>req'd</sub> =  $\frac{V_{req}\Omega}{0.75tF_u}$



## Curb Loads (copied from upper rail calcs)

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> = 2613 lbs Tens <sub>MAX</sub> = 2108 lbs Shear <sub>MAX</sub> = 2270 lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> = 1881 lbs Tens <sub>MAX</sub> = 1375 lbs Shear <sub>MAX</sub> = 2270 lbs

Max compression force on isolator: 2.613 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 2.108 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 0.567 k ≤ 1.163 k **O.K.**

## Forces on bottom bolts:

$d_b = 0.5$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 1.054 k / bolt  
 Shear = 0.284 k / bolt

**Shear on base curb:**  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n / \Omega = 4.635$  k  $e = 1.0$  in

**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n / \Omega = 5.909$  k  $A_n = 0.107$  in

**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C_m d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n / \Omega = 2.781$  k  $d / t = 7.01$

**Bearing O.K.**

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)  
 Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt} / \Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$   
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv} / \Omega = 2.209$  k **Bolt shear O.K.** **\*\*\* (Table E3.4-1, AISI) \*\*\***

## Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 10.73$  ksi  $f_v = 1.44$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv} / \Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt} / \Omega = 3.927$  k **Combined Not Applicable -> F'nt = Fnt**

## Connection of Curb to Supporting Structure

**Roof Loading** SEISMIC:  $(0.6-0.14 S_{DS})D + 0.7E$  WIND:  $0.6D + W$



<b>Transverse:</b>	Uplift <sub>MAX</sub> = 4533 lbs	Shear <sub>MAX</sub> = 1365 lbs
Compression <sub>SEISMIC</sub> =	5141 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Tension <sub>SEISMIC</sub> =	4533 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Compression <sub>WIND</sub> =	1781 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Tension <sub>WIND</sub> =	1666 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$
<b>Longitudinal:</b>	Uplift <sub>MAX</sub> = 3109 lbs	Shear <sub>MAX</sub> = 1365 lbs
Compression <sub>SEISMIC</sub> =	3717 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Tension <sub>SEISMIC</sub> =	3109 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Compression <sub>WIND</sub> =	891 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$
Tension <sub>WIND</sub> =	776 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$

**Wood Attachment:** 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

	Tall <sub>metal</sub> = 997 lbs	Vall <sub>metal</sub> = 1097 lbs
<b>Transverse:</b>	Tall <sub>wood</sub> = 760 lbs	Vall <sub>wood</sub> = 672 lbs
# of Screws Req'd for Uplift =	5.96	COMBINED LOADING: 0.902 O.K.
# of Screws Req'd for Shear =	2.03	Req'd Min Spacing = 6.07 in o.c.
Total # of screws required =	8	

Use 8 - 1/4" φ x 4.5" Simpson SDS screws @ 6.1 in o.c. along long side of curb w/ 2.75" threaded embed

<b>Loads at each Isolator</b>	Type:	CQA
<b>Transverse loading:</b> (on long edge)	Comp <sub>MAX</sub> = 2613.2 lbs Tens <sub>MAX</sub> = 2107.6 lbs Shear <sub>MAX</sub> = 567.4 lbs	
# isolators: 1		
<b>Longitudinal loading:</b> (on short edge)	Comp <sub>MAX</sub> = 1881.1 lbs Tens <sub>MAX</sub> = 1375.5 lbs Shear <sub>MAX</sub> = 567.4 lbs	
# isolators: 1		





## Longitudinal:

# of Screws Req'd for Uplift = 4.09  
# of Screws Req'd for Shear = 2.03  
Total # of screws required = 5

COMBINED LOADING: 0.974 O.K.  
Screw Spacing = 6.75 in o.c.

Use 5 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 6.8 in o.c. along short side of curb w/ 2.75" threaded embed

## Steel Deck Attachment: 1/2" $\phi$ A307 Bolts to steel angle below deck

Transverse: Tall<sub>bolt</sub> = 3927 lbs Vall<sub>bolt</sub> = 2209 lbs  
Tall<sub>metal</sub> = 2086 lbs Vall<sub>metal</sub> = 2192 lbs  
# of Bolts Req'd for Uplift = 2.17  
# of Bolts Req'd for Shear = 0.62  
Total # of bolts required = 3

COMBINED LOADING: 0.849 O.K.  
Bolt Spacing = 19.25 in o.c.

Use 3 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 19.3 in o.c. along long side of curb

## Longitudinal:

# of Bolts Req'd for Uplift = 1.49  
# of Bolts Req'd for Shear = 0.62  
Total # of bolts required = 2

COMBINED LOADING: 0.621 O.K.  
Bolt Spacing = 23.00 in o.c.

Use 2 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 23 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>o</sub> E  $\Omega_o = 2.5$

## Concrete Attachment: 0.625in $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c$  = 4000 psi  
h = 6 in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
 $h_{ef}$  = 4 in (effective embedment)  
da = 0.625 in (anchor diameter)  $d_o$  = 0.75 in (hole diameter)  
n = 5 (number of dummy anchors to check capacity with spacing effect)  
s = 14 in (initial spacing estimate)  
tk<sub>cr</sub> / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)  
tk<sub>cr</sub> / uncr = 1226 2327 psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
 $c_{Na} = 9.0625$  in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

## Tension:

Bond strength  
\*\*\*Bond strength  
will govern over  
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1343.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 38995 \text{ lbs (group)}$$

$$\phi N_{ag} = 19010 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

## Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 816 \text{ in}^2$$

$$N_b = 8601 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 144 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 48741 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 27417 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

## Shear:

### Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 3802 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 2225 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift<sub>MAX</sub> = 5489 lbs Shear<sub>MAX</sub> = 3411 lbs

$$\text{Compression}_{SEISMIC} = 6078 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 5489 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3411 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.47 \text{ spacing} = 19.25 \text{ in o.c.}$$

$$T_{applied} = 1372.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 38.50 \text{ in o.c.}$$


$$V_{applied} = 568.6 \text{ lbs}$$

Try using 4 bolts  
spaced at 12.83 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.93 \text{ O.K.}$$

Use 4 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 12.8 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift<sub>MAX</sub> = 3773 lbs Shear<sub>MAX</sub> = 3411 lbs





# MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
(619)727-4800  
Page 8 of 8

$$\begin{aligned}
 \text{Compression}_{\text{SEISMIC}} &= 4362 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Tension}_{\text{SEISMIC}} &= 3773 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Shear}_{\text{SEISMIC}} &= 3411 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\
 \text{Min Bolts Req'd Uplift} &= 1.70 \text{ spacing} = 11.50 \text{ in o.c.} &\text{Applied} = 1886.4 \text{ lbs} \\
 \text{Min Bolts Req'd Shear} &= 2.00 \text{ spacing} = 23.00 \text{ in o.c.} &\text{Applied} = 568.6 \text{ lbs} \\
 \text{Try using } 2 \text{ bolts spaced at } 23.00 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.16 \text{ O.K.}
 \end{aligned}$$

Use 2 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 23 in o.c. max. along short side of curb w/ 4in embed

<b>CURB DESIGN SUMMARY:</b>		CBISC-01	CBISCLXS	<b>Unit:</b>	ALL P***A CABINET
<b>UPPER CURB RAIL THICKNESS:</b>		0.0713 in	14 Gauge		
<b>UNIT CLIP THICKNESS:</b>		0.0713 in	14 Gauge		
<b># OF CLIPS (LONG SIDE)</b> - 1 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b># OF CLIPS (SHORT SIDE)</b> - 1 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b>VIBRATION ISOLATOR TYPE:</b> CQA		Top stud diameter: 3/8		(1) - CQA Isolators long side	
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16		(1) - CQA Isolators short side	
<b>BASE CURB THICKNESS:</b> 0.0713 in		14 Gauge		***Must weld top of CQA***	
<b>WEB STIFFENER:</b> 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
<b>CORNER CONNECTION:</b> Use minimum 3 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
<b>CURB ANCHORAGE</b>	<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>
	1/4" $\phi$ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" $\phi$ A307 Bolts to steel angle below deck		0.625in $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed
	<u>LONG DIRECTION</u>		8 @ 6.07 in o.c.		3 @ 19.25 in o.c.
	<u>SHORT DIRECTION</u>		5 @ 6.75 in o.c.		2 @ 23 in o.c.
		2 @ 23 in o.c.		4 @ 12.83 in o.c.	