



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBISC-04 Series**  
**CBISCPRD3715\*\* SERIES**




**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: August 23, 2023**  
**Project Number: PV2312**

# WELDMENT AND BOLTING DETAIL

\* OPTIONAL  
WELD I.L.O.  
BOLTED STUD



(3) 5/16" BOLTS  
GRADE 5 EA SIDE  
OF THE STIFFENER  
  
(2) EA SIDE FOR  
UPPER RAIL SUPPORT

## BASE CURB SUPPORT

Note: \* - INDICATES WELD REQUIRED I.L.O.  
BOLTED STUD FOR THE FOLLOWING CURBS:


- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM  
BUMPER FOR:  
ISCALSLU180  
ISCALSLM1830

FOR JQA/CQA:  
5/16" Ø HOLE USE 1/2" Ø A307 BOLT  
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:  
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT  
WITH FLAT WASHER AND NUT

## FOR BOLT ON ISOLATORS



HOLE FOR ISOLATOR STUD,  
W/ FLAT WASHER REQUIRED  
UNDER NUT  
7/16" FOR JQA/CQA  
9/16" FOR JQB/JQBX  
1 1/16" FOR JQE/JQF

NEOPRENE CUP  
UNDER SPRING

1/4" THICK NEOPRENE PAD  
REQUIRED



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CB-61


DATE:  
08/14/23

REV:  
2

DRAWN BY:  
FMM

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

### ASSUMES:

CONC SLAB  
 $f_c = 4000$ PSI MINIMUM  
6" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 9-1/8" EDGE DISTANCE.

### CONCRETE ATTACHMENT



Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SAV1518
SAV2025
SAV28

NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-62

DATE:  
6/28/2023

REV:  
4

DRAWN BY:  
FMM

For wood, concrete and steel attachment see  
Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard.  
For bolted spring housing, neoprene pads and  
spring cups see Weldment and Bolting Detail,  
Form No. CB-61

## STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURBS FOR PREDATOR (SUN PRO) UNITS




ZT, ZH, ZJ, ZR 037-150  
ZF, XP, ZB 078-150

### FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROVENT P/N	A	B	EST. WEIGHT
CBISCPRD371518**	8"	18"	365 Lbs
CBISCPRD371521**	11"	21"	387 Lbs
CBISCPRD371524**	14"	24"	410 Lbs
**Note: Spring configuration must be added to part number at time of order			
Weight of upper portion supported by spring isolators= 243 Lbs.			
Meets seismic requirements for the following codes: CBC 2022 IBC 2021			



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBISC-04

DATE:  
8/14/2023

PART NUMBER:  
-

REV:  
5

DRAWN BY:  
FMM




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-04	Iso Curb	CBISCPRD3715
Unit:	ZT,ZH, ZR,ZJ 037-150; ZF, XP, ZB 078-150		

### Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	80.875	in	(Length of upper curb)
wcurb =	51	in	(Width of upper curb)
WGtupper =	243	lbs	(Weight of upper curb)
# Clips long side =	3		
# Clips short side =	2		

### Unit Information

WGtunit =	1736	lbs	(Weight of Unit)
Wtmax =	521	lbs	(Maximum corner weight)
Wtmin =	369	lbs	(Minimum corner weight)
Hunit =	50.75	in	(Height of unit above curb)
Hcm =	25.375	in	(Height to center of mass)
Lunit =	89	in	(Length of unit)
Wunit =	59	in	(Width of unit)



### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.80	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.360	(Fa*Ss)
Sds =	2.240	(2/3*Sms)
Fpmax =	5.040	Wp
FpmaxASD =	6125	lbs
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	6982	lbs
	(unit + upper rail)	

### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	1179	lbs
Fh ASD long =	782	lbs
Fvert ASD =	976	lbs

$$= 0.00256 * Kz * Kzt * Kd * Ke * V^2 \quad (\text{Eq. 26.10-1 ASCE 7-16})$$

$$= 0.6 * qz * GCr * Lunit * (Hunit + Hcurb) \quad (\text{Eq. 29.4-2})$$

$$= 0.6 * qz * GCr * Wunit * (Hunit + Hcurb)$$

$$= 0.6 * qz * GCr * Lunit * Wunit \quad (\text{Eq. 29.4-3})$$

### Upper Curb Loading

<b>Transverse:</b>			
Compression <sub>SEISMIC</sub> =	4416	lbs	$= [FpmaxASD * Hcm + 2 * (1 + 0.14S_{DS}) * Wtmax * wcurb] / wcurb$
Tension <sub>SEISMIC</sub> =	2836	lbs	$= [FpmaxASD * Hcm - 2 * (0.6 - 0.14S_{DS}) * Wtmin * wcurb] / wcurb$
Compression <sub>WIND</sub> =	723	lbs	$= [F_{h ASD trans} * Hcm + 2 * 0.6 * Wtmax * wcurb - F_{vert ASD} * wcurb / 2] / wcurb$
Tension <sub>WIND</sub> =	632	lbs	$= [F_{h ASD trans} * Hcm - 2 * 0.6 * Wtmin * wcurb + F_{vert ASD} * wcurb / 2] / wcurb$

---> Negative values indicate opposite load.

<b>Longitudinal:</b>			
Compression <sub>SEISMIC</sub> =	3290	lbs	$= [FpmaxASD * Hcm + 2 * (1 + 0.14 * S_{DS}) * Wtmax * Lcurb] / Lcurb$
Tension <sub>SEISMIC</sub> =	1710	lbs	$= [FpmaxASD * Hcm - 2 * (0.6 - 0.14S_{DS}) * Wtmin * Lcurb] / Lcurb$
Compression <sub>WIND</sub> =	382	lbs	$= [F_{h ASD long} * Hcm + 2 * 0.6 * Wtmax * Lcurb - F_{vert ASD} * Lcurb / 2] / Lcurb$
Tension <sub>WIND</sub> =	291	lbs	$= [F_{h ASD long} * Hcm - 2 * 0.6 * Wtmin * Lcurb + F_{vert ASD} * Lcurb / 2] / Lcurb$

---> Negative values indicate opposite load.

### Governing Reactions:

<b>Transverse:</b>		Comp <sub>MAX</sub> =	4416	lbs	---> Along long edge of curb.
(on long edge)		Tens <sub>MAX</sub> =	2836	lbs	---> Along long edge of curb.
<b>Longitudinal:</b>		Comp <sub>MAX</sub> =	3290	lbs	---> Along short edge of curb.
(on short edge)		Tens <sub>MAX</sub> =	1710	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




**Curb Design**

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

**Calculate Section Properties of Curb**

A' = 5.500 in	a = 5.144 in = A' - (2r + t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 2.687 in <sup>4</sup>	r <sub>x</sub> = 2.08 in
I <sub>y</sub> = 0.169 in <sup>4</sup>	r <sub>y</sub> = 0.521 in
A = 0.62 in <sup>2</sup>	r <sub>min</sub> = 0.521 in



**Axial Compression**

P<sub>a</sub> = 3.062 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80

P<sub>n</sub>/Ω<sub>c</sub> = 11.798 k

Fe = 54.67 ksi       $\lambda_c = \frac{F_y}{F_e}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$

λ<sub>c</sub> = 0.96       $\Omega_c = \frac{F_n A}{F_e A}$       If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658<sup>λ<sub>c</sub>²</sup>) F<sub>y</sub>

F<sub>n</sub> = 34.10 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$

Ly = 47.50 in      Lateral unbraced length

k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 73      (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 5.5 in      -- Check limits:      C = 7.50

t = 0.0713 in      h/t = 77.14 ≤ 260      C<sub>R</sub> = 0.08

N = 7.00      N/t = 98.18 ≤ 210      C<sub>N</sub> = 0.12

Ω<sub>w</sub> = 1.75      N/h = 1.273 ≤ 2.0      C<sub>h</sub> = 0.048

P<sub>n</sub> = 1.947 k      R/t = 1.50 ≤ 12.0

P<sub>n</sub>/Ω<sub>w</sub> = 1.112 k       $P_n = C t^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$

Long side: P<sub>Utrans</sub> = 1.472 k      **web stiffener REQ'D**      # clips = 3

Short side: P<sub>ULong</sub> = 1.645 k      **web stiffener REQ'D**      # clips = 2

(See table C3.4.1-2, fastened to support, two flange, end loading)

**Check Web Stiffener**

16Ga x 3/4in x 7in (C-channel)      P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>

width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 16 Gauge      P<sub>wc</sub> = 1.947 k

web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in      P<sub>n</sub> = 14.669 k

\*\*\*Check w/t<sub>s</sub> ≤ 1.28√E/F<sub>y</sub>      Ω<sub>c</sub> = 1.70      A<sub>e</sub> = 0.380 in<sup>2</sup>

w/t<sub>s</sub> = 118.675

1.28√(E/F<sub>y</sub>) = 31.091      --> w/t<sub>s</sub> over limit      Use C3.7.2      P<sub>n</sub>/Ω<sub>c</sub> = 8.629 k      **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

T<sub>crnmax</sub> = 1745 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)

V<sub>crnmax</sub> = 2208 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs      Vall = 1208 lbs

Threaded Insert: Tall = 2860 lbs      Vall = 1096 lbs

# of Bolts required for Tension = 0.7

# of Bolts required for Shear = 2.0

# of Bolts Used = 4.0

Check Combined Stress in Bolts & Inserts: 0.680 **O.K.**

**Check 1/8" welded connection**

<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25\*t = 1.783 in       $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$        $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

L<sub>req'd</sub> = 1.493 in



**Connection Unit to Curb Clip** #10 SMS screw  $\Omega = 3.0$


$t_1 = 0.0713$  in (clip thickness)  $t_2/t_1 = 1.0$   $F_{u1} = 65$  ksi  
 $t_2 = 0.0713$  in (unit base rail thickness)  $F_{u2} = 65$  ksi  
 $d = 0.190$  in (screw diameter)  $d_w = 0.375$  in (nom. washer diameter)

For  $t_2/t_1 \leq 1.0$ :  $P_{ns} = 2266$  # For  $t_2/t_1 \geq 2.5$ :  $P_{ns} = 2377$  #  
**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$  2.27 k  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  
**Tension:**  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  $P_{ns} = 2.7t_2dF_{u2}$  2.38 k  
 $P_{ns}/\Omega = 755$  #  
 $P_{ss}/\Omega = 540$  # <- Controls  
 $P_{not} = 0.748$  k (screw pull-out strength)  $P_{not} = 0.85t_c d F_{u2}$   
 $P_{nov} = 2.607$  k (screw pull-over strength)  $t_c = \min(t_1, t_2)$   
 $P_{ts}/\Omega = 249$  # <- Controls  $P_{nov} = 1.5t_1 d_w F_{u1}$   
 $P_{ts}/\Omega = 820$  # (full tensile screw capacity)

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	3.062	3	1.02	540 #	4	2.00 in
Short side:	3.062	2	1.53	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in  
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)  
Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies  
 $F_y = 50$  ksi  $\Omega = 2.22$  bolt/screw connection  
 $A_{gv} = 0.463$  in<sup>2</sup>  $A_{nv} = 0.416$  in<sup>2</sup>  $A_{nt} = 0.082$  in<sup>2</sup>  
 $R_n/\Omega = 8.674$  k  $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$  (AISI Sect. E5.3)

**BSR O.K.**



**Curb Loads** (copied from above)

<b>Transverse:</b>	Comp <sub>MAX</sub> = 5527 lbs
(on long edge)	Tens <sub>MAX</sub> = 3943 lbs
	Shear <sub>MAX</sub> = 6982 lbs
<b>Longitudinal:</b>	Comp <sub>MAX</sub> = 3965 lbs
(on short edge)	Tens <sub>MAX</sub> = 2382 lbs
	Shear <sub>MAX</sub> = 6982 lbs

**Loads at each Isolator**

Type: CQA

<b>Transverse loading:</b>	Comp <sub>MAX</sub> = 2763.3 lbs
(on long edge)	Tens <sub>MAX</sub> = 1971.7 lbs
# isolators: 2	Shear <sub>MAX</sub> = 872.7 lbs
<b>Longitudinal loading:</b>	Comp <sub>MAX</sub> = 1982.6 lbs
(on short edge)	Tens <sub>MAX</sub> = 1191.0 lbs
# isolators: 2	Shear <sub>MAX</sub> = 872.7 lbs

Max compression force on isolator: 2.763 k  $\leq 3.176$  k **O.K.**  
Max uplift on isolator: 1.972 k  $\leq 3.176$  k **O.K.**  
Max shear on isolator: 0.873 k  $\leq 1.163$  k **O.K.**

**Forces on top bolt:**

Tension = 1.972 k  $d_b = 0.375$  in  
Shear = 0.873 k upper rail,  $t = 0.0713$  in

**Shear on curb rail:**

$P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)

**Shear O.K.**

$P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**

$P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**

$P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**

$C = 3.00$   $m_f = 1.00$

**Shear and tension in bolt:**

(Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>

$P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 17.85$  ksi  $f_v = 7.90$  ksi **O.K.**

$P'_{nt}/\Omega = 1.014$  k  $F'_{nt} = 20.65$  ksi  $F_{nv}/\Omega = 10.00$  ksi

**No Good - Use Welds**

**Longitudinal weld loading:**

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$

If  $L/t < 25$ :  $L/t = 21.04$   $t = 0.0713$   $P_n/\Omega = 2.153$  k

**Transverse weld loading:**

$t = 0.0713$   $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$

$L = 1$   $F_u = 65$  ksi  $P_n/\Omega = 1.972$  k





Client:	ProVent	PV2312	Base curb
Project:	CBISC-04	Iso Curb	CBISCPRD3715
Unit:	ZT,ZH, ZR,ZJ 037-150; ZF, XP, ZB 078-150		

#### Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	83.375	in	(Length of base curb)
wcurb =	53.5	in	(Width of base curb)
WGTbase =	167	lbs	(Weight of base curb)
# Springs long side =	2		# Springs short side = 2

#### Unit Information

WGUnit =	1736	lbs	(Weight of Unit)
Wt'max =	582	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	430	lbs	(Wtmin+1/4*WGUpper)
Hunit =	50.75	in	(Height of unit above curb)
H'cm =	35.375	in	(Hcm+10"(upper+spring))
Lunit =	89	in	(Length of unit)
Wunit =	59	in	(Width of unit)
WGUnit+upper+base =	2146	lbs	(Total weight)

#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.80	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.360	(Fa*Ss)
Sds =	2.240	(2/3*Sms)
Fpmax =	5.040	Wp
FpmaxASD =	6982	lbs
	(unit + upper rail)	
ap =	2.5	
Rp =	2	
FpmaxASD =	7571	lbs
	(unit + upper rail + base curb)	

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf
Fh ASD trans =	1798	lbs
Fh ASD long =	1192	lbs
Fvert ASD =	976	lbs

#### Base Curb Loading

##### Transverse:

Compression <sub>SEISMIC</sub> =	6144	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14S <sub>DS</sub> ) * Wt'max * wcurb] / wcurb
Tension <sub>SEISMIC</sub> =	4370	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14S <sub>DS</sub> ) * Wt'min * wcurb] / wcurb
Compression <sub>WIND</sub> =	1398	lbs	= [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb
Tension <sub>WIND</sub> =	1161	lbs	= [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb

---> Negative values indicate opposite load.

##### Longitudinal:


Compression <sub>SEISMIC</sub> =	4490	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14S <sub>DS</sub> ) * Wt'max * Lcurb] / Lcurb
Tension <sub>SEISMIC</sub> =	2716	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14S <sub>DS</sub> ) * Wt'min * Lcurb] / Lcurb
Compression <sub>WIND</sub> =	715	lbs	= [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb
Tension <sub>WIND</sub> =	478	lbs	= [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb

---> Negative values indicate opposite load.

#### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	6144	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	4370	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	4490	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	2716	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.








## Curb Design

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

## Calculate Section Properties of Curb

A' = <span style="border: 1px solid black; padding: 2px;">25.000</span> in	a = 24.644 in = A' - (2r + t)
B' = <span style="border: 1px solid black; padding: 2px;">1.750</span> in	a' = 24.929 in = A' - t
C' = <span style="border: 1px solid black; padding: 2px;">0.000</span> in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = <span style="border: 1px solid black; padding: 2px;">0.000</span> (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 128.737 in	r <sub>x</sub> = 8.00 in
I <sub>y</sub> = 0.218 in	r <sub>y</sub> = 0.329 in
A = 2.01 in <sup>2</sup>	r <sub>min</sub> = 0.329 in



## Axial Compression

P<sub>u</sub> = 3.491 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 6.940 k  
F<sub>e</sub> = 7.08 ksi       $\lambda_c = \frac{F_y}{F_e}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$   
λ<sub>c</sub> = 2.66      If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>  
F<sub>n</sub> = 6.21 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$   
L<sub>y</sub> = 83.38 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 203 (assume k=0.8)

**Compression Check = O.K.**

## Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 260	C <sub>R</sub> = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C <sub>N</sub> = 0.35	
Ω <sub>w</sub> = 1.75	N/h = 0.28 ≤ 2.0	C <sub>h</sub> = 0.02	
P <sub>n</sub> = 2.105 k	R/t = 1.50 ≤ 9.0		
P <sub>n</sub> /Ω <sub>w</sub> = 1.203 k			
Long side: P <sub>uTrans</sub> = 3.072 k	<b>web stiffener REQ'D</b> # clips = 2	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P <sub>uLong</sub> = 2.245 k	<b>web stiffener REQ'D</b> # clips = 2		

**\*\*\*h/t > 260; use web stiffeners**

## Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 16 Gauge  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/t<sub>s</sub> ≤ 1.28V<sub>e</sub>/F<sub>ys</sub>      Ω<sub>c</sub> = 1.70  
w/t<sub>s</sub> = 118.675  
1.28V<sub>e</sub>(E/F<sub>ys</sub>) = 31.091 --> w/t<sub>s</sub> over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>      A<sub>e</sub> = 0.380 in<sup>2</sup>  
P<sub>wc</sub> = 2.105 k  
P<sub>n</sub> = 14.780 k  
P<sub>n</sub>/Ω<sub>c</sub> = 8.694 k      **O.K.**

## Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 1893 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 3072 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: T<sub>all</sub> = 2480 lbs      V<sub>all</sub> = 1208 lbs  
Threaded Insert: T<sub>all</sub> = 2860 lbs      V<sub>all</sub> = 1096 lbs  
# of Bolts required for Tension = 0.8  
# of Bolts required for Shear = 2.8  
# of Bolts Used = 4.0  
Check Combined Stress in Bolts & Inserts: 0.892 **O.K.**

## Check 1/8" welded connection

---- USE WELD

Ω = 2.35

Assume L/t > 25: 25\*t = 1.783 in       $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$        $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$   
L<sub>req'd</sub> = 2.077 in



## Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp <sub>MAX</sub> =	5527	lbs
	Tens <sub>MAX</sub> =	3943	lbs
	Shear <sub>MAX</sub> =	6982	lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> =	3965	lbs
	Tens <sub>MAX</sub> =	2382	lbs
	Shear <sub>MAX</sub> =	6982	lbs

Max compression force on isolator: 2.763 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 1.972 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 0.873 k ≤ 1.163 k **O.K.**

## Forces on bottom bolts:

$d_b = 0.5$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 0.986 k / bolt  
 Shear = 0.436 k / bolt

Shear on base curb:  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n / \Omega = 4.635$  k  $e = 1.0$  in

**Shear O.K.**

Net section rupture:  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n / \Omega = 5.909$  k  $A_n = 0.107$  in

**N.S.R. O.K.**

Bolt Bearing Strength:  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n / \Omega = 2.781$  k  $d / t = 7.01$

**Bearing O.K.**

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)  
 Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt} / \Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$   
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv} / \Omega = 2.209$  k **Bolt shear O.K.** **\*\*\* (Table E3.4-1, AISI) \*\*\***

## Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 10.04$  ksi  $f_v = 2.22$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv} / \Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt} / \Omega = 3.927$  k **Combined Not Applicable ->  $F'_{nt} = F_{nt}$**

## Connection of Curb to Supporting Structure

**Roof Loading** SEISMIC:  $(0.6-0.14 S_{DS}) D + 0.7 E$  WIND:  $0.6 D + W$

<b>Transverse:</b>	<b>Uplift<sub>MAX</sub> =</b>	<b>8237 lbs</b>	<b>Shear<sub>MAX</sub> =</b>	<b>3786 lbs</b>
Compression <sub>SEISMIC</sub> =	9954 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb		
Tension <sub>SEISMIC</sub> =	8237 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb		
Compression <sub>WIND</sub> =	2184 lbs	= [F <sub>h ASD trans</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *wcurb/2-F <sub>vert ASD</sub> *wcurb/2]/wcurb		
Tension <sub>WIND</sub> =	1873 lbs	= [F <sub>h ASD trans</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *wcurb/2+F <sub>vertASD</sub> *wcurb/2]/wcurb		
<b>Longitudinal:</b>	<b>Uplift<sub>MAX</sub> =</b>	<b>5175 lbs</b>	<b>Shear<sub>MAX</sub> =</b>	<b>3786 lbs</b>
Compression <sub>SEISMIC</sub> =	6892 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb		
Tension <sub>SEISMIC</sub> =	5175 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb		
Compression <sub>WIND</sub> =	1019 lbs	= [F <sub>h ASD long</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb		
Tension <sub>WIND</sub> =	707 lbs	= [F <sub>h ASD long</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2+F <sub>vertASD</sub> *Lcurb/2]/Lcurb		

## Wood Attachment: 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)



	Tall <sub>metal</sub> =	<div>997</div>	lbs	Vall <sub>metal</sub> =	<div>1097</div>	lbs
<u>Transverse:</u>	Tall <sub>wood</sub> =	<div>760</div>	lbs	Vall <sub>wood</sub> =	<div>672</div>	lbs
# of Screws Req'd for Uplift =		10.84		COMBINED LOADING:		0.948 O.K.
# of Screws Req'd for Shear =		5.63		Req'd Min Spacing =	<div>5.38</div>	in o.c.
Total # of screws required =		<div>15</div>				

Use 15 - 1/4" φ x 4.5" Simpson SDS screws @ 5.4 in o.c. along long side of curb w/ 2.75" threaded embed

## Loads at each Isolator

Type: CQA

Transverse loading: (on long edge)	Comp <sub>MAX</sub> =	2763.3	lbs
# isolators: 2	Tens <sub>MAX</sub> =	1971.7	lbs
	Shear <sub>MAX</sub> =	872.7	lbs
Longitudinal loading: (on short edge)	Comp <sub>MAX</sub> =	1982.6	lbs
# isolators: 2	Tens <sub>MAX</sub> =	1191.0	lbs
	Shear <sub>MAX</sub> =	872.7	lbs



O.K.



Longitudinal:

# of Screws Req'd for Uplift = 6.81  
# of Screws Req'd for Shear = 5.63  
Total # of screws required = 10

COMBINED LOADING: 0.906 O.K.  
Screw Spacing = 5.06 in o.c.

Use 10 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 5.1 in o.c. along short side of curb w/ 2.75" threaded embed

**Steel Deck Attachment: 1/2"  $\phi$  A307 Bolts to steel angle below deck**

Transverse: Tall<sub>bolt</sub> = 3927 lbs Vall<sub>bolt</sub> = 2209 lbs  
Tall<sub>metal</sub> = 2086 lbs Vall<sub>metal</sub> = 2192 lbs  
# of Bolts Req'd for Uplift = 3.95  
# of Bolts Req'd for Shear = 1.73  
Total # of bolts required = 6

COMBINED LOADING: 0.850 O.K.  
Bolt Spacing = 14.28 in o.c.

Use 6 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 14.3 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 2.48  
# of Bolts Req'd for Shear = 1.73  
Total # of bolts required = 3

COMBINED LOADING: 0.605 O.K.  
Bolt Spacing = 20.75 in o.c.

Use 3 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 20.8 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>o</sub> E  $\Omega_o = 2.5$

**Concrete Attachment: 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed**

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c$  = 4000 psi  
h = 6 in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
 $h_{ef}$  = 4 in (effective embedment)  
da = 0.625 in (anchor diameter) do = 0.75 in (hole diameter)  
n = 5 (number of dummy anchors to check capacity with spacing effect)  
s = 8 in (initial spacing estimate)  
tk<sub>cr</sub> / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)  
tk<sub>cr</sub> / uncr = 1226 2327 psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
 $c_{Na} = 9.0625$  in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**

Bond strength  
\*\*\*Bond strength  
will govern over  
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 908.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 26369 \text{ lbs (group)}$$

$$\phi N_{ag} = 12855 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

**Breakout strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 528 \text{ in}^2$$

$$A_{Nco} = 144 \text{ in}^2$$

$$N_{cbg} = 31538 \text{ lbs (group)}$$

$$\phi N_{cbg} = 17740 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 8601 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

**Shear:**

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 3067$$

$$\alpha_{v,seismic} = 0.6$$

$$Tall_{LRFD} = 2571 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 1513 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1805 \text{ lbs}$$

$$D = 0.761 \quad E = 0.239 \quad \alpha = 1.699$$

Transverse: Uplift<sub>MAX</sub> = 11208 lbs Shear<sub>MAX</sub> = 9464 lbs

$$\text{Compression}_{SEISMIC} = 13069 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 11208 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 9464 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 7.41 \text{ spacing} = 10.20 \text{ in o.c.}$$

$$T_{applied} = 1245.4 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 5.24 \text{ spacing} = 14.28 \text{ in o.c.}$$


$$V_{applied} = 630.9 \text{ lbs}$$

Try using 9 bolts  
spaced at 8.92 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.17 \text{ O.K.}$$

Use 9 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 8.9 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift<sub>MAX</sub> = 7073 lbs Shear<sub>MAX</sub> = 9464 lbs





# MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
(619)727-4800  
Page 8 of 8

$$\begin{aligned}
 \text{Compression}_{\text{SEISMIC}} &= 8934 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Tension}_{\text{SEISMIC}} &= 7073 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Shear}_{\text{SEISMIC}} &= 9464 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\
 \text{Min Bolts Req'd Uplift} &= 4.67 \text{ spacing} = 10.38 \text{ in o.c.} &\text{Applied} = 1178.8 \text{ lbs} \\
 \text{Min Bolts Req'd Shear} &= 5.24 \text{ spacing} = 8.30 \text{ in o.c.} &\text{Applied} = 630.9 \text{ lbs} \\
 \text{Try using } 6 \text{ bolts spaced at } 8.30 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.13 \text{ O.K.}
 \end{aligned}$$

Use 6 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 8.3 in o.c. max. along short side of curb w/ 4in embed

<b>CURB DESIGN SUMMARY:</b>		CBISC-04	CBISCPRD3715	<b>Unit:</b>	ZT, ZH, ZR, ZJ 037-150; ZF, XP, ZB 078-150
<b>UPPER CURB RAIL THICKNESS:</b>		0.0713 in	14 Gauge		
<b>UNIT CLIP THICKNESS:</b>		0.0713 in	14 Gauge		
<b># OF CLIPS (LONG SIDE)</b> - 3 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b># OF CLIPS (SHORT SIDE)</b> - 2 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
<b>VIBRATION ISOLATOR TYPE:</b> CQA		Top stud diameter: 3/8		(2) - CQA Isolators long side	
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16		(2) - CQA Isolators short side	
<b>BASE CURB THICKNESS:</b> 0.0713 in		14 Gauge		***Must weld top of CQA***	
<b>WEB STIFFENER:</b> 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
<b>CORNER CONNECTION:</b> Use minimum 4 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
<b>CURB ANCHORAGE</b>	<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>
	1/4" $\phi$ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" $\phi$ A307 Bolts to steel angle below deck		0.625in $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed
	<u>LONG DIRECTION</u>		15 @ 5.38 in o.c.		6 @ 14.28 in o.c.
	<u>SHORT DIRECTION</u>		10 @ 5.06 in o.c.		3 @ 20.75 in o.c.
				9 @ 8.92 in o.c.	
				6 @ 8.3 in o.c.	