



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-05 Series
CBISCPRS SERIES**




Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 23, 2023
Project Number: PV2312

WELDMENT AND BOLTING DETAIL

* OPTIONAL
WELD I.L.O.
BOLTED STUD



(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

BASE CURB SUPPORT


Note: * - INDICATES WELD REQUIRED I.L.O.
BOLTED STUD FOR THE FOLLOWING CURBS:

- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA/CQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
08/14/23

REV:
2

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.

WELDED CURB

SHEATHING WHERE OCCURS

METAL DECK

STEEL ANGLE SUPPORT BY OTHERS

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 9-1/8" EDGE DISTANCE.

CONCRETE ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE.
SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø THREADED ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-62

DATE:
6/28/2023

REV:
4

DRAWN BY:
FMM

For wood, concrete and steel attachment see
Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard.
For bolted spring housing, neoprene pads and
spring cups see Weldment and Bolting Detail,
Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR DIRECT FIT (SUN CORE) SMALL CABINET UNITS

ZX 04-07; XX A7, ZX A7, ZY, ZQ, XY, XQ, ZL 04-06

PROVENT P/N	A	B	EST. WEIGHT
CBISCPRS18**	8"	18"	305 Lbs.
CBISCPRS21**	11"	21"	320 Lbs.
CBISCPRS24**	14"	24"	335 Lbs.

**Note: Spring configuration must be added
to part number at time of order

Weight of upper portion supported by
spring isolators= 188 Lbs.


Meets seismic requirements for the
following codes:
CBC 2022
IBC 2021

FEATURES


- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES


- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



(4) #10 TEK SCREWS



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-05

DATE:
7/28/2023

PART NUMBER:

-

REV:
4

DRAWN BY:
JG




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-05	Iso Curb	CBISCPRS
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06		

Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	70.375	in	(Length of upper curb)
wcurb =	40.1875	in	(Width of upper curb)
WGTupper =	188	lbs	(Weight of upper curb)
# Clips long side =	3		
# Clips short side =	2		

Unit Information

WGTunit =	916	lbs	(Weight of Unit)
Wtmax =	275	lbs	(Maximum corner weight)
Wtmin =	195	lbs	(Minimum corner weight)
Hunit =	40.56	in	(Height of unit above curb)
Hcm =	20.28	in	(Height to center of mass)
Lunit =	74.05	in	(Length of unit)
Wunit =	48.88	in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	(0.4*ap*Sds*Ip)*Wp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3289	(0.7*Fpmax)
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	3964	(unit + upper rail)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	803	lbs
Fh ASD long =	530	lbs
Fvert ASD =	673	lbs
		= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
		= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
		= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
		= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:		
Compression _{SEISMIC} =	2385	lbs
Tension _{SEISMIC} =	1551	lbs
Compression _{WIND} =	399	lbs
Tension _{WIND} =	508	lbs

---> Negative values indicate opposite load.

Longitudinal:		
Compression _{SEISMIC} =	1673	lbs
Tension _{SEISMIC} =	839	lbs
Compression _{WIND} =	146	lbs
Tension _{WIND} =	256	lbs

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:		
Comp _{MAX} =	2385	lbs
(on long edge)	Tens _{MAX} =	1551
		lbs
Longitudinal:		
Comp _{MAX} =	1673	lbs
(on short edge)	Tens _{MAX} =	839
		lbs

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r + t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	r _x = 2.08 in
I _y = 0.169 in ⁴	r _y = 0.521 in
A = 0.62 in ²	r _{min} = 0.521 in



Axial Compression

P_a = 1.645 k (Max Axial Comp) Ω_c = 1.80

P_n/Ω_c = 13.768 k

Fe = 91.64 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

λ_c = 0.74 $\Omega_c = \frac{F_n A}{F_e A}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y

F_n = 39.79 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

Ly = 36.69 in Lateral unbraced length

k_yL_y/r_y = 56 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50

t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08

N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12

Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048

P_n = 1.947 k R/t = 1.50 ≤ 12.0

P_n/Ω_w = 1.112 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Long side: P_{Utrans} = 0.795 k **O.K.** # clips = 3

Short side: P_{ULong} = 0.836 k **O.K.** # clips = 2

(See table C3.4.1-2, fastened to support, two flange, end loading)

Check Web Stiffener

N/A P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}

width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k

web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k

***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70 A_e = 0.380 in²

w/t_s = 118.675

1.28√(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2 P_n/Ω_c = 8.629 k **Not Req'd**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 991 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)

V_{crnmax} = 1192 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1208 lbs

Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs

of Bolts required for Tension = 0.4

of Bolts required for Shear = 1.1

of Bolts Used = 3.0

Check Combined Stress in Bolts & Inserts: 0.496 **O.K.**

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

L_{req'd} = 0.806 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness) $t_2/t_1 = 1.0$ $F_{u1} = 65$ ksi
 $t_2 = 0.0713$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)

For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2266$ # $P_{ns} = 2.27$ k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ $P_{ns} = 2.38$ k
 $P_{ns} = 2.7t_2dF_{u2}$ $P_{ns} = 2.38$ k
 $P_{ns}/\Omega = 755$ #
 $P_{ss}/\Omega = 540$ # <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249$ # <- Controls
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377$ #
 $P_{ns} = 2.7t_1dF_{u1}$ $P_{ns} = 2.38$ k
 $P_{ns} = 2.7t_2dF_{u2}$ $P_{ns} = 2.38$ k
 $P_{not} = 0.85t_c dF_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.645	3	0.55	540 #	4	2.00 in
Short side:	1.645	2	0.82	540 #	4	2.00 in

clip width (in) = 7.00
min spacing = 0.57 in
clip height = 2.5 in
edge distance = 0.5 in (min. 1.5d)
thinnest part = 0.0713 AISI BSR applies
Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $A_{nt} = 0.082$ in²

Curb Loads (copied from above)

Transverse:	Comp _{MAX} = 3271 lbs
(on long edge)	Tens _{MAX} = 2388 lbs
	Shear _{MAX} = 3964 lbs
Longitudinal:	Comp _{MAX} = 2180 lbs
(on short edge)	Tens _{MAX} = 1297 lbs
	Shear _{MAX} = 3964 lbs

Loads at each Isolator

Type: CQA

Transverse loading:	Comp _{MAX} = 1635.7 lbs
(on long edge)	Tens _{MAX} = 1194.1 lbs
# isolators: 2	Shear _{MAX} = 495.6 lbs
Longitudinal loading:	Comp _{MAX} = 1090.2 lbs
(on short edge)	Tens _{MAX} = 648.6 lbs
# isolators: 2	Shear _{MAX} = 495.6 lbs

Max compression force on isolator: 1.636 k ≤ 3.176 k O.K.
Max uplift on isolator: 1.194 k ≤ 3.176 k O.K.
Max shear on isolator: 0.496 k ≤ 1.163 k O.K.

Forces on top bolt:

Tension = 1.194 k $d_b = 0.375$ in
Shear = 0.496 k upper rail, $t = 0.0713$ in 7.0 in

Shear on curb rail:

$P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K.

$P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k Bolt tension O.K. $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k Bolt shear O.K.

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 10.81$ ksi $f_v = 4.49$ ksi O.K.

$P'_{nt} = A_b F'_{nt}$ $F'_{nt} = 34.48$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.692$ k Combined O.K.

Longitudinal weld loading:

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2} \right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading:

$t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



Client:	ProVent	PV2312	Base curb
Project:	CBISC-05	Iso Curb	CBISCPRS
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06		

Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	73.375	in	(Length of base curb)
wcurb =	43.125	in	(Width of base curb)
WGTbase =	147	lbs	(Weight of base curb)
# Springs long side =	2		# Springs short side = 2

Unit Information

WGUnit =	916	lbs	(Weight of Unit)
Wt'max =	322	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	242	lbs	(Wtmin+1/4*WGUpper)
Hunit =	40.56	in	(Height of unit above curb)
H'cm =	30.28	in	(Hcm+10"(upper+spring))
Lunit =	74.05	in	(Length of unit)
Wunit =	48.88	in	(Width of unit)
WGUnit+upper+base =	1251	lbs	(Total weight)

Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	3964	lbs
	(unit + upper rail)	
ap =	2.5	
Rp =	2	
FpmaxASD =	4492	lbs
	(unit + upper rail + base curb)	

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf
Fh ASD trans =	1318	lbs
Fh ASD long =	870	lbs
Fvert ASD =	673	lbs

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	3633	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14S _{DS}) * Wt'max * wcurb] / wcurb
Tension _{SEISMIC} =	2648	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14S _{DS}) * Wt'min * wcurb] / wcurb
Compression _{WIND} =	975	lbs	= [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb
Tension _{WIND} =	972	lbs	= [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	2485	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14S _{DS}) * Wt'max * Lcurb] / Lcurb
Tension _{SEISMIC} =	1500	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14S _{DS}) * Wt'min * Lcurb] / Lcurb
Compression _{WIND} =	409	lbs	= [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb
Tension _{WIND} =	406	lbs	= [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	3633	lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	2648	lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	2485	lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1500	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.






Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in	rx = 8.00 in
Iy = 0.218 in	ry = 0.329 in
A = 2.01 in ²	rmin = 0.329 in



Axial Compression

Pu = 1.982 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 8.960 k
Fe = 9.14 ksi
λc = 2.34
Fn = 8.01 ksi
Ly = 73.38 in
kyLy/r_y = 179

If λ_c ≤ 1.5; F_n = (0.658<sup>λ_c²) F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$</sup>

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 350.63 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.28 ≤ 2.0 C_h = 0.02
P_n = 2.105 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.203 k
Long side: P_{uTrans} = 1.816 k web stiffener REQ'D # clips = 2
Short side: P_{uLong} = 1.243 k web stiffener REQ'D # clips = 2

***h/t > 260; use web stiffeners

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
w/ts = 118.675
1.28V(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k Ae = 0.380 in²
P_n = 14.780 k
P_n/Ωc = 8.694 k O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1123 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
Vcrnmax = 1816 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.5
of Bolts required for Shear = 1.7
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.703 O.K.

Check 1/8" welded connection

--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in
Lreq'd = 1.228 in
 $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$
 $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} = 3271 lbs Tens _{MAX} = 2388 lbs Shear _{MAX} = 3964 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2180 lbs Tens _{MAX} = 1297 lbs Shear _{MAX} = 3964 lbs

Max compression force on isolator: 1.636 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.194 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.496 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.0713$ in
 Tension = 0.597 k / bolt
 Shear = 0.248 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 2.781$ k $d / t = 7.01$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** ***** (Table E3.4-1, AISI) *****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 6.08$ ksi $f_v = 1.26$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$ WIND: $0.6 D + W$

Transverse:	Uplift _{MAX} = 5583 lbs	Shear _{MAX} = 2246 lbs
Compression _{SEISMIC} =	6584 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Tension _{SEISMIC} =	5583 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Compression _{WIND} =	1728 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1651 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 3209 lbs	Shear _{MAX} = 2246 lbs
Compression _{SEISMIC} =	4210 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Tension _{SEISMIC} =	3209 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Compression _{WIND} =	694 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	617 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)



	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
Transverse:	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	7.35	COMBINED LOADING: 0.943 O.K.
# of Screws Req'd for Shear =	3.34	Req'd Min Spacing = 7.26 in o.c.
Total # of screws required =	10	

Use 10 - 1/4" φ x 4.5" Simpson SDS screws @ 7.3 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator

Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 1635.7 lbs Tens _{MAX} = 1194.1 lbs Shear _{MAX} = 495.6 lbs
# isolators: 2	
Longitudinal loading: (on short edge)	Comp _{MAX} = 1090.2 lbs Tens _{MAX} = 648.6 lbs Shear _{MAX} = 495.6 lbs
# isolators: 2	





Longitudinal:

of Screws Req'd for Uplift = 4.22
of Screws Req'd for Shear = 3.34
Total # of screws required = 6

COMBINED LOADING: 0.913 O.K.
Screw Spacing = 7.03 in o.c.

Use 6 - 1/4" ϕ x 4.5" Simpson SDS screws @ 7 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Tall_{metal} = 2086 lbs Vall_{metal} = 2192 lbs
of Bolts Req'd for Uplift = 2.68
of Bolts Req'd for Shear = 1.02
Total # of bolts required = 4

COMBINED LOADING: 0.840 O.K.
Bolt Spacing = 20.46 in o.c.

Use 4 - 1/2" ϕ A307 Bolts to steel angle below deck @ 20.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.54
of Bolts Req'd for Shear = 1.02
Total # of bolts required = 2

COMBINED LOADING: 0.555 O.K.
Bolt Spacing = 31.13 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 31.1 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_o E $\Omega_o = 2.5$

Concrete Attachment: 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'_c = 4000 psi
h = 6 in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
h_{ef} = 4 in (effective embedment)
d_a = 0.625 in (anchor diameter) d_o = 0.75 in (hole diameter)
n = 5 (number of dummy anchors to check capacity with spacing effect)
s = 10 in (initial spacing estimate)
tk_{cr} / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)
tk_{cr} / uncr = 1226 2327 psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$
c_{Na} = 9.0625 in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength
***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1053.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 30578 \text{ lbs (group)}$$

$$\phi N_{ag} = 14907 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 624 \text{ in}^2$$

$$N_b = 8601 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 144 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 37273 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 20966 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 2981 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 1745 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 6778 lbs Shear_{MAX} = 5615 lbs

$$\text{Compression}_{SEISMIC} = 7808 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 6778 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 5615 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 3.88 \text{ spacing} = 20.46 \text{ in o.c.}$$

$$T_{applied} = 1355.7 \text{ lbs}$$


$$\text{Min Bolts Req'd Shear} = 3.13 \text{ spacing} = 20.46 \text{ in o.c.}$$

$$V_{applied} = 701.9 \text{ lbs}$$

$$\text{Try using } 5 \text{ bolts spaced at } 15.34 \text{ in o.c.} \quad \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.17 \text{ O.K.}$$

Use 5 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 15.3 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift_{MAX} = 3909 lbs Shear_{MAX} = 5615 lbs





MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page 8 of 8

$$\begin{aligned} \text{Compression}_{\text{SEISMIC}} &= 4939 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Tension}_{\text{SEISMIC}} &= 3909 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Shear}_{\text{SEISMIC}} &= 5615 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\ \text{Min Bolts Req'd Uplift} &= 2.24 \text{ spacing} = 15.56 \text{ in o.c.} &\text{Applied} = 1303.1 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.13 \text{ spacing} = 10.38 \text{ in o.c.} &\text{Applied} = 701.9 \text{ lbs} \\ \text{Try using } 3 \text{ bolts spaced at } 15.56 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.14 \text{ O.K.} \end{aligned}$$

Use 3 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 15.6 in o.c. max. along short side of curb w/ 4in embed

CURB DESIGN SUMMARY:				CBISC-05	CBISCPRS	Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge							
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge							
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip							
WEB STIFFENER: NOT REQUIRED							
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip							
WEB STIFFENER: NOT REQUIRED							
VIBRATION ISOLATOR TYPE: CQA				Top stud diameter:	3/8	(2) - CQA Isolators long side	
Anchor bolt diameter: 1/2				Anchor hole diameter:	9/16	(2) - CQA Isolators short side	
BASE CURB THICKNESS: 0.0713 in 14 Gauge						---Bolt or Weld O.K.---	
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb							
CORNER CONNECTION: Use minimum 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts							
CURB ANCHORAGE		<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>	
		1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" ϕ A307 Bolts to steel angle below deck		0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed	
LONG DIRECTION		10 @ 7.26 in o.c.		4 @ 20.46 in o.c.		5 @ 15.34 in o.c.	
SHORT DIRECTION		6 @ 7.03 in o.c.		2 @ 31.13 in o.c.		3 @ 15.56 in o.c.	