



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-12 Series
CBISCSAV1518 SERIES**




Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 23, 2023
Project Number: PV2312

WELDMENT AND BOLTING DETAIL

* OPTIONAL
WELD I.L.O.
BOLTED STUD



(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

BASE CURB SUPPORT


Note: * - INDICATES WELD REQUIRED I.L.O.
BOLTED STUD FOR THE FOLLOWING CURBS:

- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA/CQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA/CQA
9/16" FOR JQB/JQBX
1 1/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED

FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61


DATE:
08/14/23

REV:
2

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.




NO. OF ANCHORAGE BOLTS REQUIRED

| CURB | LONG SIDE | SHORT SIDE |
|---------|-----------------|-----------------|
| LXS | 3 @ 19.25" O.C. | 2 @ 23" O.C. |
| LXL | 3 @ 19.25" O.C. | 2 @ 33" O.C. |
| SUN3672 | 4 @ 21" O.C. | 2 @ 27.25" O.C. |
| PRD3715 | 6 @ 14.28" O.C. | 3 @ 20.75" O.C. |
| PRS | 4 @ 20.46" O.C. | 2 @ 31.13" O.C. |
| PRL | 5 @ 17.44" O.C. | 2 @ 41.5" O.C. |
| SAV1518 | 6 @ 22.43" O.C. | 3 @ 35.56" O.C. |
| SAV2025 | 7 @ 21.02" O.C. | 3 @ 35.56" O.C. |
| SAV28 | 7 @ 23.75" O.C. | 3 @ 35.56" O.C. |

ASSUMES:

CONC SLAB
 $f_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 9-1/8" EDGE DISTANCE.

CONCRETE ATTACHMENT



Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

| ROOF ANCHORAGE DETAIL |
|-----------------------|
| CBISC Series |
| LXS |
| LXL |
| SUN3672 |
| PRD3715 |
| PRS |
| PRL |
| SAV1518 |
| SAV2025 |
| SAV28 |

NO. OF ANCHORAGE BOLTS REQUIRED


| CURB | LONG SIDE | SHORT SIDE |
|---------|------------------|-----------------|
| LXS | 4 @ 12.83" O.C. | 2 @ 23.0" O.C. |
| LXL | 4 @ 12.83" O.C. | 3 @ 16.50" O.C. |
| SUN3672 | 4 @ 21.0" O.C. | 2 @ 27.25" O.C. |
| PRD3715 | 9 @ 8.92" O.C. | 6 @ 8.30" O.C. |
| PRS | 5 @ 15.34" O.C. | 3 @ 15.56" O.C. |
| PRL | 7 @ 11.63" O.C. | 4 @ 13.83" O.C. |
| SAV1518 | 8 @ 16.02" O.C. | 6 @ 14.23" O.C. |
| SAV2025 | 9 @ 15.77" O.C. | 6 @ 14.23" O.C. |
| SAV28 | 10 @ 15.83" O.C. | 6 @ 14.23" O.C. |

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

| CURB | LONG SIDE | SHORT SIDE |
|---------|-----------------|-----------------|
| LXS | 8 @ 6.07" O.C. | 5 @ 6.75" O.C. |
| LXL | 7 @ 7.08" O.C. | 7 @ 6.17" O.C. |
| SUN3672 | 9 @ 8.38" O.C. | 5 @ 7.81" O.C. |
| PRD3715 | 15 @ 5.38" O.C. | 10 @ 5.06" O.C. |
| PRS | 10 @ 7.26" O.C. | 6 @ 7.03" O.C. |
| PRL | 12 @ 6.70" O.C. | 8 @ 6.50" O.C. |
| SAV1518 | 15 @ 8.29" O.C. | 10 @ 8.35" O.C. |
| SAV2025 | 18 @ 7.65" O.C. | 10 @ 8.35" O.C. |
| SAV28 | 20 @ 7.71" O.C. | 10 @ 8.35" O.C. |

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-62

DATE:
6/28/2023

REV:
4

DRAWN BY:
FMM

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

CALCULATED VIBRATION ISOLATION ROOF CURBS SUNCHOICE UNITS

AV 15-18, AD 15-18, AH 15, AL 15, HV 13

| PROVENT P/N | A | B | EST. WEIGHT |
|------------------|-----|-----|-------------|
| CBISCSAV151818** | 8" | 18" | 556 Lbs |
| CBISCSAV151821** | 11" | 21" | 606 Lbs |
| CBISCSAV151824** | 14" | 24" | 656 Lbs |

**Note: Spring configuration must be added to part number at time of order

Weight of upper portion supported by spring isolators= 295 Lbs.



Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

FEATURES


- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____

COMPANY: _____

JOB NAME: _____

EQUIPMENT: _____

NOTES: _____

FORM NO:

CBISC-12

DATE:

8/14/2023

PART NUMBER:

-

REV:

3

DRAWN BY:

FMM




| | | | |
|----------|-------------------------------------|----------|-----------------|
| Client: | ProVent | PV2312 | Upper curb rail |
| Project: | CBISC-12 | Iso Curb | CBISCSAV1518 |
| Unit: | AV 15-18; AD 15-18; AH/AL 15; HV 13 | | |

Upper Curb Information

| | | | |
|----------------------|---------|-----|-----------------------------|
| Hcurb upper = | 5.5 | in | (Height of upper curb rail) |
| Lcurb = | 121.125 | in | (Length of upper curb) |
| wcurb = | 80.125 | in | (Width of upper curb) |
| WGTupper = | 295 | lbs | (Weight of upper curb) |
| # Clips long side = | 3 | | |
| # Clips short side = | 2 | | |

Unit Information

| | | | |
|-----------|--------|-----|-----------------------------|
| WGTunit = | 2385 | lbs | (Weight of Unit) |
| Wtmax = | 716 | lbs | (Maximum corner weight) |
| Wtmin = | 507 | lbs | (Minimum corner weight) |
| Hunit = | 49.25 | in | (Height of unit above curb) |
| Hcm = | 24.625 | in | (Height to center of mass) |
| Lunit = | 129.75 | in | (Length of unit) |
| Wunit = | 88.75 | in | (Width of unit) |



Seismic Loading - 2021 IBC/2022 CBC

| | | |
|------------|---------------------|---|
| Ss = | 2.85 | (Worst case for majority of California) |
| Fa = | 1.20 | (Default Site Class D - Table 11.4-1 ASCE 7-16) |
| Ip = | 1.50 | (Importance Factor Category III Building) |
| Sms = | 3.420 | (Fa*Ss) |
| Sds = | 2.280 | (2/3*Sms) |
| Fpmax = | 5.130 | (0.4*ap*Sds*Ip)*Wp <= 1.6*Sds*Ip*Wp |
| FpmaxASD = | 8565 | lbs |
| | (unit only) | |
| ap = | 2.5 | |
| Rp = | 2 | |
| FpmaxASD = | 9624 | lbs |
| | (unit + upper rail) | |

Wind Loading - 2021 IBC/2022 CBC

| | | |
|----------------|---|--|
| Kz = | 1.13 | (For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16) |
| Kzt = | 1.00 | (Max. assumed topographic factor) |
| Kd = | 0.85 | (Directionality factor Table 26.6-1 ASCE 7-16) |
| Ke = | 1.00 | (Ground Elevation Factor Table 26.9-1 ASCE 7-16) |
| V = | 110 | (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16) |
| GCr (horiz) = | 1.9 | (Refer Sect 29.4.1 ASCE 7-16) |
| GCr (vert) = | 1.5 | (Refer Sect 29.4.1 ASCE 7-16) |
| qz = | 29.8 | psf |
| Fh ASD trans = | 1673 | lbs |
| Fh ASD long = | 1145 | lbs |
| Fvert ASD = | 2141 | lbs |
| | = 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16) | |
| | = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2) | |
| | = 0.6*qz*GCr*Wunit*(Hunit+Hcurb) | |
| | = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3) | |

Upper Curb Loading

| | | |
|----------------------------------|------|-----|
| Transverse: | | |
| Compression _{SEISMIC} = | 4520 | lbs |
| Tension _{SEISMIC} = | 2348 | lbs |
| Compression _{WIND} = | 302 | lbs |
| Tension _{WIND} = | 977 | lbs |

---> Negative values indicate opposite load.

| | | |
|----------------------------------|------|-----|
| Longitudinal: | | |
| Compression _{SEISMIC} = | 3629 | lbs |
| Tension _{SEISMIC} = | 1457 | lbs |
| Compression _{WIND} = | 21 | lbs |
| Tension _{WIND} = | 695 | lbs |

---> Negative values indicate opposite load.

Governing Reactions:

| | | |
|-----------------------|-----------------------|------|
| Transverse: | | |
| Comp _{MAX} = | 4520 | lbs |
| (on long edge) | Tens _{MAX} = | 2348 |
| Longitudinal: | | |
| Comp _{MAX} = | 3629 | lbs |
| (on short edge) | Tens _{MAX} = | 1457 |

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

| | |
|---|--|
| A' = 5.500 in | a = 5.144 in = A' - (2r + t) |
| B' = 1.500 in | a' = 5.429 in = A' - t |
| C' = 0.500 in (0 if no lips) | b = 1.233 in = B' - [r + t/2 + α(r + t/2)] |
| α = 0.500 (0 - no Lip; 1 w/ lip) | b' = 1.447 in = B' - (t/2 + αt/2) |
| R = 0.1069 (Inside bend radius) | c = 0.161 in = α[C' - (r + t/2)] |
| t = 0.0713 in | c' = 0.232 in = α(C' - t/2) |
| r' = 0.143 in = R + t/2 | u = 0.224 in = πr/2 |
| x = 0.292 in (Distance between centroid and web centerline) | |
| I _x = 2.515 in ⁴ | rx = 2.04 in |
| I _y = 0.133 in ⁴ | ry = 0.470 in |
| A = 0.60 in ² | rmin = 0.470 in |



Axial Compression

P_a = 4.282 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 4.957 k
F_e = 16.90 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.72 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 14.82 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 77.13 in Lateral unbraced length
k_yL_y/r_y = 131 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 260 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Long side: P_{Utrans} = 1.507 k **web stiffener REQ'D** # clips = 3
Short side: P_{ULong} = 1.814 k **web stiffener REQ'D** # clips = 2

Check Web Stiffener

16Ga x 1 3/16in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70 A_e = 0.380 in²
w/t_s = 118.675
1.28√(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2406 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 2260 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 1.0
of Bolts required for Shear = 2.1
of Bolts Used = 4.0
Check Combined Stress in Bolts & Inserts: 0.758 **O.K.**

Check 1/8" welded connection


<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 1.528 in



| | | | |
|---|---|-------------------------------|--|
| Connection Unit to Curb Clip | | #10 SMS screw | $\Omega = 3.0$ |
| $t_1 = 0.0713$ in (clip thickness) | $t_2/t_1 = 1.0$ | $F_{u1} = 65$ ksi | |
| $t_2 = 0.0713$ in (unit base rail thickness) | | $F_{u2} = 65$ ksi | |
| $d = 0.190$ in (screw diameter) | $d_w = 0.375$ in (nom. washer diameter) | | |
| For $t_2/t_1 \leq 1.0$: | | $P_{ns} = 2266$ # | For $t_2/t_1 \geq 2.5$: |
| Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ | | 2.27 k | $P_{ns} = 2377$ # |
| Tension: $P_{ns} = 2.7t_1dF_{u1}$ | | 2.38 k | $P_{ns} = 2.7t_1dF_{u1}$ |
| $P_{ns} = 2.7t_2dF_{u2}$ | | 2.38 k | $P_{ns} = 2.7t_2dF_{u2}$ |
| $P_{ns}/\Omega = 755$ # | | | |
| $P_{ss}/\Omega = 540$ # <- Controls | | | $P_{not} = 0.85t_c d F_{u2}$ |
| $P_{not} = 0.748$ k (screw pull-out strength) | | | $t_c = \min(t_1, t_2)$ |
| $P_{nov} = 2.607$ k (screw pull-over strength) | | | $P_{nov} = 1.5t_1 d_w F_{u1}$ |
| $P_{ts}/\Omega = 249$ # <- Controls | | | |
| $P_{ts}/\Omega = 820$ # | | (full tensile screw capacity) | |
| | Shear (k) | # clips | V_{clip} (k) |
| Long side: | 4.282 | 3 | 1.43 |
| Short side: | 4.282 | 2 | 2.14 |
| | | | V_{allow} (lb) |
| | | | 540 # |
| | | | 540 # |
| | | | # screws |
| | | | 4 |
| | | | 4 |
| | | | spacing |
| | | | 2.00 in |
| | | | 2.00 in |
| | clip width (in) = 7.00 | | clip height = 2.5 in |
| | min spacing = 0.57 in | | edge distance = 0.5 in (min. 1.5d) |
| Check Block shear rupture: | O.K. | | thinnest part = 0.0713 AISI BSR applies |
| $F_y = 50$ ksi | | | $\Omega = 2.22$ bolt/screw connection |
| $A_{gv} = 0.463$ in ² | | | $A_{nv} = 0.416$ in ² |
| $R_n/\Omega = 8.674$ k | | | $A_{nt} = 0.082$ in ² |
| | | | $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ |
| | | | (AISI Sect. E5.3) |



Curb Loads (copied from above)

| | |
|-----------------|---------------------------------|
| Transverse: | Comp _{MAX} = 5386 lbs |
| (on long edge) | Tens _{MAX} = 3242 lbs |
| | Shear _{MAX} = 9624 lbs |
| Longitudinal: | Comp _{MAX} = 4161 lbs |
| (on short edge) | Tens _{MAX} = 2017 lbs |
| | Shear _{MAX} = 9624 lbs |

Loads at each Isolator

Type: CQA

| | |
|-----------------------|----------------------------------|
| Transverse loading: | Comp _{MAX} = 1795.4 lbs |
| (on long edge) | Tens _{MAX} = 1080.7 lbs |
| # isolators: 3 | Shear _{MAX} = 962.4 lbs |
| Longitudinal loading: | Comp _{MAX} = 2080.6 lbs |
| (on short edge) | Tens _{MAX} = 1008.6 lbs |
| # isolators: 2 | Shear _{MAX} = 962.4 lbs |

Max compression force on isolator: 2.081 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.081 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.962 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.081 k $d_b = 0.375$ in
 Shear = 0.962 k upper rail, $t = 0.0713$ in

Shear on curb rail: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 9.78$ ksi $f_v = 8.71$ ksi **O.K.**
 $F'_{nt} = 17.36$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 0.852$ k **No Good - Use Welds**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



| | | | |
|----------|-------------------------------------|----------|--------------|
| Client: | ProVent | PV2312 | Base curb |
| Project: | CBISC-12 | Iso Curb | CBISCSAV1518 |
| Unit: | AV 15-18; AD 15-18; AH/AL 15; HV 13 | | |

Base Curb Information

| | | | |
|-----------------------|---------|-----|--------------------------|
| Hbase curb = | 25 | in | (Height of base curb) |
| Lcurb = | 124.125 | in | (Length of base curb) |
| wcurb = | 83.125 | in | (Width of base curb) |
| WGTbase = | 361 | lbs | (Weight of base curb) |
| # Springs long side = | 3 | | # Springs short side = 2 |

Unit Information

| | | | |
|---------------------|--------|-----|-----------------------------|
| WGUnit = | 2385 | lbs | (Weight of Unit) |
| Wt'max = | 789 | lbs | (Wtmax+1/4*WGUpper) |
| Wt'min = | 581 | lbs | (Wtmin+1/4*WGUpper) |
| Hunit = | 49.25 | in | (Height of unit above curb) |
| H'cm = | 34.625 | in | (Hcm+10"(upper+spring)) |
| Lunit = | 129.75 | in | (Length of unit) |
| Wunit = | 88.75 | in | (Width of unit) |
| WGUnit+upper+base = | 3041 | lbs | (Total weight) |

Seismic Loading - 2021 IBC/2022 CBC

| | | |
|------------|---------------------------------|---|
| Ss = | 2.85 | (Worst case for majority of California) |
| Fa = | 1.20 | (Default Site Class D - Table 11.4-1 ASCE 7-16) |
| Ip = | 1.50 | (Importance Factor Category III Building) |
| Sms = | 3.420 | (Fa*Ss) |
| Sds = | 2.280 | (2/3*Sms) |
| Fpmax = | 5.130 | Wp |
| FpmaxASD = | 9624 | lbs |
| | (unit + upper rail) | |
| ap = | 2.5 | |
| Rp = | 2 | |
| FpmaxASD = | 10920 | lbs |
| | (unit + upper rail + base curb) | |

Wind Loading - 2021 IBC/2022 CBC

| | | |
|----------------|------|--|
| Kz = | 1.13 | (For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16) |
| Kzt = | 1.00 | (Max. assumed topographic factor) |
| Kd = | 0.85 | (Directionality factor Table 26.6-1 ASCE 7-16) |
| Ke = | 1.00 | (Ground Elevation Factor Table 26.9-1 ASCE 7-16) |
| V = | 110 | (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16) |
| GCr(horiz) = | 1.9 | (Refer Sect 29.4.1 ASCE 7-16) |
| GCr(vert) = | 1.5 | (Refer Sect 29.4.1 ASCE 7-16) |
| qz | 29.8 | psf |
| Fh ASD trans = | 2575 | lbs |
| Fh ASD long = | 1761 | lbs |
| Fvert ASD = | 2141 | lbs |

Base Curb Loading

Transverse:

| | | | |
|----------------------------------|------|-----|--|
| Compression _{SEISMIC} = | 6091 | lbs | = [FpmaxASD * H'cm + 2 * (1 + 0.14 * S _{DS}) * Wt'max * wcurb] / wcurb |
| Tension _{SEISMIC} = | 3683 | lbs | = [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S _{DS}) * Wt'min * wcurb] / wcurb |
| Compression _{WIND} = | 949 | lbs | = [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb |
| Tension _{WIND} = | 1446 | lbs | = [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb |

---> Negative values indicate opposite load.

Longitudinal:


| | | | |
|----------------------------------|------|-----|--|
| Compression _{SEISMIC} = | 4767 | lbs | = [FpmaxASD * H'cm + 2 * (1 + 0.14 * S _{DS}) * Wt'max * Lcurb] / Lcurb |
| Tension _{SEISMIC} = | 2359 | lbs | = [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S _{DS}) * Wt'min * Lcurb] / Lcurb |
| Compression _{WIND} = | 368 | lbs | = [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb |
| Tension _{WIND} = | 865 | lbs | = [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb |

---> Negative values indicate opposite load.

Governing Reactions:

| | | | | |
|-----------------|-----------------------|------|-----|--------------------------------|
| Transverse: | Comp _{MAX} = | 6091 | lbs | ---> Along long edge of curb. |
| (on long edge) | Tens _{MAX} = | 3683 | lbs | ---> Along long edge of curb. |
| Longitudinal: | Comp _{MAX} = | 4767 | lbs | ---> Along short edge of curb. |
| (on short edge) | Tens _{MAX} = | 2359 | lbs | ---> Along short edge of curb. |

---> Negative values indicate opposite load.






Curb Design

F_y = 50 ksi
E = 29500 ksi
F_u = 65 ksi
t = 0.1017 12 Gauge

Calculate Section Properties of Curb

| | |
|---|--|
| A' = 25.000 in | a = 24.492 in = A' - (2r + t) |
| B' = 1.500 in | a' = 24.898 in = A' - t |
| C' = 1.000 in (0 if no lips) | b = 0.992 in = B' - [r + t/2 + α(r + t/2)] |
| α = 1.000 (0 - no Lip; 1 w/ lip) | b' = 1.398 in = B' - (t/2 + αt/2) |
| R = 0.1525 (Inside bend radius) | c = 0.746 in = α[C' - (r + t/2)] |
| t = 0.1017 in | c' = 0.949 in = α(C' - t/2) |
| r' = 0.203 in = R + t/2 | u = 0.319 in = πr/2 |
| x = 0.149 in (Distance between centroid and web centerline) | |
| I _x = 197.156 in | r _x = 8.14 in |
| I _y = 0.460 in | r _y = 0.393 in |
| A = 2.97 in ² | r _{min} = 0.393 in |



Axial Compression

P_u = 4.812 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 6.622 k
F_e = 4.57 ksi
λ_c = 3.31
F_n = 4.01 ksi
L_y = 124.13 in
k_yL_y/r_y = 252

If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length (assume k=0.8)

Ω_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$

Compression Check = **O.K.**

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.1017 in h/t = 245.82 ≤ 260 C_R = 0.14
N = 7.00 N/t = 68.83 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.28 ≤ 2.0 C_h = 0.02
P_n = 4.106 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 2.346 k
Long side: P_{uTrans} = 2.030 k **O.K.** # clips = 3
Short side: P_{uLong} = 2.383 k **web stiffener REQ'D** # clips = 2

(See table C3.4.1-2, fastened to support, one flange, end loading)

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70
w/ts = 118.675
1.28V(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 4.106 k Ae = 0.380 in²
P_n = 16.181 k
P_n/Ω_c = 9.518 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2730 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 3046 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 1.1
of Bolts required for Shear = 2.8
of Bolts Used = 4.0
Check Combined Stress in Bolts & Inserts: 0.970 **O.K.**

Check 1/8" welded connection

USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 2.543 in
L_{req'd} = 1.444 in
P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$



Curb Loads (copied from upper rail calcs)

| | |
|---|---|
| Transverse: (on long edge) | Comp _{MAX} = 5386 lbs Tens _{MAX} = 3242 lbs Shear _{MAX} = 9624 lbs |
| Longitudinal: (on short edge) | Comp _{MAX} = 4161 lbs Tens _{MAX} = 2017 lbs Shear _{MAX} = 9624 lbs |

Max compression force on isolator: 2.081 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.081 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.962 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.540 k / bolt
 Shear = 0.481 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 3.966$ k $d / t = 4.92$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** ***** (Table E3.4-1, AISI) *****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 5.50$ ksi $f_v = 2.45$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> $F'_{nt} = F_{nt}$**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$

WIND: $0.6 D + W$



| | | |
|----------------------------------|----------------------------------|--|
| Transverse: | Uplift _{MAX} = 7406 lbs | Shear _{MAX} = 5460 lbs |
| Compression _{SEISMIC} = | 9839 lbs | $= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$ |
| Tension _{SEISMIC} = | 7406 lbs | $= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$ |
| Compression _{WIND} = | 1689 lbs | $= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$ |
| Tension _{WIND} = | 2005 lbs | $= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$ |
| Longitudinal: | Uplift _{MAX} = 4819 lbs | Shear _{MAX} = 5460 lbs |
| Compression _{SEISMIC} = | 7252 lbs | $= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$ |
| Tension _{SEISMIC} = | 4819 lbs | $= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$ |
| Compression _{WIND} = | 688 lbs | $= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$ |
| Tension _{WIND} = | 1004 lbs | $= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$ |

Wood Attachment: 1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

| | | |
|--------------------------------|---------------------------------|----------------------------------|
| | Tall _{metal} = 997 lbs | Vall _{metal} = 1097 lbs |
| Transverse: | Tall _{wood} = 760 lbs | Vall _{wood} = 672 lbs |
| # of Screws Req'd for Uplift = | 9.74 | COMBINED LOADING: 0.975 O.K. |
| # of Screws Req'd for Shear = | 8.13 | Req'd Min Spacing = 8.29 in o.c. |
| Total # of screws required = | 15 | |

Use 15 - 1/4" ϕ x 4.5" Simpson SDS screws @ 8.3 in o.c. along long side of curb w/ 2.75" threaded embed

| | |
|---|--|
| Loads at each Isolator | Type: CQA |
| Transverse loading: (on long edge) # isolators: 3 | Comp _{MAX} = 1795.4 lbs Tens _{MAX} = 1080.7 lbs Shear _{MAX} = 962.4 lbs |
| Longitudinal loading: (on short edge) # isolators: 2 | Comp _{MAX} = 2080.6 lbs Tens _{MAX} = 1008.6 lbs Shear _{MAX} = 962.4 lbs |





Longitudinal:

of Screws Req'd for Uplift = 6.34
of Screws Req'd for Shear = 8.13
Total # of screws required = 10

COMBINED LOADING: 0.959 O.K.
Screw Spacing = 8.35 in o.c.

Use 10 - 1/4" ϕ x 4.5" Simpson SDS screws @ 8.3 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Tall_{metal} = 2086 lbs Vall_{metal} = 2192 lbs
of Bolts Req'd for Uplift = 3.55 COMBINED LOADING: 0.868 O.K.
of Bolts Req'd for Shear = 2.49 Bolt Spacing = 22.43 in o.c.
Total # of bolts required = 6

Use 6 - 1/2" ϕ A307 Bolts to steel angle below deck @ 22.4 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 2.31 COMBINED LOADING: 0.662 O.K.
of Bolts Req'd for Shear = 2.49 Bolt Spacing = 35.56 in o.c.
Total # of bolts required = 3

Use 3 - 1/2" ϕ A307 Bolts to steel angle below deck @ 35.6 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7 Ω_o E $\Omega_o = 2.5$

Concrete Attachment: 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'_c = 4000 psi
h = 6 in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
 h_{ef} = 4 in (effective embedment)
da = 0.625 in (anchor diameter) do = 0.75 in (hole diameter)
n = 5 (number of dummy anchors to check capacity with spacing effect)
s = 14 in (initial spacing estimate)
tk_{cr} / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)
tk_{cr} / uncr = 1226 2327 psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$
 $c_{Na} = 9.0625$ in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength
***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1343.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 38995 \text{ lbs (group)}$$

$$\phi N_{ag} = 19010 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 816 \text{ in}^2$$

$$N_b = 8601 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 144 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 48741 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 27417 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 3802 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 2225 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 9579 lbs Shear_{MAX} = 13650 lbs

$$\text{Compression}_{SEISMIC} = 12104 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 9579 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 13650 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 4.30 \text{ spacing} = 28.03 \text{ in o.c.}$$

$$\text{T applied} = 1197.3 \text{ lbs}$$


$$\text{Min Bolts Req'd Shear} = 7.60 \text{ spacing} = 16.02 \text{ in o.c.}$$

$$\text{V applied} = 975.0 \text{ lbs}$$

$$\text{Try using } 8 \text{ bolts spaced at } 16.02 \text{ in o.c.} \quad \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.08 \text{ O.K.}$$

Use 8 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 16 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift_{MAX} = 6268 lbs Shear_{MAX} = 13650 lbs





MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page 8 of 8

$$\begin{aligned} \text{Compression}_{\text{SEISMIC}} &= 8794 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Tension}_{\text{SEISMIC}} &= 6268 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\ \text{Shear}_{\text{SEISMIC}} &= 13650 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\ \text{Min Bolts Req'd Uplift} &= 2.82 \text{ spacing} = 35.56 \text{ in o.c.} &\text{Applied} = 1044.7 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 7.60 \text{ spacing} = 10.16 \text{ in o.c.} &\text{Applied} = 975.0 \text{ lbs} \\ \text{Try using } 6 \text{ bolts spaced at } 14.23 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.01 \text{ O.K.} \end{aligned}$$

Use 6 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 14.2 in o.c. max. along short side of curb w/ 4in embed

| | | | | | | |
|--|--|-----------------------|--|----------------------------|---|--------------------------------|
| CURB DESIGN SUMMARY: | | CBISC-12 | CBISCSAV1518 | Unit: | AV 15-18; AD 15-18; AH/AL 15; HV 13 | |
| UPPER CURB RAIL THICKNESS: | | 0.1017 in | 12 Gauge | | | |
| UNIT CLIP THICKNESS: | | 0.0713 in | 14 Gauge | | | |
| # OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip | | | | | | |
| WEB STIFFENER: 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip | | | | | | |
| # OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip | | | | | | |
| WEB STIFFENER: 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip | | | | | | |
| VIBRATION ISOLATOR TYPE: | | CQA | Top stud diameter: | 3/8 | (3) - CQA Isolators long side | |
| | | Anchor bolt diameter: | 1/2 | Anchor hole diameter: | 9/16 | (2) - CQA Isolators short side |
| BASE CURB THICKNESS: | | 0.1017 in | 12 Gauge | ***Must weld top of CQA*** | | |
| WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb | | | | | | |
| CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts | | | | | | |
| CURB ANCHORAGE | <u>WOOD</u> | | <u>STEEL</u> | | <u>CONCRETE</u> | |
| | 1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin = | | 1/2" ϕ A307 Bolts to steel angle below deck | | 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed | |
| | <u>LONG DIRECTION</u> | | 15 @ 8.29 in o.c. | | 6 @ 22.43 in o.c. | 8 @ 16.02 in o.c. |
| | <u>SHORT DIRECTION</u> | | 10 @ 8.35 in o.c. | | 3 @ 35.56 in o.c. | 6 @ 14.23 in o.c. |