



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBISC-14 Series**  
**CBISCSAV28\*\* SERIES**




**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: August 23, 2023**  
**Project Number: PV2312**

# WELDMENT AND BOLTING DETAIL

\* OPTIONAL  
WELD I.L.O.  
BOLTED STUD



(3) 5/16" BOLTS  
GRADE 5 EA SIDE  
OF THE STIFFENER  
  
(2) EA SIDE FOR  
UPPER RAIL SUPPORT

## BASE CURB SUPPORT


Note: \* - INDICATES WELD REQUIRED I.L.O.  
BOLTED STUD FOR THE FOLLOWING CURBS:

- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM  
BUMPER FOR:  
ISCALSLU180  
ISCALSLM1830

FOR JQA/CQA:  
5/16" Ø HOLE USE 1/2" Ø A307 BOLT  
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:  
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT  
WITH FLAT WASHER AND NUT



## FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,  
W/ FLAT WASHER REQUIRED  
UNDER NUT  
7/16" FOR JQA/CQA  
9/16" FOR JQB/JQBX  
1 1/16" FOR JQE/JQF

NEOPRENE CUP  
UNDER SPRING

1/4" THICK NEOPRENE PAD  
REQUIRED



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CB-61


DATE:  
08/14/23

REV:  
2

DRAWN BY:  
FMM

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

### ASSUMES:

CONC SLAB  
 $f_c = 4000$ PSI MINIMUM  
6" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 9-1/8" EDGE DISTANCE.

### CONCRETE ATTACHMENT



Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SAV1518
SAV2025
SAV28

NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-62

DATE:  
6/28/2023

REV:  
4

DRAWN BY:  
FMM

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

## CALCULATED VIBRATION ISOLATION ROOF CURBS SUNCHOICE UNITS

AV 28, AD 28, AE 18-23, AW 18-23, AH 25, AL 25, HV 25




PROVENT P/N	A	B	EST. WEIGHT
CBISCSAV2818**	8"	18"	653 Lbs
CBISCSAV2821**	11"	21"	698 Lbs
CBISCSAV2824**	14"	24"	748 Lbs
**Note: Spring configuration must be added to part number at time of order			
Weight of upper portion supported by spring isolators= 365 Lbs.			
Meets seismic requirements for the following codes: CBC 2022 IBC 2021			

### FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBISC-14

DATE:  
8/16/2023

PART NUMBER:  
CBISCSAV28 SERIES

REV:  
2

DRAWN BY:  
FMM




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-14	Iso Curb	CBISCSAV28
Unit:	AV/AD 28; AE/AW 18-23; AH/AL 25; HV 25		

### Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	151.5	in	(Length of upper curb)
wcurb =	80.125	in	(Width of upper curb)
WGTupper =	365	lbs	(Weight of upper curb)
# Clips long side =	3		# Clips short side = 3

### Unit Information

WGTunit =	3010	lbs	(Weight of Unit)
Wtmax =	903	lbs	(Maximum corner weight)
Wtmin =	640	lbs	(Minimum corner weight)
Hunit =	57.25	in	(Height of unit above curb)
Hcm =	28.625	in	(Height to center of mass)
Lunit =	160.0625	in	(Length of unit)
Wunit =	88.75	in	(Width of unit)



### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	(0.4*ap*Sds*Ip)*Wp <= 1.6*Sds*Ip*Wp
FpmaxASD =	10809	(0.7*Fpmax)
	(unit only)	FpmaxASD = 12120 lbs
		(unit + upper rail)

### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	2366	lbs
Fh ASD long =	1312	lbs
Fvert ASD =	2642	lbs
		= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
		= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
		= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
		= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

### Upper Curb Loading

<b>Transverse:</b>			
Compression <sub>SEISMIC</sub> =	6244	lbs	= [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	3502	lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*wcurb]/wcurb
Compression <sub>WIND</sub> =	608	lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	1398	lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

<b>Longitudinal:</b>			
Compression <sub>SEISMIC</sub> =	4425	lbs	= [FpmaxASD*Hcm+2*(1+0.14*S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	1683	lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	11	lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	801	lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	6244	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	3502	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	4425	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	1683	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




## Curb Design

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

## Calculate Section Properties of Curb

A' = <span style="border: 1px solid black; padding: 2px;">5.500</span> in	a = 5.144 in = A' - (2r + t)
B' = <span style="border: 1px solid black; padding: 2px;">1.500</span> in	a' = 5.429 in = A' - t
C' = <span style="border: 1px solid black; padding: 2px;">0.500</span> in (0 if no lips)	b = 1.233 in = B' - [r + t/2 + α(r + t/2)]
α = <span style="border: 1px solid black; padding: 2px;">0.500</span> (0 - no Lip; 1 w/ lip)	b' = 1.447 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.161 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.232 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.282 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 2.641 in <sup>4</sup>	r <sub>x</sub> = 2.06 in
I <sub>y</sub> = 0.157 in <sup>4</sup>	r <sub>y</sub> = 0.502 in
A = 0.623 in <sup>2</sup>	r <sub>min</sub> = 0.502 in



## Axial Compression

P <sub>a</sub> = 5.404 k	(Max Axial Comp)	Ω <sub>c</sub> = 1.80
P <sub>n</sub> /Ω <sub>c</sub> = 5.838 k		
F <sub>e</sub> = 19.23 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
λ <sub>c</sub> = 1.61	If λ <sub>c</sub> ≤ 1.5; F <sub>n</sub> = (0.658λ <sub>c</sub> <sup>2</sup> ) F <sub>y</sub>	$F_e = \frac{\pi^2 E}{(kl/r)^2}$
F <sub>n</sub> = 16.87 ksi	If λ <sub>c</sub> > 1.5; F <sub>n</sub> = $\frac{0.877}{\lambda_c^2} F_y$	
L <sub>y</sub> = 77.13 in	Lateral unbraced length	
k <sub>y</sub> L <sub>y</sub> /r <sub>y</sub> = 123	(assume k=0.8)	

**Compression Check = O.K.**

## Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 260	C <sub>R</sub> = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C <sub>N</sub> = 0.12	
Ω <sub>w</sub> = 1.75	N/h = 1.273 ≤ 2.0	C <sub>h</sub> = 0.048	
P <sub>n</sub> = 1.947 k	R/t = 1.50 ≤ 12.0		
P <sub>n</sub> /Ω <sub>w</sub> = 1.112 k		$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Long side: P <sub>Utrans</sub> = 2.081 k	<b>web stiffener REQ'D</b>	# clips = 3	
Short side: P <sub>Ulong</sub> = 1.475 k	<b>web stiffener REQ'D</b>	# clips = 3	

## Check Web Stiffener

16Ga x 1 3/16in x 7in (C-channel)	P <sub>n</sub> = 0.7(P <sub>wc</sub> + A <sub>e</sub> F <sub>y</sub> ) ≥ P <sub>wc</sub>
width of stiffener = 7.000 in	ts = 0.0566 <span style="border: 1px solid black; padding: 2px;">16 Gauge</span>
web of stiff. w = 6.717 in	R <sub>s</sub> = 0.0849 in
***Check w/ts ≤ 1.28√E/F <sub>y</sub>	Ω <sub>c</sub> = 1.70
w/ts = 118.675	
1.28√(E/F <sub>y</sub> ) = 31.091	--> w/ts over limit Use C3.7.2
P <sub>n</sub> /Ω <sub>c</sub> = 8.629 k	<b>O.K.</b>

## Corner Connections

### 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T <sub>crnmax</sub> = 3030 lbs	Max(F <sub>pmaxASD</sub> /4 -OR- F <sub>hASDtrans</sub> /4 corner connections)
V <sub>crnmax</sub> = 3122 lbs	Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = <span style="border: 1px solid black; padding: 2px;">2480</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1208</span> lbs
Threaded Insert: Tall = <span style="border: 1px solid black; padding: 2px;">2860</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1096</span> lbs
# of Bolts required for Tension = 1.2	
# of Bolts required for Shear = 2.8	
# of Bolts Used = <span style="border: 1px solid black; padding: 2px;">5.0</span>	
Check Combined Stress in Bolts & Inserts: 0.814	<b>O.K.</b>

## Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in	$\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tL F_u \geq V_{req}$	$L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$
L <sub>req'd</sub> = 2.111 in		



**Connection Unit to Curb Clip** #10 SMS screw  $\Omega = 3.0$

$t_1 = 0.0713$  in (clip thickness)  $t_2/t_1 = 1.0$   $F_{u1} = 65$  ksi  
 $t_2 = 0.0713$  in (unit base rail thickness)  $F_{u2} = 65$  ksi  
 $d = 0.190$  in (screw diameter)  $d_w = 0.375$  in (nom. washer diameter)

For  $t_2/t_1 \leq 1.0$ :  $P_{ns} = 2266$  # For  $t_2/t_1 \geq 2.5$ :  $P_{ns} = 2377$  #


**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$  2.27 k  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  
**Tension:**  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  $P_{ns} = 2.7t_2dF_{u2}$  2.38 k  
 $P_{ns}/\Omega = 755$  #  
 $P_{ss}/\Omega = 540$  # <- Controls  
 $P_{not} = 0.748$  k (screw pull-out strength)  $P_{not} = 0.85t_c d F_{u2}$   
 $P_{nov} = 2.607$  k (screw pull-over strength)  $t_c = \min(t_1, t_2)$   
 $P_{ts}/\Omega = 249$  # <- Controls  $P_{nov} = 1.5t_1 d_w F_{u1}$   
 $P_{ts}/\Omega = 820$  # (full tensile screw capacity)

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	5.404	3	1.80	540 #	4	2.00 in
Short side:	5.404	3	1.80	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in  
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)  
thinnest part = 0.0713 AISI BSR applies

**Check Block shear rupture:** O.K.  
 $F_y = 50$  ksi  $\Omega = 2.22$  bolt/screw connection  
 $A_{gv} = 0.463$  in<sup>2</sup>  $A_{nv} = 0.416$  in<sup>2</sup>  $A_{nt} = 0.082$  in<sup>2</sup>  
 $R_n/\Omega = 8.674$  k  $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$  (AISI Sect. E5.3)

**BSR O.K.**



**Curb Loads** (copied from above)

<b>Transverse:</b>	Comp <sub>MAX</sub> = 7388 lbs
(on long edge)	Tens <sub>MAX</sub> = 4688 lbs
	Shear <sub>MAX</sub> = 12120 lbs
<b>Longitudinal:</b>	Comp <sub>MAX</sub> = 4956 lbs
(on short edge)	Tens <sub>MAX</sub> = 2256 lbs
	Shear <sub>MAX</sub> = 12120 lbs

**Loads at each Isolator**

Type: CQA

<b>Transverse loading:</b>	Comp <sub>MAX</sub> = 2462.6 lbs
(on long edge)	Tens <sub>MAX</sub> = 1562.6 lbs
# isolators: 3	Shear <sub>MAX</sub> = 1010.0 lbs
<b>Longitudinal loading:</b>	Comp <sub>MAX</sub> = 1652.0 lbs
(on short edge)	Tens <sub>MAX</sub> = 752.0 lbs
# isolators: 3	Shear <sub>MAX</sub> = 1010.0 lbs

Max compression force on isolator: 2.463 k  $\leq 3.176$  k O.K.  
Max uplift on isolator: 1.563 k  $\leq 3.176$  k O.K.  
Max shear on isolator: 1.010 k  $\leq 1.163$  k O.K.

**Forces on top bolt:**

Tension = 1.563 k  $d_b = 0.375$  in  
Shear = 1.010 k upper rail,  $t = 0.0713$  in

**Shear on curb rail:**

$P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)

**Shear O.K.**

$P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**

$P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**

$P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**

$C = 3.00$   $m_f = 1.00$

**Shear and tension in bolt:**

(Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>

$P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 14.15$  ksi  $f_v = 9.14$  ksi O.K.

$P'_{nt} = A_b F'_{nt}$   $F'_{nt} = 15.62$  ksi  $F_{nv}/\Omega = 10.00$  ksi

$P'_{nt}/\Omega = 0.767$  k **No Good - Use Welds**

**Longitudinal weld loading:**

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$

If  $L/t < 25$ :  $L/t = 21.04$   $t = 0.0713$   $P_n/\Omega = 2.153$  k

**Transverse weld loading:**

$t = 0.0713$   $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$

$L = 1$   $F_u = 65$  ksi  $P_n/\Omega = 1.972$  k





Client:	ProVent	PV2312	Base curb
Project:	CBISC-14	Iso Curb	CBISCSAV28
Unit:	AV/AD 28; AE/AW 18-23; AH/AL 25; HV 25		

#### Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	154.5	in	(Length of base curb)
wcurb =	83.125	in	(Width of base curb)
WGTbase =	383	lbs	(Weight of base curb)
# Springs long side =	3		# Springs short side = 3

#### Unit Information

WGUnit =	3010	lbs	(Weight of Unit)
Wt'max =	994	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	731	lbs	(Wtmin+1/4*WGUpper)
Hunit =	57.25	in	(Height of unit above curb)
H'cm =	38.625	in	(Hcm+10"(upper+spring))
Lunit =	160.0625	in	(Length of unit)
Wunit =	88.75	in	(Width of unit)
WGUnit+upper+base =	3758	lbs	(Total weight)

#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	12120	lbs
	(unit + upper rail)	
ap =	2.5	
Rp =	2	
FpmaxASD =	13495	lbs
	(unit + upper rail + base curb)	

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf
Fh ASD trans =	3478	lbs
Fh ASD long =	1928	lbs
Fvert ASD =	2642	lbs

#### Base Curb Loading

##### Transverse:

Compression <sub>SEISMIC</sub> =	8255	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S <sub>DS</sub> ) * Wt'max * wcurb] / wcurb
Tension <sub>SEISMIC</sub> =	5221	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S <sub>DS</sub> ) * Wt'min * wcurb] / wcurb
Compression <sub>WIND</sub> =	1488	lbs	= [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb
Tension <sub>WIND</sub> =	2060	lbs	= [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb

---> Negative values indicate opposite load.

##### Longitudinal:


Compression <sub>SEISMIC</sub> =	5653	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S <sub>DS</sub> ) * Wt'max * Lcurb] / Lcurb
Tension <sub>SEISMIC</sub> =	2619	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S <sub>DS</sub> ) * Wt'min * Lcurb] / Lcurb
Compression <sub>WIND</sub> =	354	lbs	= [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb
Tension <sub>WIND</sub> =	926	lbs	= [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb

---> Negative values indicate opposite load.

#### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	8255	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	5221	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	5653	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	2619	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.








## Curb Design

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.1017 12 Gauge

## Calculate Section Properties of Curb

A' = <span style="border: 1px solid black;">25.000</span> in	a = 24.492 in = A' - (2r + t)
B' = <span style="border: 1px solid black;">1.750</span> in	a' = 24.898 in = A' - t
C' = <span style="border: 1px solid black;">1.000</span> in (0 if no lips)	b = 1.242 in = B' - [r + t/2 + α(r + t/2)]
α = <span style="border: 1px solid black;">1.000</span> (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2 + αt/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = α[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = α(C' - t/2)
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.187 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 205.037 in	r <sub>x</sub> = 8.23 in
I <sub>y</sub> = 0.672 in	r <sub>y</sub> = 0.471 in
A = 3.02 in <sup>2</sup>	r <sub>min</sub> = 0.471 in



## Axial Compression

P<sub>u</sub> = 6.060 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 6.244 k  
F<sub>e</sub> = 4.24 ksi       $\lambda_c = \frac{F_y}{F_e}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$   
λ<sub>c</sub> = 3.44      If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>)F<sub>y</sub>  
F<sub>n</sub> = 3.72 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$   
L<sub>y</sub> = 154.50 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 262 (assume k=0.8)

Compression Check = **O.K.**

## Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 245.82 ≤ 260	C <sub>R</sub> = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C <sub>N</sub> = 0.35	
Ω <sub>w</sub> = 1.75	N/h = 0.28 ≤ 2.0	C <sub>h</sub> = 0.02	
P <sub>n</sub> = 4.106 k	R/t = 1.50 ≤ 9.0		
P <sub>n</sub> /Ω <sub>w</sub> = 2.346 k			
Long side: P <sub>uTrans</sub> = 2.752 k	<b>web stiffener REQ'D</b> # clips = 3	$P_n = Ct^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$	
Short side: P <sub>uLong</sub> = 1.884 k	<b>O.K.</b> # clips = 3		

## Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 16 Gauge  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/t<sub>s</sub> ≤ 1.28E/F<sub>ys</sub>      Ω<sub>c</sub> = 1.70  
w/t<sub>s</sub> = 118.675  
1.28E/F<sub>ys</sub> = 31.091 --> w/t<sub>s</sub> over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>      A<sub>e</sub> = 0.380 in<sup>2</sup>  
P<sub>wc</sub> = 4.106 k  
P<sub>n</sub> = 16.181 k  
P<sub>n</sub>/Ω<sub>c</sub> = 9.518 k      **O.K.**

## Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 3374 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 4127 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: T<sub>all</sub> = 2480 lbs      V<sub>all</sub> = 1208 lbs  
Threaded Insert: T<sub>all</sub> = 2860 lbs      V<sub>all</sub> = 1096 lbs  
# of Bolts required for Tension = 1.4  
# of Bolts required for Shear = 3.8  
# of Bolts Used = 6.0  
Check Combined Stress in Bolts & Inserts: 0.854 **O.K.**

## Check 1/8" welded connection

---- USE WELD

Ω = 2.35

Assume L/t > 25: 25\*t = 2.543 in       $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$        $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$   
L<sub>req'd</sub> = 1.956 in



## Curb Loads (copied from upper rail calcs)

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> =	7388	lbs
	Tens <sub>MAX</sub> =	4688	lbs
	Shear <sub>MAX</sub> =	12120	lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> =	4956	lbs
	Tens <sub>MAX</sub> =	2256	lbs
	Shear <sub>MAX</sub> =	12120	lbs

Max compression force on isolator: 2.463 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 1.563 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 1.010 k ≤ 1.163 k **O.K.**

## Forces on bottom bolts:

$d_b = 0.5$  in  
 base curb,  $t = 0.1017$  in  
 Tension = 0.781 k / bolt  
 Shear = 0.505 k / bolt

**Shear on base curb:**  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n / \Omega = 6.611$  k  $e = 1.0$  in

**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n / \Omega = 8.428$  k  $A_n = 0.153$  in

**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n / \Omega = 3.966$  k  $d / t = 4.92$

**Bearing O.K.**

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)  
 Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt} / \Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$   
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv} / \Omega = 2.209$  k **Bolt shear O.K.** **\*\*\* (Table E3.4-1, AISI) \*\*\***

## Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 7.96$  ksi  $f_v = 2.57$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv} / \Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt} / \Omega = 3.927$  k **Combined Not Applicable ->  $F'_{nt} = F_{nt}$**

## Connection of Curb to Supporting Structure

**Roof Loading** SEISMIC:  $(0.6-0.14 S_{DS}) D + 0.7 E$

WIND:  $0.6 D + W$

<b>Transverse:</b>	Uplift <sub>MAX</sub> =	9802 lbs	Shear <sub>MAX</sub> =	6747 lbs
Compression <sub>SEISMIC</sub> =	12808 lbs	=[FpmaxASD*(H'cm+Hbase curb)+(1+0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb		
Tension <sub>SEISMIC</sub> =	9802 lbs	=[FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb		
Compression <sub>WIND</sub> =	2469 lbs	=[F <sub>h ASD trans</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *wcurb/2-F <sub>vert ASD</sub> *wcurb/2]/wcurb		
Tension <sub>WIND</sub> =	2855 lbs	=[F <sub>h ASD trans</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *wcurb/2+F <sub>vert ASD</sub> *wcurb/2]/wcurb		
<b>Longitudinal:</b>	Uplift <sub>MAX</sub> =	5030 lbs	Shear <sub>MAX</sub> =	6747 lbs
Compression <sub>SEISMIC</sub> =	8036 lbs	=[FpmaxASD*(H'cm+Hbase curb)+(1+0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb		
Tension <sub>SEISMIC</sub> =	5030 lbs	=[FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14SD <sub>S</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb		
Compression <sub>WIND</sub> =	601 lbs	=[F <sub>h ASD long</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb		
Tension <sub>WIND</sub> =	988 lbs	=[F <sub>h ASD long</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2+F <sub>vert ASD</sub> *Lcurb/2]/Lcurb		

**Wood Attachment:** 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

	Tall <sub>metal</sub> =	997	lbs	Vall <sub>metal</sub> =	1097	lbs
<b>Transverse:</b>	Tall <sub>wood</sub> =	760	lbs	Vall <sub>wood</sub> =	672	lbs
	# of Screws Req'd for Uplift =	12.90		COMBINED LOADING:	0.980	O.K.
	# of Screws Req'd for Shear =	10.04		Req'd Min Spacing =	7.71	in o.c.
	Total # of screws required =	20				



Use 20 - 1/4" φ x 4.5" Simpson SDS screws @ 7.7 in o.c. along long side of curb w/ 2.75" threaded embed

## Loads at each Isolator

Type:

CQA

<b>Transverse loading:</b> (on long edge) # isolators: 3	Comp <sub>MAX</sub> =	2462.6	lbs
	Tens <sub>MAX</sub> =	1562.6	lbs
	Shear <sub>MAX</sub> =	1010.0	lbs
<b>Longitudinal loading:</b> (on short edge) # isolators: 3	Comp <sub>MAX</sub> =	1652.0	lbs
	Tens <sub>MAX</sub> =	752.0	lbs
	Shear <sub>MAX</sub> =	1010.0	lbs



O.K.



Longitudinal:

# of Screws Req'd for Uplift = 6.62  
# of Screws Req'd for Shear = 10.04  
Total # of screws required = 10

COMBINED LOADING: 0.997 O.K.  
Screw Spacing = 8.35 in o.c.

Use 10 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 8.3 in o.c. along short side of curb w/ 2.75" threaded embed

**Steel Deck Attachment: 1/2"  $\phi$  A307 Bolts to steel angle below deck**

Transverse: Tall<sub>bolt</sub> = 3927 lbs Vall<sub>bolt</sub> = 2209 lbs  
Tall<sub>metal</sub> = 2086 lbs Vall<sub>metal</sub> = 2192 lbs  
# of Bolts Req'd for Uplift = 4.70 COMBINED LOADING: 0.979 O.K.  
# of Bolts Req'd for Shear = 3.08 Bolt Spacing = 23.75 in o.c.  
Total # of bolts required = 7

Use 7 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 23.8 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 2.41 COMBINED LOADING: 0.652 O.K.  
# of Bolts Req'd for Shear = 3.08 Bolt Spacing = 35.56 in o.c.  
Total # of bolts required = 3

Use 3 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 35.6 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>o</sub> E  $\Omega_o = 2.5$

**Concrete Attachment: 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed**

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c$  = 4000 psi  
h = 6 in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
 $h_{ef}$  = 4 in (effective embedment)  
da = 0.625 in (anchor diameter) do = 0.75 in (hole diameter)  
n = 5 (number of dummy anchors to check capacity with spacing effect)  
s = 14.2 in (initial spacing estimate)  
tk<sub>cr</sub> / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)  
tk<sub>cr</sub> / uncr = 1226 2327 psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
 $c_{Na} = 9.0625$  in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**

Bond strength  
\*\*\*Bond strength  
will govern over  
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1358.02 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 39416 \text{ lbs (group)}$$

$$\phi N_{ag} = 19215 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

**Breakout strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 825.6 \text{ in}^2$$

$$A_{Nco} = 144 \text{ in}^2$$

$$N_{cbg} = 49315 \text{ lbs (group)}$$

$$\phi N_{cbg} = 27739 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 8601 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

**Shear:**

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 3067$$

$$\alpha_{v,seismic} = 0.6$$

$$Tall_{LRFD} = 3843 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 2249 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift<sub>MAX</sub> = 13520 lbs Shear<sub>MAX</sub> = 16869 lbs

$$\text{Compression}_{SEISMIC} = 16702 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 13520 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 16869 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 6.01 \text{ spacing} = 23.75 \text{ in o.c.}$$

$$T_{applied} = 1352.0 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 9.40 \text{ spacing} = 15.83 \text{ in o.c.}$$


$$V_{applied} = 1054.3 \text{ lbs}$$

Try using 10 bolts  
spaced at 15.83 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.19 \text{ O.K.}$$

Use 10 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 15.8 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift<sub>MAX</sub> = 7016 lbs Shear<sub>MAX</sub> = 16869 lbs





# MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
(619)727-4800  
Page 8 of 8

$$\begin{aligned}
 \text{Compression}_{\text{SEISMIC}} &= 10198 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Tension}_{\text{SEISMIC}} &= 7016 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Shear}_{\text{SEISMIC}} &= 16869 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\
 \text{Min Bolts Req'd Uplift} &= 3.12 \text{ spacing} = 23.71 \text{ in o.c.} &\text{Applied} = 1169.4 \text{ lbs} \\
 \text{Min Bolts Req'd Shear} &= 9.40 \text{ spacing} = 7.90 \text{ in o.c.} &\text{Applied} = 1054.3 \text{ lbs} \\
 \text{Try using } 6 \text{ bolts spaced at } 14.23 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.11 \text{ O.K.}
 \end{aligned}$$

Use 6 - 0.625in  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 14.2 in o.c. max. along short side of curb w/ 4in embed

<b>CURB DESIGN SUMMARY:</b>		CBISC-14	CBISCSAV28	<b>Unit:</b>	AV/AD 28; AE/AW 18-23; AH/AL 25; HV 25
<b>UPPER CURB RAIL THICKNESS:</b>		0.1017 in	12 Gauge		
<b>UNIT CLIP THICKNESS:</b>		0.0713 in	14 Gauge		
<b># OF CLIPS (LONG SIDE)</b> - 3 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip					
<b># OF CLIPS (SHORT SIDE)</b> - 3 clips with 4 - #10 SMS screws each clip					
<b>WEB STIFFENER:</b> 16Ga x 1 3/16in x 7in (C-channel) stiffener at each clip					
<b>VIBRATION ISOLATOR TYPE:</b> CQA		Top stud diameter: 3/8		(3) - CQA Isolators long side	
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16		(3) - CQA Isolators short side	
<b>BASE CURB THICKNESS:</b> 0.1017 in		12 Gauge		***Must weld top of CQA***	
<b>WEB STIFFENER:</b> NOT REQUIRED					
<b>CORNER CONNECTION:</b> Use minimum 6 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
<b>CURB ANCHORAGE</b>	<u>WOOD</u>		<u>STEEL</u>	<u>CONCRETE</u>	
	1/4" $\phi$ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" $\phi$ A307 Bolts to steel angle below deck	0.625in $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed	
	<u>LONG DIRECTION</u>		20 @ 7.71 in o.c.	7 @ 23.75 in o.c.	10 @ 15.83 in o.c.
	<u>SHORT DIRECTION</u>		10 @ 8.35 in o.c.	3 @ 35.56 in o.c.	6 @ 14.23 in o.c.