



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-03 Series
CBISCSUN3672 SERIES**




Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 23, 2023
Project Number: PV2312

WELDMENT AND BOLTING DETAIL

* OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT

Note: * - INDICATES WELD REQUIRED I.L.O.
BOLTED STUD FOR THE FOLLOWING CURBS:


- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA/CQA:
 $\frac{9}{16}$ " \varnothing HOLE USE $\frac{1}{2}$ " \varnothing A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
 $\frac{1}{16}$ " \varnothing HOLE USE $\frac{5}{8}$ " \varnothing A307 BOLT
WITH FLAT WASHER AND NUT

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA/CQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-61

DATE:
08/14/23

REV:
2

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.

WELDED CURB

SHEATHING WHERE OCCURS

METAL DECK

STEEL ANGLE SUPPORT BY OTHERS

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 9-1/8" EDGE DISTANCE.

CONCRETE ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE.
SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø THREADED ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-62

DATE:
6/28/2023

REV:
4

DRAWN BY:
FMM

For wood, concrete and steel attachment see
Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are
standard. For bolted spring housing,
neoprene pads and spring cups see
Weldment and Bolting Detail, Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURBS FOR SMALL SUNLINE 3-6 TON UNITS

ZR, XN, XP 036-060,
ZE, ZF 036-072

PROVENT P/N	A	B	EST. WEIGHT
-------------	---	---	----------------

CBISCSUN367218**	8"	18"	260 Lbs.
------------------	----	-----	----------

CBISCSUN367221**	11"	21"	280 Lbs.
------------------	-----	-----	----------

CBISCSUN367224**	14"	24"	300 Lbs.
------------------	-----	-----	----------

**Note: Spring configuration must be
added to part number at time of order

Weight of upper portion supported by
spring isolators= 144 Lbs.




Meets seismic requirements for the
following codes:
CBC 2022
IBC 2021

FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____

COMPANY: _____

JOB NAME: _____

EQUIPMENT: _____

NOTES: _____

FORM NO:

CBISC-03

DATE:

8/14/2023

PART NUMBER:

-

REV:

5

DRAWN BY:

FMM




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-03	Iso Curb	CBISCSUN3672
Unit:	ZR, XN, XP 036-060; ZE, ZF 036-072		

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	72.5 in	(Length of upper curb)
wcurb =	36.75 in	(Width of upper curb)
WGTupper =	144 lbs	(Weight of upper curb)
# Clips long side =	2	
# Clips short side =	1	

Unit Information

WGTunit =	845 lbs	(Weight of Unit)
Wtmax =	254 lbs	(Maximum corner weight)
Wtmin =	180 lbs	(Minimum corner weight)
Hunit =	32.625 in	(Height of unit above curb)
Hcm =	16.3125 in	(Height to center of mass)
Lunit =	82.25 in	(Length of unit)
Wunit =	44.875 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3034 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 3551 lbs
		(unit + upper rail)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	739 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	403 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	686 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:		
Compression _{SEISMIC} =	2016 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1246 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	289 lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	456 lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:		
Compression _{SEISMIC} =	1352 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	582 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	52 lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	218 lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:		
Comp _{MAX} =	2016 lbs	---> Along long edge of curb.
(on long edge) Tens _{MAX} =	1246 lbs	---> Along long edge of curb.
Longitudinal:		
Comp _{MAX} =	1352 lbs	---> Along short edge of curb.
(on short edge) Tens _{MAX} =	582 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r + t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	rx = 2.08 in
I _y = 0.169 in ⁴	ry = 0.521 in
A = 0.62 in ²	rmin = 0.521 in



Axial Compression

P_a = 1.517 k (Max Axial Comp) Ω_c = 1.80

P_n/Ω_c = 14.341 k

Fe = 111.57 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

λ_c = 0.67 If λ_c ≤ 1.5; F_n = (0.658^{λ_c²) F_y If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$}

F_n = 41.45 ksi

Ly = 33.25 in Lateral unbraced length (assume k=0.8)

k_yL_y/r_y = 51

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50

t = 0.0713 in h/t = 77.14 ≤ 260 C_R = 0.08

N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12

Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048

P_n = 1.947 k R/t = 1.50 ≤ 12.0

P_n/Ω_w = 1.112 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Long side: P_{Utrans} = 1.008 k **O.K.** # clips = 2

Short side: P_{ULong} = 1.352 k **web stiffener REQ'D** # clips = 1

Check Web Stiffener

16Ga x 3/4in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}

width of stiffener = 7.000 in ts = 0.0566 16 Gauge P_{wc} = 1.947 k

web of stiff. w = 6.717 in Rs = 0.0849 in P_n = 14.669 k

***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70 A_e = 0.380 in²

w/ts = 118.675

1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 888 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)

V_{crnmax} = 1008 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1208 lbs

Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs

of Bolts required for Tension = 0.4

of Bolts required for Shear = 0.9

of Bolts Used = 2.0

Check Combined Stress in Bolts & Inserts: 0.639 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

L_{req'd} = 0.681 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$


$t_1 = 0.0713$ in (clip thickness) $t_2/t_1 = 1.0$ $F_{u1} = 65$ ksi
 $t_2 = 0.0713$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)

For $t_2/t_1 \leq 1.0$: $P_{ns} = 2266$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2377$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755$ #
 $P_{ss}/\Omega = 540$ # <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 249$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.517	2	0.76	540 #	4	2.00 in
Short side:	1.517	1	1.52	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)
Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies
 $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.463$ in² $A_{nv} = 0.416$ in² $A_{nt} = 0.082$ in²
 $R_n/\Omega = 8.674$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)

BSR O.K.



Curb Loads (copied from above)

Transverse:	Comp _{MAX} = 2760 lbs
(on long edge)	Tens _{MAX} = 1969 lbs
	Shear _{MAX} = 3551 lbs
Longitudinal:	Comp _{MAX} = 1721 lbs
(on short edge)	Tens _{MAX} = 930 lbs
	Shear _{MAX} = 3551 lbs

Loads at each Isolator

Type: CQA

Transverse loading:	Comp _{MAX} = 1380.1 lbs
(on long edge)	Tens _{MAX} = 984.5 lbs
# isolators: 2	Shear _{MAX} = 591.9 lbs
Longitudinal loading:	Comp _{MAX} = 1720.9 lbs
(on short edge)	Tens _{MAX} = 929.7 lbs
# isolators: 1	Shear _{MAX} = 591.9 lbs

Max compression force on isolator: 1.721 k ≤ 3.176 k **O.K.**
Max uplift on isolator: 0.985 k ≤ 3.176 k **O.K.**
Max shear on isolator: 0.592 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 0.985 k $d_b = 0.375$ in
Shear = 0.592 k upper rail, $t = 0.0713$ in

Shear on curb rail:

$P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K.

$P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 8.91$ ksi $f_v = 5.36$ ksi **O.K.**

$P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 1.519$ k $F_{nv}/\Omega = 10.00$ ksi

Combined O.K.

Longitudinal weld loading:

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading:

$t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



Client:	ProVent	PV2312	Base curb
Project:	CBISC-03	Iso Curb	CBISCSUN3672
Unit:	ZR, XN, XP 036-060; ZE, ZF 036-072		

Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	75	in	(Length of base curb)
wcurb =	39.25	in	(Width of base curb)
WGTbase =	156	lbs	(Weight of base curb)
# Springs long side =	2		# Springs short side = 1

Unit Information

WGUnit =	845	lbs	(Weight of Unit)
Wt'max =	290	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	216	lbs	(Wtmin+1/4*WGUpper)
Hunit =	32.625	in	(Height of unit above curb)
H'cm =	26.3125	in	(Hcm+10"(upper+spring))
Lunit =	82.25	in	(Length of unit)
Wunit =	44.875	in	(Width of unit)
WGUnit+upper+base =	1145	lbs	(Total weight)

Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3551 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 4112 lbs (unit + upper rail + base curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1310 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	715 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	686 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	3145 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	2260 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	883 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	963 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	2010 lbs	= [FpmaxASD*H'cm+2*(1+0.14*S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	1125 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	255 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	335 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	3145 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	2260 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	2010 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1125 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.






Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in	rx = 8.00 in
Iy = 0.218 in	ry = 0.329 in
A = 2.01 in ²	rmin = 0.329 in



Axial Compression

Pu = 1.776 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 8.576 k
Fe = 8.74 ksi
λc = 2.39
Fn = 7.67 ksi
Ly = 75.00 in
kyLy/r_y = 182

If λ_c ≤ 1.5; F_n = (0.658^{λ_c²}) F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 350.63 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.28 ≤ 2.0 C_h = 0.02
P_n = 2.105 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.203 k
Long side: P_{uTrans} = 1.572 k web stiffener REQ'D # clips = 2
Short side: P_{uLong} = 2.010 k web stiffener REQ'D # clips = 1

***h/t > 260; use web stiffeners

$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
w/ts = 118.675
1.28V(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k Ae = 0.380 in²
P_n = 14.780 k
P_n/Ω_c = 8.694 k O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1028 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
Vcrnmax = 1572 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.4
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.616 O.K.

Check 1/8" welded connection

USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in
Lreq'd = 1.063 in
 $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$
 $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} =	2760	lbs
	Tens _{MAX} =	1969	lbs
	Shear _{MAX} =	3551	lbs
Longitudinal: (on short edge)	Comp _{MAX} =	1721	lbs
	Tens _{MAX} =	930	lbs
	Shear _{MAX} =	3551	lbs

Max compression force on isolator: 1.721 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 0.985 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.592 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.0713$ in
 Tension = 0.492 k / bolt
 Shear = 0.296 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 2.781$ k $d / t = 7.01$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** ***** (Table E3.4-1, AISI) *****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 5.01$ ksi $f_v = 1.51$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> $F'_{nt} = F_{nt}$**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$ WIND: $0.6 D + W$

Transverse:	Uplift_{MAX} =	5215 lbs	Shear_{MAX} =	2056 lbs
Compression _{SEISMIC} =	6131 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) + (1 + 0.14 S _{DS}) * WGT _{unit+upper+base} * wcurb / 2] / wcurb		
Tension _{SEISMIC} =	5215 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) - (0.6 - 0.14 S _{DS}) * WGT _{unit+upper+base} * wcurb / 2] / wcurb		
Compression _{WIND} =	1713 lbs	= [F _{h ASD trans} * (H'cm + Hbase curb) + 0.6 * WGT _{unit+upper+base} * wcurb / 2 - F _{vert ASD} * wcurb / 2] / wcurb		
Tension _{WIND} =	1712 lbs	= [F _{h ASD trans} * (H'cm + Hbase curb) - 0.6 * WGT _{unit+upper+base} * wcurb / 2 + F _{vert ASD} * wcurb / 2] / wcurb		
Longitudinal:	Uplift_{MAX} =	2652 lbs	Shear_{MAX} =	2056 lbs
Compression _{SEISMIC} =	3568 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) + (1 + 0.14 S _{DS}) * WGT _{unit+upper+base} * Lcurb / 2] / Lcurb		
Tension _{SEISMIC} =	2652 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) - (0.6 - 0.14 S _{DS}) * WGT _{unit+upper+base} * Lcurb / 2] / Lcurb		
Compression _{WIND} =	489 lbs	= [F _{h ASD long} * (H'cm + Hbase curb) + 0.6 * WGT _{unit+upper+base} * Lcurb / 2 - F _{vert ASD} * Lcurb / 2] / Lcurb		
Tension _{WIND} =	489 lbs	= [F _{h ASD long} * (H'cm + Hbase curb) - 0.6 * WGT _{unit+upper+base} * Lcurb / 2 + F _{vert ASD} * Lcurb / 2] / Lcurb		

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

Tall_{metal} =

997

lbs

Tall_{wood} =

760

lbs

of Screws Req'd for Uplift =

6.86

of Screws Req'd for Shear =

3.06

Total # of screws required =

9

Vall_{metal} =

1097

lbs

Vall_{wood} =

672

lbs

COMBINED LOADING:

0.981 O.K.

Req'd Min Spacing =



8.38

in o.c.

Transverse:

Use 9 - 1/4" φ x 4.5" Simpson SDS screws @ 8.4 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator	Type:	CQA
Transverse loading: (on long edge)	Comp _{MAX} =	1380.1 lbs
# isolators: 2	Tens _{MAX} =	984.5 lbs
	Shear _{MAX} =	591.9 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} =	1720.9 lbs
# isolators: 1	Tens _{MAX} =	929.7 lbs
	Shear _{MAX} =	591.9 lbs





Longitudinal:

of Screws Req'd for Uplift = 3.49
of Screws Req'd for Shear = 3.06
Total # of screws required = 5

COMBINED LOADING: 0.917 O.K.
Screw Spacing = 7.81 in o.c.

Use 5 - 1/4" ϕ x 4.5" Simpson SDS screws @ 7.8 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Tall_{metal} = 2086 lbs Vall_{metal} = 2192 lbs
of Bolts Req'd for Uplift = 2.50 COMBINED LOADING: 0.781 O.K.
of Bolts Req'd for Shear = 0.94 Bolt Spacing = 21.00 in o.c.
Total # of bolts required = 4

Use 4 - 1/2" ϕ A307 Bolts to steel angle below deck @ 21 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.27 COMBINED LOADING: 0.474 O.K.
of Bolts Req'd for Shear = 0.94 Bolt Spacing = 27.25 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 27.3 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_o E $\Omega_o = 2.5$

Concrete Attachment: 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'_c = 4000 psi
h = 6 in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
h_{ef} = 4 in (effective embedment)
d_a = 0.625 in (anchor diameter) d_o = 0.75 in (hole diameter)
n = 5 (number of dummy anchors to check capacity with spacing effect)
s = 14 in (initial spacing estimate)
tk_{cr} / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)
tk_{cr} / uncr = 1226 2327 psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$
c_{Na} = 9.0625 in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength
***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1343.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 38995 \text{ lbs (group)}$$

$$\phi N_{ag} = 19010 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 816 \text{ in}^2$$

$$N_b = 8601 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 144 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 48741 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 27417 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = \text{7865 (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 3802 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 2225 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 5790 lbs Shear_{MAX} = 5140 lbs

$$\text{Compression}_{SEISMIC} = 6716 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 5790 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 5140 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.60 \text{ spacing} = 31.50 \text{ in o.c.}$$

$$\text{T applied} = 1447.4 \text{ lbs}$$


$$\text{Min Bolts Req'd Shear} = 2.86 \text{ spacing} = 31.50 \text{ in o.c.}$$

$$\text{V applied} = 856.6 \text{ lbs}$$

$$\text{Try using } 4 \text{ bolts spaced at } 21.00 \text{ in o.c.} \quad \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.13 \text{ O.K.}$$

Use 4 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 21 in o.c. max. along long side of curb w/ 4in embed

Longitudinal: Uplift_{MAX} = 2952 lbs Shear_{MAX} = 5140 lbs





MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page 8 of 8

$$\begin{aligned}
 \text{Compression}_{\text{SEISMIC}} &= 3879 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * W_{\text{GT}_{\text{unit+curb}}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Tension}_{\text{SEISMIC}} &= 2952 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * W_{\text{GT}_{\text{unit+curb}}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Shear}_{\text{SEISMIC}} &= 5140 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\
 \text{Min Bolts Req'd Uplift} &= 1.33 \text{ spacing} = 13.63 \text{ in o.c.} &\text{Applied} = 1476.2 \text{ lbs} \\
 \text{Min Bolts Req'd Shear} &= 2.86 \text{ spacing} = 13.63 \text{ in o.c.} &\text{Applied} = 856.6 \text{ lbs} \\
 \text{Try using } 2 \text{ bolts spaced at } 27.25 \text{ in o.c.} &\text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 &= 1.14 \text{ O.K.}
 \end{aligned}$$

Use 2 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 27.3 in o.c. max. along short side of curb w/ 4in embed

CURB DESIGN SUMMARY:		CBISC-03	CBISCSUN3672	Unit:	ZR, XN, XP 036-060; ZE, ZF 036-072
UPPER CURB RAIL THICKNESS:		0.0713 in	14 Gauge		
UNIT CLIP THICKNESS:		0.0713 in	14 Gauge		
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: NOT REQUIRED					
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8		(2) - CQA Isolators long side	
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16		(1) - CQA Isolators short side	
BASE CURB THICKNESS: 0.0713 in		14 Gauge		---Bolt or Weld O.K.---	
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
CORNER CONNECTION: Use minimum 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
CURB ANCHORAGE	<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>
	1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" ϕ A307 Bolts to steel angle below deck		0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed
	<u>LONG DIRECTION</u>		9 @ 8.38 in o.c.		4 @ 21 in o.c.
	<u>SHORT DIRECTION</u>		5 @ 7.81 in o.c.		2 @ 27.25 in o.c.