



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBKD-80 Series
CBKDPRD3715 SERIES**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: September 26, 2023
Project Number: PV2312




For wood, concrete, and steel attachments, see Roof Anchorage Detail, Form no. CB-60.

Will conform to seismic code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)


STRUCTURALLY CALCULATED HOLD DOWN CLIPS FOR KNOCK-DOWN ROOF CURBS FOR PREDATOR (SUN PRO) UNITS

ZT, ZH, ZJ, ZR 037-150
ZF, XP, ZB 078-150


PROVENT P/N	A	EST. WEIGHT	SEISMIC KIT P/N	WEIGHT
CBKDPRD371508	8"	115 Lbs.	KDKITPRD3715	23 Lbs.
CBKDPRD371511	11"	129 Lbs.		
CBKDPRD371514	14"	144 Lbs		
			Meets seismic requirements for the following codes: CBC 2022 IBC 2021	



HOLD DOWN DETAIL



CORNER DETAIL



DETAIL L



3847 WABASH DR.
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBKD-80

DATE:
8/25/2023


PART NUMBER:
KDKITPRD3715 SERIES

REV:
7

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

ASSUMES:


CONC SLAB
f_c= 4000PSI MINIMUM
4" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-60

DATE:
8/28/2023

REV:
10

DRAWN BY:
FMM




Client:	ProVent	PV2312
Description:	CBPKD-80	PRD3715
Unit:	ZT, ZH, ZR, ZJ 037-150; ZF, XP, ZB 078-150	

Curb Information

Hcurb =	14 in	(Height of curb)
Lcurb =	80.875 in	(Length of curb)
wcurb =	51 in	(Width of curb)
WGTCurb =	159 lbs	(Weight of curb)
# Clips long side =	2	
# Clips short side =	1	

Unit Information

WGTunit =	1736 lbs	(Oper. Weight of Unit)
Wtmax =	521 lbs	(Maximum corner weight)
Wtmin =	369 lbs	(Minimum corner weight)
Hunit =	50.75 in	(Height of unit above curb)
Hcm =	25.375 in	(Height to center of mass)
Lunit =	89 in	(Length of unit)
Wunit =	59 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2078 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 2268 lbs
		(unit and curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1484 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	983 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	1067 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:	
Compression _{SEISMIC} =	2408 lbs
Tension _{SEISMIC} =	827 lbs
Compression _{WIND} =	829 lbs
Tension _{WIND} =	829 lbs
---> Negative values indicate opposite load.	
Longitudinal:	
Compression _{SEISMIC} =	2737 lbs
Tension _{SEISMIC} =	601 lbs
Compression _{WIND} =	540 lbs
Tension _{WIND} =	540 lbs
---> Negative values indicate opposite load.	

Governing Reactions:

Transverse:	Comp _{MAX} =	2408 lbs	---> Along long edge of curb.
	Tens _{MAX} =	829 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	2737 lbs	---> Along short edge of curb.
	Tens _{MAX} =	601 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 **14 Gauge**

Calculate Section Properties of Curb

A' = 14.000 in	a = 13.644 in = A' - (2r+t)
B' = 1.750 in	a' = 13.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.171 in (Distance between centroid and web centerline)	
I _x = 27.499 in ⁴	r _x = 4.73 in
I _y = 0.204 in ⁴	r _y = 0.407 in
A = 1.23 in ²	r _{min} = 0.407 in



Axial Compression

P_u = 1.039 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 18.250 k
F_e = 33.42 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658^{λ_c}) F_y
λ_c = 1.22 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 26.73 ksi
L_y = 48 in Lateral unbraced length
k_yL_y/r_y = 93 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 196.35 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.5 ≤ 2.0 C_h = 0.02
P_n = 2.422 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.384 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
Long side: P_{uTrans} = 1.204 k **O.K.** # clips = 2
Short side: P_{uLong} = 1.368 k **O.K.** # clips = 2

*assumes partial load goes to clips on adjacent side.

Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)
width of stiffener = 6.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 101.007
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.324 in²
P_{wc} = 2.422 k P_n/Ω = 7.659 k
P_n = 13.021 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 567 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1368 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 1.1
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.454 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 0.925 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1d_wF_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.078	2	1.04	540 #	2	6.00 in
Short side:	2.078	2	1.04	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.443$ in²


$A_{nt} = 0.042$ in²

$R_n/\Omega = 7.500$ k

$R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 1485 lbs	Shear _{MAX} = 1134 lbs
Compression _{SEISMIC} =	3001 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1485 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1180 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vertASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1111 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vertASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 838 lbs	Shear _{MAX} = 1134 lbs
Compression _{SEISMIC} =	2354 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	838 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	514 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vertASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	444 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: 1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

$T_{allmetal} = 997$ lbs

$V_{allmetal} = 1097$ lbs

Transverse: $T_{allwood} = 616$ lbs

$V_{allwood} = 672$ lbs

of Screws Req'd for Uplift = 2.41

COMBINED LOADING: 0.820 O.K.

of Screws Req'd for Shear = 1.69

Screw Spacing = 18.2 in o.c.

Total # of screws Required = 5

1/4" ϕ x 3.5" Simpson SDS screws @ 18.2 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

of Screws Req'd for Uplift = 1.4

COMBINED LOADING: 0.762 O.K.

of Screws Req'd for Shear = 1.7

Screw Spacing = 14.3 in o.c.

Total # of screws Required = 4

1/4" ϕ x 3.5" Simpson SDS screws @ 14.3 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

$T_{allbolt} = 3927$ lbs

$V_{allbolt} = 2209$ lbs

Transverse: $T_{allmetal} = 2086$ lbs

$V_{allmetal} = 2192$ lbs

of Bolts Req'd for Uplift = 0.71

COMBINED LOADING: 0.284 O.K.

of Bolts Req'd for Shear = 0.52

Bolt Spacing = 68.9 in o.c.

Total # of Bolts Required = 2

1/2" ϕ A307 Bolts to steel angle below deck @ 68.9 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.40

COMBINED LOADING: 0.174 O.K.

of Bolts Req'd for Shear = 0.52

Req'd Min Spacing = 39.0 in o.c.

Total # of Bolts Required = 2

1/2" ϕ A307 Bolts to steel angle below deck @ 39 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_e E $\Omega_0 = 2.0$

Concrete Attachment: 1/2" ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 3000$ psi
 $h = 4$ in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
 $h_{ef} = 2.75$ in (effective embedment)
 $d_a = 0.5$ in (anchor diameter) $d_o = 0.625$ in (hole diameter)
 $n = 2$ (number of dummy anchors to check capacity with spacing effect)
 $s = 16.9$ in (initial spacing estimate)
 $\tau_{k,cr} / \text{uncr} = 1135 / 2220$ psi (from ESR 4868, Table 14, Temp range B)
 $\tau_{k,cr} / \text{uncr} = 1156 / 2261$ psi If $f'_c > 2500$, multiply by $(f'_c / 2500)^{0.1}$
 $c_{Na} = 7.15$ in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 408.98 \text{ in}^2$$

$$A_{Na0} = 204.49 \text{ in}^2$$

$$N_{ba} = 4943 \text{ lbs}$$

$$N_{ag} = 9886 \text{ lbs (group)}$$

$$\phi N_{ag} = 4820 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$$

$$\alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.8 \text{ for light}$$

**Breakout
strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 207.4875 \text{ in}^2$$

$$A_{Nco} = 68.0625 \text{ in}^2$$

$$N_{cbg} = 12945 \text{ lbs (group)}$$

$$\phi N_{cbg} = 7281 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 4246 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 4940 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 1927$$

$$T_{all,LRFD} = 2410 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E$$

$$T_{all,ASD} = T_{all,LRFD} / \alpha = 1411 \text{ lbs}$$

$$V_{all,ASD} = V_{all,LRFD} / \alpha = 1796 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 3236 lbs Shear_{MAX} = 2268 lbs

$$\text{Compression}_{SEISMIC} = 4752 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3236 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 2268 \text{ lbs} = \Omega_0 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.29 \text{ spacing} = 34.44 \text{ in o.c.}$$

$$T_{applied} = 1078.8 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 68.88 \text{ in o.c.}$$

$$V_{applied} = 453.7 \text{ lbs}$$

Try using 3 bolts

spaced at 34.44 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.02 \quad \text{O.K.}$$

Use 3 - 1/2" ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 34.4 in o.c. max. along long side of curb w/ 2.75in embed

Longitudinal: Uplift_{MAX} = 1943 lbs Shear_{MAX} = 2268 lbs

$$\text{Compression}_{SEISMIC} = 3459 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 1943 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 2268 \text{ lbs} = \Omega_0 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.38 \text{ spacing} = 19.50 \text{ in o.c.}$$

$$T_{applied} = 971.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 39.00 \text{ in o.c.}$$


$$V_{applied} = 453.7 \text{ lbs}$$

Try using 2 bolts

spaced at 39.00 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.94 \quad \text{O.K.}$$

Use 2 - 1/2" ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 39 in o.c. max. along short side of curb w/ 2.75in embed



CURB DESIGN SUMMARY:			CBPKD-80	PRD3715	Unit:	ZT, ZH, ZR, ZJ 037-150; ZF, XP, ZB 078-150
CURB RAIL THICKNESS:			0.0713 in	14 Gauge		
UNIT CLIP THICKNESS:			0.0713 in	14 Gauge		
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip						
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip						
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #10 SMS screws each clip						
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip						
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts						
CURB ANCHORAGE	WOOD		STEEL		CONCRETE	
	1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded embed		1/2" ϕ A307 Bolts to steel angle below deck		1/2" ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed	
	5 @ 18.22 in o.c.		2 @ 68.88 in o.c.		3 @ 34.44 in o.c.	
LONG DIRECTION	5 @ 18.22 in o.c.		2 @ 68.88 in o.c.		3 @ 34.44 in o.c.	
SHORT DIRECTION	4 @ 14.33 in o.c.		2 @ 39 in o.c.		2 @ 39 in o.c.	