



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBKD-140 Series**  
**CBKDPRS\*\* SERIES**



**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: September 26, 2023**  
**Project Number: PV2312**





For wood, concrete, and steel attachments, see Roof Anchorage Detail, Form no. CB-60.

Will conform to seismic code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)


## STRUCTURALLY CALCULATED HOLD DOWN CLIPS FOR KNOCK-DOWN ROOF CURBS FOR DIRECT FIT (SUN CORE) SMALL CABINET UNITS

ZX04-07; XXA7, ZXA7  
ZY, ZQ, XY, XQ, ZL04-06

PROVENT P/N	A	EST. WEIGHT	SEISMIC KIT P/N	WEIGHT
CBKDPRS08	8"	67 Lbs.	KDKITPRS	43 Lbs.
CBKDPRS11	11"	79 Lbs.		
CBKDPRS14	14"	91 Lbs	Meets seismic requirements for the following codes: CBC 2022 IBC 2021	



**DETAIL K**



**CORNER DETAIL**



3847 WABASH DR.  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBKD-140

DATE:  
7/18/2023


PART NUMBER:  
KDKITPRS SERIES

REV:  
9

DRAWN BY:  
JG

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

### ASSUMES:


CONC SLAB  
f<sub>c</sub>= 4000PSI MINIMUM  
4" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021

### ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

### CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-60

DATE:  
8/28/2023

REV:  
10

DRAWN BY:  
FMM




Client:	ProVent	PV2312
Description:	CBPKD-140	PRS
Unit:	ZX 04-07; XX/ZX A7; ZY, ZQ, XY, XQ, ZL 04-06	

#### Curb Information

Hcurb =	14 in	(Height of curb)
Lcurb =	70.875 in	(Length of curb)
wcurb =	40.69 in	(Width of curb)
WGTCurb =	134 lbs	(Weight of curb)
# Clips long side =	2	
# Clips short side =	1	

#### Unit Information

WGUnit =	916 lbs	(Oper. Weight of Unit)
Wtmax =	243 lbs	(Maximum corner weight)
Wtmin =	202 lbs	(Minimum corner weight)
Hunit =	40.56 in	(Height of unit above curb)
Hcm =	20.28 in	(Height to center of mass)
Lunit =	74.05 in	(Length of unit)
Wunit =	48.88 in	(Width of unit)



#### Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	1096 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 1257 lbs
		(unit and curb)

#### Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1040 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	687 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	736 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

#### Curb Loading

##### Transverse:

Compression <sub>SEISMIC</sub> =	1187 lbs	= [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	433 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*wcurb]/wcurb
Compression <sub>WIND</sub> =	442 lbs	= [Fh ASD trans*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	644 lbs	= [Fh ASD trans*Hcm-2*0.6*Wtmin*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

##### Longitudinal:

Compression <sub>SEISMIC</sub> =	954 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	201 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	120 lbs	= [Fh ASD long*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	322 lbs	= [Fh ASD long*Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

#### Governing Reactions:

Transverse:	Comp <sub>MAX</sub> =	1187 lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	644 lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	954 lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	322 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.

$$\begin{aligned} \text{Assume } L/t > 25: 25 \cdot t &= 1.783 \text{ in} \\ L_{req'd} &= 0.401 \text{ in} \end{aligned} \quad P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req} \quad L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$



**Connection Unit to Curb Clip**

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$  in

$F_{u1} = 65$  ksi

$t_2 = 0.1017$  in (unit base rail thickness)

$F_{u2} = 65$  ksi

$d = 0.190$  in (screw diameter)

$d_w = 0.375$  in (nom. washer diameter)

$t_2/t_1 = 1.4$

For  $t_2/t_1 \leq 1.0$ :

Shear:  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2377$  #

For  $t_2/t_1 \geq 2.5$ :

$P_{ns} = 2377$  #

$P_{ns} = 2.7t_1dF_{u1}$  2.38 k

$P_{ns} = 2.7t_1dF_{u1}$  2.38 k

$P_{ns} = 2.7t_2dF_{u2}$  3.39 k

$P_{ns} = 2.7t_2dF_{u2}$  3.39 k

$P_{ns}/\Omega = 792$  #

$P_{ss}/\Omega = 540$  # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension:  $P_{not} = 1.068$  k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$  k (screw pull-over strength)

$P_{nov} = 1.5t_1d_w F_{u1}$

$P_{ts}/\Omega = 356$  # <- Controls

$P_{ts}/\Omega = 820$  #

(full tensile screw capacity)

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	1.096	2	0.55	540 #	2	6.00 in
Short side:	1.096	1	1.10	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$  ksi

$\Omega = 2.22$  bolt/screw connection

$A_{gv} = 0.463$  in<sup>2</sup>

$A_{nv} = 0.430$  in<sup>2</sup>


$A_{nt} = 0.042$  in<sup>2</sup>

$R_n/\Omega = 7.500$  k

$R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$

(AISI Sect. E5.3)

**BSR O.K.**



**Connection of Curb to Supporting Structure**

**Roof Loading**

SEISMIC:  $(0.6-0.14S_{DS})D + 0.7E$

WIND:  $0.6D + W$

Transverse:	Uplift <sub>MAX</sub> = 929 lbs	Shear <sub>MAX</sub> = 628 lbs
Compression <sub>SEISMIC</sub> =	1751 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension <sub>SEISMIC</sub> =	911 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression <sub>WIND</sub> =	823 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vertASD} * w_{curb}/2] / w_{curb}$
Tension <sub>WIND</sub> =	929 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vertASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift <sub>MAX</sub> = 460 lbs	Shear <sub>MAX</sub> = 628 lbs
Compression <sub>SEISMIC</sub> =	1300 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension <sub>SEISMIC</sub> =	460 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression <sub>WIND</sub> =	279 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vertASD} * L_{curb}/2] / L_{curb}$
Tension <sub>WIND</sub> =	385 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vertASD} * L_{curb}/2] / L_{curb}$

**Wood Attachment:** 1/4"  $\phi$  x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

Tall<sub>metal</sub> = 997 lbs

Vall<sub>metal</sub> = 1097 lbs

Transverse: Tall<sub>wood</sub> = 616 lbs

Vall<sub>wood</sub> = 672 lbs

# of Screws Req'd for Uplift = 1.51

COMBINED LOADING: 0.814 O.K.

# of Screws Req'd for Shear = 0.94

Screw Spacing = 31.4 in o.c.

Total # of screws Required = 3

1/4"  $\phi$  x 3.5" Simpson SDS screws @ 31.4 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift = 0.7

COMBINED LOADING: 0.841 O.K.

# of Screws Req'd for Shear = 0.9

Screw Spacing = 32.7 in o.c.

Total # of screws Required = 2

1/4"  $\phi$  x 3.5" Simpson SDS screws @ 32.7 in o.c. along short side of curb w/ 2.25" threaded embed

**Steel Deck Attachment:**

1/2"  $\phi$  A307 Bolts to steel angle below deck

Tall<sub>bolt</sub> = 3927 lbs

Vall<sub>bolt</sub> = 2209 lbs

Transverse: Tall<sub>metal</sub> = 2086 lbs

Vall<sub>metal</sub> = 2192 lbs

# of Bolts Req'd for Uplift = 0.45

COMBINED LOADING: 0.121 O.K.

# of Bolts Req'd for Shear = 0.29

Bolt Spacing = 58.9 in o.c.

Total # of Bolts Required = 2

1/2"  $\phi$  A307 Bolts to steel angle below deck @ 58.9 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 0.22

COMBINED LOADING: 0.065 O.K.

# of Bolts Req'd for Shear = 0.29

Req'd Min Spacing = 28.7 in o.c.

Total # of Bolts Required = 2

1/2"  $\phi$  A307 Bolts to steel angle below deck @ 28.7 in o.c. along short side of curb



**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>e</sub> E  $\Omega_0 = 2.0$

**Concrete Attachment:** 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 3000$  psi  
 $h = 4$  in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
 $h_{ef} = 2.75$  in (effective embedment)  
 $d_a = 0.5$  in (anchor diameter)  $d_o = 0.625$  in (hole diameter)  
 $n = 2$  (number of dummy anchors to check capacity with spacing effect)  
 $s = 16.9$  in (initial spacing estimate)  
 $\tau_{k,cr} / \text{uncr} = 1135 / 2220$  psi (from ESR 4868, Table 14, Temp range B)  
 $\tau_{k,cr} / \text{uncr} = 1156 / 2261$  psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
 $c_{Na} = 7.15$  in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**

**Bond strength**

\*\*\*Bond strength  
will govern over  
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 408.98 \text{ in}^2$$

$$A_{Na0} = 204.49 \text{ in}^2$$

$$N_{ba} = 4943 \text{ lbs}$$

$$N_{ag} = 9886 \text{ lbs (group)}$$

$$\phi N_{ag} = 4820 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$$

$$\alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.8 \text{ for light}$$

**Breakout  
strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 207.4875 \text{ in}^2$$

$$A_{Nco} = 68.0625 \text{ in}^2$$

$$N_{cbg} = 12945 \text{ lbs (group)}$$

$$\phi N_{cbg} = 7281 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 4246 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

**Shear:**

**Steel strength**

$$V_{sa,eq} = 4940 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 1927$$

$$T_{all,LRFD} = 2410 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E$$

$$T_{all,ASD} = T_{all,LRFD} / \alpha = 1411 \text{ lbs}$$

$$V_{all,ASD} = V_{all,LRFD} / \alpha = 1796 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

**Transverse:** Uplift<sub>MAX</sub> = 1970 lbs Shear<sub>MAX</sub> = 1257 lbs

$$\text{Compression}_{SEISMIC} = 2810 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 1970 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 1257 \text{ lbs} = \Omega_0 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.40 \text{ spacing} = 29.44 \text{ in o.c.}$$

$$T_{applied} = 985.1 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 58.88 \text{ in o.c.}$$

$$V_{applied} = 314.2 \text{ lbs}$$

Try using 2 bolts

spaced at 58.88 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.87 \quad \text{O.K.}$$

Use 2 - 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 58.9 in o.c. max. along long side of curb w/ 2.75in embed

**Longitudinal:** Uplift<sub>MAX</sub> = 1068 lbs Shear<sub>MAX</sub> = 1257 lbs

$$\text{Compression}_{SEISMIC} = 1908 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 1068 \text{ lbs} = [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 1257 \text{ lbs} = \Omega_0 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 0.76 \text{ spacing} = 14.35 \text{ in o.c.}$$

$$T_{applied} = 534.2 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 28.69 \text{ in o.c.}$$


$$V_{applied} = 314.2 \text{ lbs}$$

Try using 2 bolts

spaced at 28.69 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.55 \quad \text{O.K.}$$

Use 2 - 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 28.7 in o.c. max. along short side of curb w/ 2.75in embed



CURB DESIGN SUMMARY:		Unit:
CURB RAIL THICKNESS: 0.0713 in 14 Gauge		ZX 04-07; XX/ZX A7; ZY, ZQ, XY,
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge		XQ, ZL 04-06
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
# OF CLIPS (SHORT SIDE) - 1 clips with 3 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
CORNER CONNECTION: Use 3 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts		
CURB ANCHORAGE	WOOD	STEEL
	1/4" $\phi$ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" $\phi$ A307 Bolts to steel angle below deck
LONG DIRECTION	3 @ 31.44 in o.c.	2 @ 58.88 in o.c.
SHORT DIRECTION	2 @ 32.69 in o.c.	2 @ 28.69 in o.c.