



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBKD-165 Series
CBKDSAV1518 SERIES**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: September 26, 2023
Project Number: PV2312

FEATURES

- Roof curb perimeter made of galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Corner flanges are pre-threaded for easy bolt on assembly.
- Pitched, adjustable height, welded, different height, isolation and calculated curbs are available.

NOTES

Attach ductwork to roof curb.
Flanges of duct rest on top of curb.
Support ductwork below the curb.

HOLD DOWN CLIPS FOR SUNCHOICE UNITS

AV15-18, AD15-18; AH15, AL15, HV13

ProVent P/N

A

Est. Weight

SEISMIC CLIP P/N:

Est. Weight

CBKDSAV151808

8"

195 Lbs.

CBKDSAV151811

11"

225 Lbs.

CBKDSAV151814

14"

265 Lbs.

CBKDSAV151818



18"

462 Lbs.


KDKITSAV1518

20 Lbs.


Meets seismic requirements
for the following codes:
CBC 2022
IBC 2021



Attach to curb with
(3) #10x3/4" TEK Screws
each side.




CORNER ATTACHMENT
(3) 1/4"-20 THREADED INSERT
(3) 1/4"-20x3/4" GRADE 8 BOLT



HOLD DOWN DETAIL

CORNER & HOLD DOWN DETAIL



3847 WABASH DR.
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____

COMPANY: _____

JOB NAME: _____

EQUIPMENT: _____

NOTES: _____

FORM NO:

CBKD-165

PART NUMBER:

CBKD-165

DATE:

8/25/2023

REV:


3

DRAWN BY:

FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

ASSUMES:


CONC SLAB
f_c= 4000PSI MINIMUM
4" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-60

DATE:
8/28/2023

REV:
10

DRAWN BY:
FMM




Client:	ProVent	PV2312
Description:	CBPKD-165	SAV1518
Unit:	AV 15-18; AD 15-18; AH/AL 15; HV 13	

Curb Information

Hcurb =	18 in	(Height of curb)
Lcurb =	121.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	545 lbs	(Weight of curb)
# Clips long side =	2	
# Clips short side =	2	

Unit Information

WGUnit =	2385 lbs	(Oper. Weight of Unit)
Wtmax =	716 lbs	(Maximum corner weight)
Wtmin =	507 lbs	(Minimum corner weight)
Hunit =	49.25 in	(Height of unit above curb)
Hcm =	24.625 in	(Height to center of mass)
Lunit =	129.75 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2855 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 3507 lbs
		(unit and curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2246 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1537 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2340 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:		
Compression _{SEISMIC} =	2765 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	593 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	379 lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	1252 lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb
---> Negative values indicate opposite load.		
Longitudinal:		
Compression _{SEISMIC} =	2468 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	296 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	1 lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	874 lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb
---> Negative values indicate opposite load.		

Governing Reactions:

Transverse:		
(on long edge)	Comp _{MAX} = 2765 lbs	---> Along long edge of curb.
	Tens _{MAX} = 1252 lbs	---> Along long edge of curb.
Longitudinal:		
(on short edge)	Comp _{MAX} = 2468 lbs	---> Along short edge of curb.
	Tens _{MAX} = 874 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.492 in = A' - (2r+t)
B' = 1.500 in	a' = 17.898 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.246 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.449 in = B' - (t/2+αt/2)
R = 0.1525 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.000 in = α(C' - t/2)
r = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.102 in (Distance between centroid and web centerline)	
I _x = 70.803 in ⁴	r _x = 5.81 in
I _y = 0.185 in ⁴	r _y = 0.297 in
A = 2.10 in ²	r _{min} = 0.297 in



Axial Compression

P_u = 1.427 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 6.875 k
F_e = 6.73 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 2.73 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 5.90 ksi
L_y = 77.125 in Lateral unbraced length
k_yL_y/r_y = 208 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 18 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 176.99 ≤ 260	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.388889 ≤ 2.0	C _h = 0.02	
P _n = 4.390 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 2.509 k			
Long side: P _{uTrans} = 1.383 k	O.K. # clips = 2	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{uLong} = 1.234 k	O.K. # clips = 2		

Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)
width of stiffener = 6.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 101.007
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.324 in²
P_{wc} = 4.390 k P_n/Ω = 8.470 k
P_n = 14.398 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 877 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1383 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.1
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.499 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.655 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.1017$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.0$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 3391$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 3391$ #

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 1130$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 3.718$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.855	2	1.43	540 #	3	3.00 in
Short side:	2.855	2	1.43	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.1017 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.661$ in²

$A_{nv} = 0.613$ in²


$A_{nt} = 0.060$ in²

$R_n/\Omega = 10.697$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 1486 lbs	Shear _{MAX} = 1754 lbs
Compression _{SEISMIC} =	3798 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1454 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	904 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vertASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1486 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vertASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 832 lbs	Shear _{MAX} = 1754 lbs
Compression _{SEISMIC} =	3167 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	823 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	250 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vertASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	832 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: 1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	2.41	COMBINED LOADING: 0.837 O.K.
# of Screws Req'd for Shear =	2.61	Screw Spacing = 22.6 in o.c.
Total # of screws Required =	6	

1/4" ϕ x 3.5" Simpson SDS screws @ 22.6 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift =	1.4	COMBINED LOADING: 0.990 O.K.
# of Screws Req'd for Shear =	2.6	Screw Spacing = 24.0 in o.c.
Total # of screws Required =	4	

1/4" ϕ x 3.5" Simpson SDS screws @ 24 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 2086 lbs	Vall _{metal} = 2192 lbs
# of Bolts Req'd for Uplift =	0.71	COMBINED LOADING: 0.202 O.K.
# of Bolts Req'd for Shear =	0.80	Bolt Spacing = 54.6 in o.c.
Total # of Bolts Required =	3	

1/2" ϕ A307 Bolts to steel angle below deck @ 54.6 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.40	COMBINED LOADING: 0.285 O.K.
# of Bolts Req'd for Shear =	0.80	Req'd Min Spacing = 68.1 in o.c.
Total # of Bolts Required =	2	

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_oE Ω_o = 2.0

Concrete Attachment: 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 3000$ psi
 $h = 4$ in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
 $h_{ef} = 2.75$ in (effective embedment)
 $d_a = 0.5$ in (anchor diameter) $d_o = 0.625$ in (hole diameter)
 $n = 2$ (number of dummy anchors to check capacity with spacing effect)
 $s = 16.9$ in (initial spacing estimate)
 $\tau_{k,cr} / \text{uncr} = 1135 / 2220$ psi (from ESR 4868, Table 14, Temp range B)
 $\tau_{k,cr} / \text{uncr} = 1156 / 2261$ psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$
 $c_{Na} = 7.15$ in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 408.98 \text{ in}^2$$

$$A_{Na0} = 204.49 \text{ in}^2$$

$$N_{ba} = 4943 \text{ lbs}$$

$$N_{ag} = 9886 \text{ lbs (group)}$$

$$\phi N_{ag} = 4820 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$$

$$\alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.8 \text{ for light}$$

**Breakout
strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 207.4875 \text{ in}^2$$

$$A_{Nco} = 68.0625 \text{ in}^2$$

$$N_{cbg} = 12945 \text{ lbs (group)}$$

$$\phi N_{cbg} = 7281 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 4246 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 4940 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 1927$$

$$T_{all,LRFD} = 2410 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E$$

$$T_{all,ASD} = T_{all,LRFD} / \alpha = 1411 \text{ lbs}$$

$$V_{all,ASD} = V_{all,LRFD} / \alpha = 1796 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 3320 lbs Shear_{MAX} = 3507 lbs

$$\text{Compression}_{SEISMIC} = 5664 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3320 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3507 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.35 \text{ spacing} = 54.56 \text{ in o.c.}$$

$$T_{applied} = 1106.7 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 109.13 \text{ in o.c.}$$

$$V_{applied} = 701.4 \text{ lbs}$$

Try using 3 bolts

spaced at 54.56 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18 \quad \text{O.K.}$$

Use 3 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 54.6 in o.c. max. along long side of curb w/ 2.75in embed

Longitudinal: Uplift_{MAX} = 2057 lbs Shear_{MAX} = 3507 lbs

$$\text{Compression}_{SEISMIC} = 4401 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 2057 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 3507 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.46 \text{ spacing} = 34.06 \text{ in o.c.}$$

$$T_{applied} = 1028.5 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 68.13 \text{ in o.c.}$$


$$V_{applied} = 701.4 \text{ lbs}$$

Try using 2 bolts

spaced at 68.13 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12 \quad \text{O.K.}$$

Use 2 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 2.75in embed



CURB DESIGN SUMMARY:		Unit:
CBPKD-165 SAV1518		AV 15-18; AD 15-18; AH/AL 15;
CURB RAIL THICKNESS: 0.1017 in 12 Gauge		HV 13
UNIT CLIP THICKNESS: 0.1017 in 12 Gauge		
# OF CLIPS (LONG SIDE) - 2 clips with 3 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts		
CURB ANCHORAGE	WOOD	STEEL
	CONCRETE	
LONG DIRECTION	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" φ A307 Bolts to steel angle below deck
	6 @ 22.63 in o.c.	3 @ 54.56 in o.c.
SHORT DIRECTION	4 @ 24.04 in o.c.	2 @ 68.13 in o.c.
		2 @ 68.13 in o.c.