



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBKD-166 Series**  
**CBKDSAV2025\*\* SERIES**



**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**


**Date: September 26, 2023**  
**Project Number: PV2312**


|  |  |     |               |     |             |   |             |
|--|--|-----|---------------|-----|-------------|---|-------------|
| <p><b>FEATURES</b></p> <ul style="list-style-type: none"> <li>• Roof curb perimeter made of galvanized steel.</li> <li>• Gasketing package provided.</li> <li>• Heat treated wood nailer provided.</li> <li>• Corner flanges are pre-threaded for easy bolt on assembly.</li> <li>• Pitched, adjustable height, welded, different height, isolation and calculated curbs are available.</li> </ul> | <p><b>HOLD DOWN CLIPS FOR SUNCHOICE UNITS</b></p> <p>AV20-25, AD20-25, AE13-15, AW13-15, AH18-20, AL18-20, HV15-20</p> |     | ProVent P/N   | A   | Est. Weight | SEISMIC CLIP P/N:   | Est. Weight |
|  |  |     | CBKDSAV202508 | 8"  | 220 Lbs.    | KDKITSAV2025  | 25 Lbs.     |
|  | CBKDSAV202511  | 11" | 250 Lbs.      |     |             |   |             |
|  | CBKDSAV202514  | 14" | 280 Lbs.      |     |             |   |             |
|  |  |     | CBKDSAV202518 | 18" | 400 Lbs.    | Meets seismic requirements for the following codes:<br>CBC 2022<br>IBC 2021 |             |


**NOTES**

Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.


**For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60**







**CORNER ATTACHMENT**  
 (3) 1/4"-20 THREADED INSERT  
 (3) 1/4"-20x3/4" GRADE 8 BOLT



Attach to curb with (3) #10x3/4" TEK Screws each side.


Unit Base Rail


Attach to unit with (3) #10 TEK Screws per clip.

14 Ga Unit Hold Down

14 Ga Curb for 8", 11" & 14" tall curb (12 Ga for 18" tall curb)

**HOLD DOWN DETAIL**





**3847 WABASH DR.  
MIRA LOMA, CA 91752**

**PHONE (951) 685-1101  
FAX (619) 872-9799**

SUBMITTED TO: \_\_\_\_\_

COMPANY: \_\_\_\_\_

JOB NAME: \_\_\_\_\_

EQUIPMENT: \_\_\_\_\_

NOTES: \_\_\_\_\_

**PART NUMBER:**  
CBKD-166

**DATE:**  
8/25/2023


**PART NUMBER:**  
CBKD-166

**REV:**  
2

**DRAWN BY:**  
FMM

### STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

| CURB    | LONG SIDE       | SHORT SIDE      |
|---------|-----------------|-----------------|
| LXS     | 2 @ 34.5" O.C.  | 2 @ 19" O.C.    |
| LXL     | 2 @ 34.5" O.C.  | 2 @ 29" O.C.    |
| SUN3672 | 2 @ 60.5" O.C.  | 2 @ 24.75" O.C. |
| PRD3715 | 2 @ 68.88" O.C. | 2 @ 39" O.C.    |
| PRS     | 2 @ 58.88" O.C. | 2 @ 28.69" O.C. |
| PRL     | 2 @ 72" O.C.    | 2 @ 41.5" O.C.  |
| SAV1518 | 3 @ 54.56" O.C. | 2 @ 68.13" O.C. |
| SAV2025 | 3 @ 61.56" O.C. | 2 @ 68.13" O.C. |
| SAV28   | 3 @ 69.75" O.C. | 2 @ 68.13" O.C. |

### ASSUMES:


CONC SLAB  
f<sub>c</sub>= 4000PSI MINIMUM  
4" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:  
CBC 2022  
IBC 2021

### ROOF ANCHORAGE DETAIL

| CBKD Series | CBWC Series |
|-------------|-------------|
| LXS         | LXS         |
| LXL         | LXL         |
| SUN3672     | SUN3672     |
| PRD3715     | PRD3715     |
| PRS         | PRS         |
| PRL         | PRL         |
| SAV1518     | SAV1518     |
| SAV2025     | SAV2025     |
| SAV28       | SAV28       |

### CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

| CURB    | LONG SIDE       | SHORT SIDE      |
|---------|-----------------|-----------------|
| LXS     | 2 @ 34.5" O.C.  | 2 @ 19.0" O.C.  |
| LXL     | 2 @ 34.5" O.C.  | 2 @ 29" O.C.    |
| SUN3672 | 2 @ 60.5" O.C.  | 2 @ 24.75" O.C. |
| PRD3715 | 4 @ 22.96" O.C. | 2 @ 39" O.C.    |
| PRS     | 2 @ 58.88" O.C. | 2 @ 28.69" O.C. |
| PRL     | 3 @ 36" O.C.    | 2 @ 41.5" O.C.  |
| SAV1518 | 4 @ 36.38" O.C. | 2 @ 68.13" O.C. |
| SAV2025 | 4 @ 41.04" O.C. | 3 @ 34.06" O.C. |
| SAV28   | 5 @ 34.88" O.C. | 3 @ 34.06" O.C. |

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.

### WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

| CURB    | LONG SIDE       | SHORT SIDE      |
|---------|-----------------|-----------------|
| LXS     | 4 @ 12.83" O.C. | 3 @ 11.5" O.C.  |
| LXL     | 4 @ 12.83" O.C. | 3 @ 16.5" O.C.  |
| SUN3672 | 4 @ 21.5" O.C.  | 3 @ 14.38" O.C. |
| PRD3715 | 7 @ 12.15" O.C. | 5 @ 10.75" O.C. |
| PRS     | 4 @ 20.96" O.C. | 3 @ 16.35" O.C. |
| PRL     | 6 @ 15.2" O.C.  | 4 @ 15.17" O.C. |
| SAV1518 | 6 @ 22.63" O.C. | 5 @ 18.03" O.C. |
| SAV2025 | 7 @ 21.19" O.C. | 5 @ 18.03" O.C. |
| SAV28   | 8 @ 20.5" O.C.  | 5 @ 18.03" O.C. |



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-60

DATE:  
8/28/2023

REV:  
10

DRAWN BY:  
FMM




|              |   |         |
|--------------|---|---------|
| Client:      | ProVent   | PV2312  |
| Description: | CBPKD-166                                       | SAV2025 |
| Unit:        | AV/AD 20-25; AE/AW 13-15; AH/AL 18-20; HV 15-20 |         |

#### Curb Information

|                      |            |                  |
|----------------------|------------|------------------|
| Hcurb =              | 18 in      | (Height of curb) |
| Lcurb =              | 135.125 in | (Length of curb) |
| wcurb =              | 80.125 in  | (Width of curb)  |
| WGTCurb =            | 565 lbs    | (Weight of curb) |
| # Clips long side =  | 3          |                  |
| # Clips short side = | 2          |                  |

#### Unit Information

|          |             |                             |
|----------|-------------|-----------------------------|
| WGUnit = | 2655 lbs    | (Oper. Weight of Unit)      |
| Wtmax =  | 797 lbs     | (Maximum corner weight)     |
| Wtmin =  | 564 lbs     | (Minimum corner weight)     |
| Hunit =  | 57.25 in    | (Height of unit above curb) |
| Hcm =    | 28.625 in   | (Height to center of mass)  |
| Lunit =  | 143.8125 in | (Length of unit)            |
| Wunit =  | 88.75 in    | (Width of unit)             |



#### Seismic Loading - 2021 IBC/2022 CBC

|            |             |   |
|------------|-------------|---|
| Ss =       | 2.85        | (Worst case for majority of California)         |
| Fa =       | 1.20        | (Default Site Class D - Table 11.4-1 ASCE 7-16) |
| Ip =       | 1.50        | (Importance Factor Category III Building)       |
| Sms =      | 3.420       | (Fa*Ss)   |
| Sds =      | 2.280       | (2/3*Sms)                                       |
| Fpmax =    | 1.710 Wp    | (0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp        |
| FpmaxASD = | 3178 lbs    | (0.7*Fpmax)                                     |
|            | (unit only) |   |
|            |             | ap = 2.5  |
|            |             | Rp = 6  |
|            |             | FpmaxASD = 3854 lbs                             |
|            |             | (unit and curb)                                 |

#### Wind Loading - 2021 IBC/2022 CBC

|                |          |   |
|----------------|----------|---|
| Kz =           | 1.13     | (For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)                         |
| Kzt =          | 1.0      | (No topographic effects assumed for rooftop mounted units)                            |
| Kd =           | 0.85     | (Directionality factor Table 26.6-1 ASCE 7-16)  |
| V =            | 115      | (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16) |
| GCr(horiz) =   | 1.9      | (Refer Sect 29.4.1 ASCE 7-16)   |
| GCr(vert) =    | 1.5      | (Refer Sect 29.4.1 ASCE 7-16)   |
| qz =           | 32.5 psf | = 0.00256*Kz*Kzt*Kd*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)                            |
| Fh ASD trans = | 2786 lbs | = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)   |
| Fh ASD long =  | 1719 lbs | = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)  |
| Fvert ASD =    | 2594 lbs | = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)   |

#### Curb Loading

##### Transverse:

|                                  |          |   |
|----------------------------------|----------|---|
| Compression <sub>SEISMIC</sub> = | 3237 lbs | = [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb   |
| Tension <sub>SEISMIC</sub> =     | 819 lbs  | = [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*wcurb]/wcurb |
| Compression <sub>WIND</sub> =    | 654 lbs  | = [Fh ASD trans*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb  |
| Tension <sub>WIND</sub> =        | 1615 lbs | = [Fh ASD trans*Hcm-2*0.6*Wtmin*wcurb+Fvert ASD*wcurb/2]/wcurb  |

---> Negative values indicate opposite load.

##### Longitudinal:

|                                  |          |   |
|----------------------------------|----------|---|
| Compression <sub>SEISMIC</sub> = | 2775 lbs | = [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb   |
| Tension <sub>SEISMIC</sub> =     | 356 lbs  | = [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*Lcurb]/Lcurb |
| Compression <sub>WIND</sub> =    | 23 lbs   | = [Fh ASD long*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb   |
| Tension <sub>WIND</sub> =        | 984 lbs  | = [Fh ASD long*Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD*Lcurb/2]/Lcurb   |

---> Negative values indicate opposite load.

#### Governing Reactions:

|                 |                       |          |                                |
|-----------------|-----------------------|----------|--------------------------------|
| Transverse:     | Comp <sub>MAX</sub> = | 3237 lbs | ---> Along long edge of curb.  |
| (on long edge)  | Tens <sub>MAX</sub> = | 1615 lbs | ---> Along long edge of curb.  |
| Longitudinal:   | Comp <sub>MAX</sub> = | 2775 lbs | ---> Along short edge of curb. |
| (on short edge) | Tens <sub>MAX</sub> = | 984 lbs  | ---> Along short edge of curb. |

---> Negative values indicate opposite load.




### Curb Design

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.1017 **12 Gauge**

### Calculate Section Properties of Curb

|   |                                      |
|---|--------------------------------------|
| A' = 18.000 in  | a = 17.492 in = A' - (2r+t)          |
| B' = 1.500 in   | a' = 17.898 in = A' - t              |
| C' = 0.000 in (0 if no lips)                                | b = 1.246 in = B' - [r+t/2+α(r+t/2)] |
| α = 0.000 (0 - no Lip; 1 w/ lip)                            | b' = 1.449 in = B' - (t/2+αt/2)      |
| R = 0.1525 (Inside bend radius)                             | c = 0.000 in = α[C' - (r+t/2)]       |
| t = 0.1017 in   | c' = 0.000 in = α(C' - t/2)          |
| r = 0.203 in = R+t/2  | u = 0.319 in = πr/2                  |
| x = 0.102 in (Distance between centroid and web centerline) |                                      |
| I <sub>x</sub> = 70.803 in <sup>4</sup>                     | r <sub>x</sub> = 5.81 in             |
| I <sub>y</sub> = 0.185 in <sup>4</sup>                      | r <sub>y</sub> = 0.297 in            |
| A = 2.10 in <sup>2</sup>                                    | r <sub>min</sub> = 0.297 in          |



### Axial Compression

P<sub>u</sub> = 1.589 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 6.875 k  
F<sub>e</sub> = 6.73 ksi       $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$       If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>  
λ<sub>c</sub> = 2.73       $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$       If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$       λ<sub>c</sub> =  $\sqrt{\frac{F_y}{F_e}}$       F<sub>e</sub> =  $\frac{\pi^2 E}{(kl/r)^2}$   
F<sub>n</sub> = 5.90 ksi  
L<sub>y</sub> = 77.125 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 208 (assume k=0.8)

**Compression Check = O.K.**

### Check Web Crippling

h = 18 in      -- Check limits:      C = 4.00  
t = 0.1017 in      h/t = 176.99 ≤ 260      C<sub>R</sub> = 0.14  
N = 7.00      N/t = 68.83 ≤ 210      C<sub>N</sub> = 0.35  
Ω<sub>w</sub> = 1.75      N/h = 0.388889 ≤ 2.0      C<sub>h</sub> = 0.02  
P<sub>n</sub> = 4.390 k      R/t = 1.50 ≤ 9.0  
P<sub>n</sub>/Ω<sub>w</sub> = 2.509 k  
Long side: P<sub>uTrans</sub> = 1.079 k      **O.K.** # clips = 3       $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$   
Short side: P<sub>uLong</sub> = 1.387 k      **O.K.** # clips = 2

### Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)  
width of stiffener = 6.000 in      t<sub>s</sub> = 0.0566 **16 Gauge**  
web of stiff. w = 5.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28√E/F<sub>y</sub>      Ω<sub>c</sub> = 1.70  
w/ts = 101.007  
1.28√(E/F<sub>y</sub>) = 31.091 --> w/ts over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>      A<sub>e</sub> = 0.324 in<sup>2</sup>  
P<sub>wc</sub> = 4.390 k      P<sub>n</sub>/Ω = 8.470 k  
P<sub>n</sub> = 14.398 k

**Not Req'd**

### Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 964 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 1618 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1208 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1536 lbs  
# of Bolts required for Tension = 0.4  
# of Bolts required for Shear = 1.3  
# of Bolts Used = 3.0  
Check Combined Stress in Bolts & Inserts: 0.576 **O.K.**

### Check 1/8" welded connection

<--- USE WELD      Ω = 2.35  
Assume L/t > 25: 25\*t = 2.543 in       $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tL F_u \geq V_{req}$       L<sub>req'd</sub> =  $\frac{V_{req}\Omega}{0.75tF_u}$   
L<sub>req'd</sub> = 0.767 in



**Connection Unit to Curb Clip**

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.1017$  in

$F_{u1} = 65$  ksi

$t_2 = 0.1017$  in (unit base rail thickness)

$F_{u2} = 65$  ksi

$d = 0.190$  in (screw diameter)

$dw = 0.375$  in (nom. washer diameter)

$t_2/t_1 = 1.0$

For  $t_2/t_1 \leq 1.0$ :

Shear:  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 3391$  #

3.86 k

For  $t_2/t_1 \geq 2.5$ :

$P_{ns} = 2.7t_1dF_{u1}$

$P_{ns} = 3391$  #

3.39 k

$P_{ns} = 2.7t_2dF_{u2}$

3.39 k

$P_{ns} = 2.7t_2dF_{u2}$

3.39 k

$P_{ns}/\Omega = 1130$  #

$P_{ss}/\Omega = 540$  # <- Controls

Tension:  $P_{not} = 1.068$  k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 3.718$  k (screw pull-over strength)

$t_c = \min(t_1, t_2)$   
 $P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$  # <- Controls

$P_{ts}/\Omega = 820$  #

(full tensile screw capacity)

|             | Shear (k) | # clips | $V_{clip}$ (k) | $V_{allow}$ (lb) | # screws | spacing |
|-------------|-----------|---------|----------------|------------------|----------|---------|
| Long side:  | 3.178     | 3       | 1.06           | 540 #            | 2        | 6.00 in |
| Short side: | 3.178     | 2       | 1.59           | 540 #            | 3        | 3.00 in |

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.1017 AISI BSR applies

$F_y = 50$  ksi

$\Omega = 2.22$  bolt/screw connection

$A_{gv} = 0.661$  in<sup>2</sup>

$A_{nv} = 0.613$  in<sup>2</sup>


$A_{nt} = 0.060$  in<sup>2</sup>

$R_n/\Omega = 10.697$  k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

**BSR O.K.**



**Connection of Curb to Supporting Structure**

**Roof Loading**

SEISMIC:  $(0.6-0.14S_{DS})D + 0.7E$

WIND:  $0.6D + W$

|                                  |                                  |  |
|----------------------------------|----------------------------------|--|
| Transverse:                      | Uplift <sub>MAX</sub> = 1952 lbs | Shear <sub>MAX</sub> = 1927 lbs  |
| Compression <sub>SEISMIC</sub> = | 4367 lbs                         | $= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$                 |
| Tension <sub>SEISMIC</sub> =     | 1791 lbs                         | $= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$               |
| Compression <sub>WIND</sub> =    | 1290 lbs                         | $= [F_{hASDtrans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vertASD} * w_{curb}/2] / w_{curb}$ |
| Tension <sub>WIND</sub> =        | 1952 lbs                         | $= [F_{hASDtrans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vertASD} * w_{curb}/2] / w_{curb}$ |
| Longitudinal:                    | Uplift <sub>MAX</sub> = 924 lbs  | Shear <sub>MAX</sub> = 1927 lbs  |
| Compression <sub>SEISMIC</sub> = | 3454 lbs                         | $= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$                 |
| Tension <sub>SEISMIC</sub> =     | 878 lbs                          | $= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$               |
| Compression <sub>WIND</sub> =    | 262 lbs                          | $= [F_{hASDlong} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vertASD} * L_{curb}/2] / L_{curb}$  |
| Tension <sub>WIND</sub> =        | 924 lbs                          | $= [F_{hASDlong} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vertASD} * L_{curb}/2] / L_{curb}$  |

**Wood Attachment:** 1/4"  $\phi$  x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

|                                |                                 |                                  |
|--------------------------------|---------------------------------|----------------------------------|
| Transverse:                    | Tall <sub>metal</sub> = 997 lbs | Vall <sub>metal</sub> = 1097 lbs |
|                                | Tall <sub>wood</sub> = 616 lbs  | Vall <sub>wood</sub> = 672 lbs   |
| # of Screws Req'd for Uplift = | 3.17                            | COMBINED LOADING: 0.862 O.K.     |
| # of Screws Req'd for Shear =  | 2.87                            | Screw Spacing = 21.2 in o.c.     |
| Total # of screws Required =   | 7                               |                                  |

1/4"  $\phi$  x 3.5" Simpson SDS screws @ 21.2 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

|                                |     |                              |
|--------------------------------|-----|------------------------------|
| # of Screws Req'd for Uplift = | 1.5 | COMBINED LOADING: 0.874 O.K. |
| # of Screws Req'd for Shear =  | 2.9 | Screw Spacing = 18.0 in o.c. |
| Total # of screws Required =   | 5   |                              |

1/4"  $\phi$  x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

**Steel Deck Attachment:**

1/2"  $\phi$  A307 Bolts to steel angle below deck

|                               |                                  |                                  |
|-------------------------------|----------------------------------|----------------------------------|
| Transverse:                   | Tall <sub>bolt</sub> = 3927 lbs  | Vall <sub>bolt</sub> = 2209 lbs  |
|                               | Tall <sub>metal</sub> = 2086 lbs | Vall <sub>metal</sub> = 2192 lbs |
| # of Bolts Req'd for Uplift = | 0.94                             | COMBINED LOADING: 0.273 O.K.     |
| # of Bolts Req'd for Shear =  | 0.88                             | Bolt Spacing = 61.6 in o.c.      |
| Total # of Bolts Required =   | 3                                |                                  |

1/2"  $\phi$  A307 Bolts to steel angle below deck @ 61.6 in o.c. along long side of curb

Longitudinal:

|                               |      |                                  |
|-------------------------------|------|----------------------------------|
| # of Bolts Req'd for Uplift = | 0.44 | COMBINED LOADING: 0.335 O.K.     |
| # of Bolts Req'd for Shear =  | 0.88 | Req'd Min Spacing = 68.1 in o.c. |
| Total # of Bolts Required =   | 2    |                                  |

1/2"  $\phi$  A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Q<sub>s</sub>E  $\Omega_0 = 2.0$

**Concrete Attachment:** 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 3000$  psi  
 $h = 4$  in (concrete thickness,  $t_{min} = h_{ef} + 2d_o$ ) O.K.  
 $h_{ef} = 2.75$  in (effective embedment)  
 $d_a = 0.5$  in (anchor diameter)  $d_o = 0.625$  in (hole diameter)  
 $n = 2$  (number of dummy anchors to check capacity with spacing effect)  
 $s = 16.9$  in (initial spacing estimate)  
 $\tau_{k,cr} / \text{uncr} = 1135 / 2220$  psi (from ESR 4868, Table 14, Temp range B)  
 $\tau_{k,cr} / \text{uncr} = 1156 / 2261$  psi If  $f'_c > 2500$ , multiply by  $(f'_c/2500)^{0.1}$   
 $c_{Na} = 7.15$  in (min. edge distance for full capacity);  $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**

**Bond strength**

\*\*\*Bond strength  
will govern over  
concrete breakout

$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba}$  (ACI318-14, 17.4.5.1b)  
 $\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$   
 $A_{Na} = 408.98$  in<sup>2</sup>  
 $A_{Na0} = 204.49$  in<sup>2</sup>  
 $N_{ba} = 4943$  lbs  $N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$   $\alpha_{n,seismic} = 0.99$   
 $N_{ag} = 9886$  lbs (group)  $\lambda_a = 1.0$   
 $\phi N_{ag} = 4820$  lbs (group)  $\lambda_a = 1.0$  for normal weight conc; U.b for light

**Breakout  
strength**

$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$   $N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$   
 $A_{Nc} = 207.4875$  in<sup>2</sup>  $N_b = 4246$  lbs  $\phi_{conc} = 0.75$   
 $A_{Nco} = 68.0625$  in<sup>2</sup>  $k_c = 17$   $\phi_{bond} = 0.65$   
 $N_{cbg} = 12945$  lbs (group)  $\phi_{seis} = 0.75$   
 $\phi N_{cbg} = 7281$  lbs (group)  $\phi_{steel} = 0.65$

**Shear:**

**Steel strength**

$V_{sa,eq} = 4940$  (from ESR4868, Table 11)  $\alpha_{v,seismic} = 0.6$   
 $\phi V_{sa,eq} = 1927$   
 $T_{all,LRFD} = 2410$  lbs (anchor)  $V_{all,LRFD} = 3067$  lbs  $\alpha = (1 + 0.2SDS)D + 2.5E$   
 $T_{all,ASD} = T_{all,LRFD}/\alpha = 1411$  lbs  $V_{all,ASD} = V_{all,LRFD}/\alpha = 1796$  lbs  $D = 0.758$   $E = 0.242$   $\alpha = 1.709$

**Transverse:** Uplift<sub>MAX</sub> = 4034 lbs Shear<sub>MAX</sub> = 3854 lbs


Compression<sub>SEISMIC</sub> = 6610 lbs  $= [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$   
Tension<sub>SEISMIC</sub> = 4034 lbs  $= [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$   
Shear<sub>SEISMIC</sub> = 3854 lbs  $= \Omega_0 * F_{pmaxASD}/2$   
Min Bolts Req'd Uplift = 2.86 spacing = 61.56 in o.c.  $T_{applied} = 1008.4$  lbs  
Min Bolts Req'd Shear = 2.15 spacing = 61.56 in o.c.  $V_{applied} = 642.4$  lbs  
Try using 4 bolts  
spaced at 41.04 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.07$  O.K.

Use 4 - 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 41 in o.c. max. along long side of curb w/ 2.75in embed

**Longitudinal:** Uplift<sub>MAX</sub> = 2208 lbs Shear<sub>MAX</sub> = 3854 lbs

Compression<sub>SEISMIC</sub> = 4784 lbs  $= [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$   
Tension<sub>SEISMIC</sub> = 2208 lbs  $= [\Omega_0 * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$   
Shear<sub>SEISMIC</sub> = 3854 lbs  $= \Omega_0 * F_{pmaxASD}/2$   
Min Bolts Req'd Uplift = 1.56 spacing = 34.06 in o.c.  $T_{applied} = 1103.9$  lbs  
Min Bolts Req'd Shear = 2.15 spacing = 34.06 in o.c.  $V_{applied} = 642.4$  lbs  
Try using 2 bolts  
spaced at 68.13 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.14$  O.K.

Use 2 - 1/2"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 2.75in embed



|   |   |                   |  |                           |
|---|---|-------------------|--|---------------------------|
| <b>CURB DESIGN SUMMARY:</b>   |   | CBPKD-166 SAV2025 | <b>Unit:</b>                                     | AV/AD 20-25; AE/AW 13-15; |
| CURB RAIL THICKNESS: 0.1017 in 12 Gauge   |   |                   | AH/AL 18-20; HV 15-20                            |                           |
| UNIT CLIP THICKNESS: 0.1017 in 12 Gauge   |   |                   |  |                           |
| # OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip                      |   |                   |  |                           |
| WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip                      |   |                   |  |                           |
| # OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip                     |   |                   |  |                           |
| WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip                      |   |                   |  |                           |
| CORNER CONNECTION: Use 3 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts |   |                   |  |                           |
| CURB ANCHORAGE  | WOOD  |                   | STEEL  |                           |
|   | 1/4" $\phi$ x 3.5" Simpson SDS screws w/ 2.25" threaded embed |                   | 1/2" $\phi$ A307 Bolts to steel angle below deck |                           |
| LONG DIRECTION  | 7 @ 21.19 in o.c.   |                   | 3 @ 61.56 in o.c.                                |                           |
| SHORT DIRECTION   | 5 @ 18.03 in o.c.   |                   | 2 @ 68.13 in o.c.                                |                           |
|   |   |                   | 4 @ 41.04 in o.c.                                |                           |
|   |   |                   | 2 @ 68.13 in o.c.                                |                           |