



MOUR GROUP
ENGINEERING + DESIGN






6593 Riverdale St.
San Diego, CA 92120
619-727-4800


Structural Calculations
for
CBKD-167 Series
CBKDSAV28 SERIES**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725


Date: September 26, 2023
Project Number: PV2312

FEATURES <ul style="list-style-type: none"> • Roof curb perimeter made of galvanized steel. • Gasketing package provided. • Heat treated wood nailer provided. • Corner flanges are pre-threaded for easy bolt on assembly. • Pitched, adjustable height, welded, different height, isolation and calculated curbs are available. 		HOLD DOWN CLIPS FOR SUNCHOICE UNITS AV28, AD28, AE18-23, AW18-23, AH25, AL25, HV25		ProVent P/N	A	Est. Weight	SEISMIC CLIP P/N:	Est. Weight
				CBKDSAV2808	8"	240 Lbs.		
				CBKDSAV2811	11"	275 Lbs.	KDKITSAV28	27 Lbs.
				CBKDSAV2814	14"	311 Lbs.		
				CBKDSAV2818	18"	454 Lbs.		
NOTES Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb. For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60								
Meets seismic requirements for the following codes: CBC 2022 IBC 2021								
 <p>Attach to curb with (3) #10x3/4" TEK Screws each side.</p> <p>Unit Base Rail</p> <p>Attach to unit with (3) #10 TEK Screws per clip.</p> <p>14 Ga Unit Hold Down (3) each side (12 total)</p> <p>14 Ga Curb for 8", 11" & 14" tall curb (12 Ga for 18" tall curb)</p>		 <p>1 3/8" Typ.</p> <p>7" Typ.</p> <p>CORNER ATTACHMENT (3) 1/4"-20 THREADED INSERT (3) 1/4"-20x3/4" GRADE 8 BOLT</p>						
HOLD DOWN DETAIL		CORNER & HOLD DOWN DETAIL						

	3847 WABASH DR. MIRA LOMA, CA 91752 PHONE (951) 685-1101 FAX (619) 872-9799	SUBMITTED TO: _____		FORM NO: CBKD-167		PART NUMBER: KDKIT28	
		COMPANY: _____		DATE: 8/25/2023		REV: 1	
		JOB NAME: _____				DRAWN BY: FMM	
		EQUIPMENT: _____					
		NOTES: _____					

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

ASSUMES:


CONC SLAB
f_c= 4000PSI MINIMUM
4" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
8/28/2023

REV:
10

DRAWN BY:
FMM




Client:	ProVent	PV2312
Description:	CBPKD-167	SAV28
Unit:	AV/AD 28; AE/AW 18-23; AH/AL 25; HV 25	

Curb Information

Hcurb =	18 in	(Height of curb)
Lcurb =	151.5 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	585 lbs	(Weight of curb)
# Clips long side =	3	
# Clips short side =	3	

Unit Information

WGUnit =	3010 lbs	(Oper. Weight of Unit)
Wtmax =	903 lbs	(Maximum corner weight)
Wtmin =	640 lbs	(Minimum corner weight)
Hunit =	57.25 in	(Height of unit above curb)
Hcm =	28.625 in	(Height to center of mass)
Lunit =	160.0625 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3603 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 4303 lbs
		(unit and curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	3101 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1719 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2887 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:	
Compression _{SEISMIC} =	3670 lbs
Tension _{SEISMIC} =	928 lbs
Compression _{WIND} =	748 lbs
Tension _{WIND} =	1784 lbs
---> Negative values indicate opposite load.	
Longitudinal:	
Compression _{SEISMIC} =	3063 lbs
Tension _{SEISMIC} =	322 lbs
Compression _{WIND} =	-35 lbs
Tension _{WIND} =	1001 lbs
---> Negative values indicate opposite load.	

Governing Reactions:

Transverse:	Comp _{MAX} =	3670 lbs	---> Along long edge of curb.
	Tens _{MAX} =	1784 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	3063 lbs	---> Along short edge of curb.
	Tens _{MAX} =	1001 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.492 in = A' - (2r+t)
B' = 1.500 in	a' = 17.898 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.246 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.449 in = B' - (t/2+αt/2)
R = 0.1525 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.000 in = α(C' - t/2)
r = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.102 in (Distance between centroid and web centerline)	
I _x = 70.803 in ⁴	r _x = 5.81 in
I _y = 0.185 in ⁴	r _y = 0.297 in
A = 2.10 in ²	r _{min} = 0.297 in



Axial Compression

P_u = 1.801 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 6.875 k
F_e = 6.73 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658^{λ_c}) F_y λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
λ_c = 2.73 If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
F_n = 5.90 ksi
L_y = 77.125 in Lateral unbraced length
k_yL_y/r_y = 208 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 18 in -- Check limits: C = 4.00
t = 0.1017 in h/t = 176.99 ≤ 260 C_R = 0.14
N = 7.00 N/t = 68.83 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.388889 ≤ 2.0 C_h = 0.02
P_n = 4.390 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 2.509 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
Long side: P_{uTrans} = 1.223 k **O.K.** # clips = 3
Short side: P_{uLong} = 1.021 k **O.K.** # clips = 3

Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)
width of stiffener = 6.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 101.007
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.324 in²
P_{wc} = 4.390 k P_n/Ω = 8.470 k
P_n = 14.398 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 1076 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1835 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.5
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.651 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 0.870 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.1017$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.0$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 3391$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 3391$ #

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 1130$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 3.718$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.603	3	1.20	540 #	3	3.00 in
Short side:	3.603	3	1.20	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.1017 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.661$ in²

$A_{nv} = 0.613$ in²


$A_{nt} = 0.060$ in²

$R_n/\Omega = 10.697$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 2169 lbs	Shear _{MAX} = 2152 lbs
Compression _{SEISMIC} =	4875 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1999 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1439 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vertASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	2169 lbs	$= [F_{hASDtrans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vertASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 894 lbs	Shear _{MAX} = 2152 lbs
Compression _{SEISMIC} =	3696 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	820 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	164 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vertASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	894 lbs	$= [F_{hASDlong} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: 1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	3.52	COMBINED LOADING: 0.961 O.K.
# of Screws Req'd for Shear =	3.20	Screw Spacing = 23.9 in o.c.
Total # of screws Required =	7	

1/4" ϕ x 3.5" Simpson SDS screws @ 23.9 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift =	1.5	COMBINED LOADING: 0.931 O.K.
# of Screws Req'd for Shear =	3.2	Screw Spacing = 18.0 in o.c.
Total # of screws Required =	5	

1/4" ϕ x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 2086 lbs	Vall _{metal} = 2192 lbs
# of Bolts Req'd for Uplift =	1.04	COMBINED LOADING: 0.326 O.K.
# of Bolts Req'd for Shear =	0.98	Bolt Spacing = 69.8 in o.c.
Total # of Bolts Required =	3	

1/2" ϕ A307 Bolts to steel angle below deck @ 69.8 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.43	COMBINED LOADING: 0.382 O.K.
# of Bolts Req'd for Shear =	0.98	Req'd Min Spacing = 68.1 in o.c.
Total # of Bolts Required =	2	

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_e E Ω_o = 2.0

Concrete Attachment: 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'c = 3000 psi
h = 4 in (concrete thickness, t_{min} = h_{ef} + 2do) O.K.
h_{ef} = 2.75 in (effective embedment)
da = 0.5 in (anchor diameter) do = 0.625 in (hole diameter)
n = 2 (number of dummy anchors to check capacity with spacing effect)
s = 16.9 in (initial spacing estimate)
tk,cr / uncr = 1135 / 2220 psi (from ESR 4868, Table 14, Temp range B)
tk,cr / uncr = 1156 / 2261 psi If f'c > 2500, multiply by (f'c/2500)^{0.1}
c_{Na} = 7.15 in (min. edge distance for full capacity); c_{Na} = 10d_a√(τ_{uncr}/1100)

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

N_{ag} = $\frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba}$ (ACI318-14, 17.4.5.1b)
φ_{ec,Na} φ_{ed,Na} φ_{cp,Na} = 1.0
A_{Na} = 408.98 in²
A_{Na0} = 204.49 in²
N_{ba} = 4943 lbs N_{ba} = λ_a τ_{cr} π d_a h_{ef} α_{n,seismic} α_{n,seismic} = 0.99
N_{ag} = 9886 lbs (group) λ_a = 1.0
φN_{ag} = 4820 lbs (group) λ_a = 1.0 for normal weight conc; U.b for light

**Breakout
strength**

N_{cbg} = $\frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$ N_b = λ_a k_c √f'c h_{ef}^{1.5}
A_{Nc} = 207.4875 in² N_b = 4246 lbs φ_{conc} = 0.75
A_{Nco} = 68.0625 in² k_c = 17 φ_{bond} = 0.65
N_{cbg} = 12945 lbs (group) φ_{seis} = 0.75
φN_{cbg} = 7281 lbs (group) φ_{steel} = 0.65

Shear:

Steel strength

V_{sa,eq} = 4940 (from ESR4868, Table 11) α_{v,seismic} = 0.6
V_{sa,eq} = 1927
Tall_{LRFD} = 2410 lbs (anchor) V_{all,LRFD} = 3067 lbs α = (1 + 0.2SDS)D + 2.5E
Tall_{ASD} = Tall_{LRFD}/α = 1411 lbs V_{all,ASD} = V_{all,LRFD}/α = 1796 lbs D = 0.758 E = 0.242 α = 1.709

Transverse: Uplift_{MAX} = 4503 lbs Shear_{MAX} = 4303 lbs

Compression_{SEISMIC} = 7379 lbs = [Ω_o*F_{pmaxASD}*(H_{cm}+H_{curb})+(1+0.14S_{DS})*WGT_{unit+curb}*w_{curb}/2]/w_{curb}
Tension_{SEISMIC} = 4503 lbs = [Ω_o*F_{pmaxASD}*(H_{cm}+H_{curb})-(0.6-0.14S_{DS})*WGT_{unit+curb}*w_{curb}/2]/w_{curb}
Shear_{SEISMIC} = 4303 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 3.19 spacing = 46.50 in o.c. T_{applied} = 1125.8 lbs
Min Bolts Req'd Shear = 2.40 spacing = 69.75 in o.c. V_{applied} = 717.2 lbs
Try using 4 bolts COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.20$ O.K.
spaced at 46.50 in o.c.

Use 4 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 46.5 in o.c. max. along long side of curb w/ 2.75in embed

Longitudinal: Uplift_{MAX} = 2144 lbs Shear_{MAX} = 4303 lbs

Compression_{SEISMIC} = 5020 lbs = [Ω_o*F_{pmaxASD}*(H_{cm}+H_{curb})+(1+0.14S_{DS})*WGT_{unit+curb}*L_{curb}/2]/L_{curb}
Tension_{SEISMIC} = 2144 lbs = [Ω_o*F_{pmaxASD}*(H_{cm}+H_{curb})-(0.6-0.14S_{DS})*WGT_{unit+curb}*L_{curb}/2]/L_{curb}
Shear_{SEISMIC} = 4303 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 1.52 spacing = 34.06 in o.c. T_{applied} = 1072.0 lbs
Min Bolts Req'd Shear = 2.40 spacing = 34.06 in o.c. V_{applied} = 717.2 lbs
Try using 2 bolts COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$ O.K.
spaced at 68.13 in o.c.

Use 2 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 2.75in embed

CURB DESIGN SUMMARY: CBPKD-167 SAV28			Unit: AV/AD 28; AE/AW 18-23; AH/AL 25; HV 25
CURB RAIL THICKNESS: 0.1017 in 12 Gauge			
UNIT CLIP THICKNESS: 0.1017 in 12 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 3 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 3 clips with 3 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4"φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" φ A307 Bolts to steel angle below deck	1/2"φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed
	LONG DIRECTION	7 @ 23.92 in o.c.	3 @ 69.75 in o.c.
SHORT DIRECTION	5 @ 18.03 in o.c.	2 @ 68.13 in o.c.	2 @ 68.13 in o.c.

