




MOUR GROUP
ENGINEERING + DESIGN

Wind Calculations
for
York LX Series (Small Chassis) Rooftop
Equipment

Kit #80-265-49**

2017 Florida Building Code requirements




Prepared for:

PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: January 25, 2019
Project Number: PV1807

STEEL ATTACHMENT


CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE *	
80-265-49	2 @ 34.5" o.c.	2 @ 19" o.c.	LXS
80-265-50	2 @ 34.5" o.c.	2 @ 29" o.c.	LXL
80-265-13	2 @ 61" o.c.	2 @ 25.3" o.c.	SUNLINE 3-6 TON
80-265-45	2 @ 58.4" o.c.	2 @ 28.2" o.c.	PRESTIGE SMALL
80-265-46	2 @ 72" o.c.	2 @ 41" o.c.	PRESTIGE LARGE
80-265-29	3 @ 34.7" o.c.	2 @ 39.5" o.c.	PREDATOR
80-265-19	3 @ 51.6" o.c.	2 @ 72" o.c.	SUNLINE ULTRA
80-265-18	4 @ 38.1" o.c.	3 @ 36" o.c.	SUNLINE MAGNA

WOOD ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø WOOD LAG SCREWS (3.5" MIN. EMBED. INTO WOOD FRAMING)



CURB KIT	NO. OF ANCHORAGE SCREWS REQUIRED		UNIT
	LONG SIDE	SHORT SIDE	
80-265-49	5 @ 9.6" o.c.	3 @ 11.5" o.c.	LXS
80-265-50	5 @ 9.6" o.c.	5 @ 8.3" o.c.	LXL
80-265-13	8 @ 9.3" o.c.	4 @ 9.8" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 12.5" o.c.	3 @ 16.1" o.c.	PRESTIGE SMALL
80-265-46	6 @ 15.2" o.c.	4 @ 15" o.c.	PRESTIGE LARGE
80-265-29	14 @ 5.6" o.c.	7 @ 7.3" o.c.	PREDATOR
80-265-19	15 @ 7.7" o.c.	12 @ 6.9" o.c.	SUNLINE ULTRA
80-265-18	23 @ 5.4" o.c.	14 @ 5.8" o.c.	SUNLINE MAGNA

FOUR INCHES FROM EACH CORNER EVENLY SPACED.


WIND LOAD ROOF ANCHORAGE DETAIL

Meets wind requirements for the following codes:
FBC 2017
based on ASCE 7-10.

Wind:

190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max

CONCRETE ATTACHMENT



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D ROD IN HIT-IT HIT-HY 200 EPOXY, 4" MIN. EMBED INTO CONCRETE.


- NORMAL WEIGHT CONC SLAB
- f_c=4000 PSI MIN
- 6" MIN THICK CONC.
- SPECIAL INSPECTION REQUIRED (ESR-3187)

NO. OF ANCHORAGE BOLTS REQUIRED


CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE *	
80-265-49	5 @ 8.6" o.c.	4 @ 6.3" o.c.	LXS
80-265-50	5 @ 8.6" o.c.	5 @ 7.25" o.c.	LXL
80-265-13	9 @ 7.63" o.c.	6 @ 5.1" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 11.7" o.c.	4 @ 9.4" o.c.	PRESTIGE SMALL
80-265-46	6 @ 14.4" o.c.	5 @ 10.25" o.c.	PRESTIGE LARGE
80-265-29	15 @ 4.63" o.c.	10 @ 4.4" o.c.	PREDATOR
80-265-19	15 @ 7.4" o.c.	12 @ 6.5" o.c.	SUNLINE ULTRA
80-265-18	22 @ 5.4" o.c.	17 @ 4.5" o.c.	SUNLINE MAGNA

STEEL AND CONCRETE ANCHORS ARE 6" FROM EACH CORNER EVENLY SPACED

CONCRETE OVER METAL DECK



NOTE: FOR CONC OVER METAL DECK OVER STEEL FRAMING USE STEEL ATTACHMENT



SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

1625 DIPLOMAT DRIVE
CARROLLTON, TX 75006
PHONE (972) 247-7447
FAX (972) 243-0940

FORM NO:
CB-25A

DATE: 01/07/19
REV: 1
DRAWN BY: FMM

RRS ROOFTOP SYSTEMS

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-25A.

Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)



**CALCULATED WIND
ROOF CURBS FOR YORK UNITS**

P*A ALL MODELS**



ProVent P/N	A	WEIGHT
80-265-4914	14"	129 Lbs
80-265-4918	18"	153 Lbs

Meets wind requirements for the following codes:
FBC 2017
based on ASCE 7-10.


Wind:
190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max




INTERIOR CURB SUPPORT




HOLD DOWN DETAIL



STUD STIFFENER



**CORNER &
END CLIP DETAIL**



1625 DIPLOMAT DRIVE
CARROLLTON, TX 75006
PHONE (972) 247-7447
FAX (972) 243-0940



SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBKD-160A

DATE:
01/07/19

REV:
1

PART NUMBER:
80-265-49

DRAWN BY:
FMM



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____


Client: ProVent PV1807
Description: 80-265-49**
Unit: York LX Series [Small Chassis] Rooftop Equipment

Curb Information

Hcurb = 18 in (Height of curb)
Lcurb = 46.5 in (Length of curb)
wcurb = 31 in (Width of curb)
WGTCurb = 153 lbs (Weight of curb)

Unit Information

WGTUnit = 367 lbs (Weight of Unit)
Wtmax = 120 lbs (Maximum corner weight)
Wtmin = 71 lbs (Minimum corner weight)
Hunit = 49 in (Height of unit above curb)
Hcm = 24.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 35.75 in (Width of unit)



Seismic Loading - 2017 FBC/2015 IBC

Ss = 0.15 (Worst Case for state of Florida)
Fa = 2.5 (Worst case Site class E from Table 11.4-1 ASCE 7-10)
Sms = 0.375 (Fa*Ss)
Sds = 0.250 (2/3*Sms)
Ip = 1.5 (Importance Factor Category III or IV Building)
Fpmax = 0.6000 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 154 lbs (0.7*Fpmax)
FpmaxASD = 218 lbs (unit and curb)

Wind Loading - 2017 FBC/2015 IBC

*** Exposure Category D ***

Kz = 1.31 (For 60 ft roof height, Exposure D - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 190 (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat D)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 102.9 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 2797 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1951 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 1178 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 370 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 163 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTUnit
Compression_{WIND} = 1766 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 2724 lbs = Comp_{WIND}+Fvert-0.6*WGTUnit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 330 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 122 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTUnit
Compression_{WIND} = 583 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 1541 lbs = Comp_{WIND}+Fvert-0.6*WGTUnit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1766 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2724 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 583 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1541 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 18.000 in a = 17.644 in = A' - (2r + t)
B' = 2.000 in a' = 17.929 in = A' - t
C' = 0.000 in [0 if no lips] b = 1.822 in = B' - [r + t/2 + a(r + t/2)]
α = 0.000 [0 - no Lip; 1 w/ lip] b' = 1.964 in = B' - (t/2 + αt/2)
R = 0.1069 [Inside bend radius] c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R + t/2 u = 0.224 in = πr/2
x = 0.178 in [Distance between centroid and web centerline]
I_x = 56.073 in⁴ [Moment of Inertia about X-Axis]
I_y = 0.311 in⁴ [Moment of Inertia about Y-Axis]
A = 1.55 in²
r_x = 6.02 in
r_y = 0.448 in
r_{min} = 0.448 in



Axial Compression

P_u = 1.399 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 24.287 k
F_e = 36.56 ksi If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 1.17 If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 28.21 ksi Lateral unbraced length
L_y = 50 in [assume k=0.8]
k_yL_y/r_y = 89

Compression Check = **O.K.**

Check Web Crippling

h = 18 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 252.45 ≤ 200 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.388889 ≤ 2.0 C_h = 0.02
P_n = 2.296 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.312 k
Long side: P_{uTrans} = 1.766 k **web stiffener REQ'D** # clips = 1
Short side: P_{uLong} = 0.583 k **O.K.** # clips = 1
***h/t > 200; use web stiffeners

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28√E/F_y = 31.091 → w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 2.296 k P_n/Ω = 8.773 k
P_n = 14.913 k
O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4"-20-UNC Threaded inserts
T_{crnmax} = 699 lbs Max[F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections]
V_{crnmax} = 1362 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 1.2
of Bolts Used = 2.0
***If combined fails:
Check Combined Stress in Bolts & Inserts: 0.762 **O.K.** USE → 3.0
StressComb = 0.508 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 0.921 in



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

Connection Unit to Curb Clip

#12 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.216$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

$P_{ns} = 2703$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2703$ #

Shear:

$P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

4.12 k

$P_{ns} = 2.7t_1dF_{u1}$

2.70 k

$P_{ns} = 2.7t_2dF_{u2}$

3.86 k

$P_{ns} = 2.7t_2dF_{u2}$

3.86 k

$P_{ns}/\Omega = 901$ #

$P_{ss}/\Omega = 840$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension:

$P_{not} = 1.214$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 405$ # <- Controls

$P_{ts}/\Omega = 845$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.797	1	2.80	840 #	4	2.00 in
Short side:	1.951	1	1.95	840 #	3	3.00 in

clip width (in) = 7.00

clip height = 2.5 in

min spacing = 0.65 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.410$ in²


$A_{nt} = 0.081$ in²

$R_n/\Omega = 8.647$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

BSR O.K.

(AISI Sect. E5.3)



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX}	4268 lbs	Shear _{MAX}	1399 lbs
-------------	-----------------------	----------	----------------------	----------

Compression_{SEISMIC} = 569 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 275 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression_{WIND} = 3402 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$

Tension_{WIND} = 4268 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$

Longitudinal:	Uplift _{MAX}	2217 lbs	Shear _{MAX}	976 lbs
---------------	-----------------------	----------	----------------------	---------

Compression_{SEISMIC} = 469 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 175 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression_{WIND} = 1350 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$

Tension_{WIND} = 2217 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: Use 5/8" ϕ wood lag screws w/ 3.5" Min. Embed

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Transverse: Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 4.51

COMBINED LOADING: 0.987 O.K.

of Screws Req'd for Shear = 1.37

Screw Spacing = 9.6 in o.c.

Total # of screws Required = 5

Use 5/8" ϕ wood lag screws @ 9.6 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 2.3

COMBINED LOADING: 0.935 O.K.

of Screws Req'd for Shear = 1.0

Screw Spacing = 11.5 in o.c.

Total # of screws Required = 3

Use 5/8" ϕ wood lag screws @ 11.5 in o.c. along short side of curb

Steel Deck Attachment: Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

Transverse: Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

of Bolts Req'd for Uplift = 0.62

COMBINED LOADING: 0.204 O.K.

of Bolts Req'd for Shear = 0.38

Bolt Spacing = 34.5 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 34.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.32

COMBINED LOADING: 0.082 O.K.

of Bolts Req'd for Shear = 0.27

Req'd Min Spacing = 19.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 19 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$T_{all,LRFD} = 1722 \text{ lbs} \quad V_{all,LRFD} = 2032 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

$$\text{Transverse: } Uplift_{MAX} = 4268 \text{ lbs} \quad Shear_{MAX} = 1399 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 1018 \text{ lbs} = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 724 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14S_{DS}] * [WGT_{unit+curb}]$$

$$\text{Shear}_{SEISMIC} = 273 \text{ lbs} = 2.5 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 4.64 \text{ spacing} = 5.63 \text{ in o.c.} \quad T_{applied} = 853.7 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 22.5 \text{ in o.c.} \quad V_{applied} = 279.7 \text{ lbs}$$

Try using 5 bolts
spaced at 8.63 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18$$

Use 5 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 8.6 in o.c. max. along long side of curb w/ 4" embed

$$\text{Longitudinal: } Uplift_{MAX} = 2217 \text{ lbs} \quad Shear_{MAX} = 1399 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 768 \text{ lbs} = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 474 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14S_{DS}] * [WGT_{unit+curb}]$$

$$\text{Shear}_{SEISMIC} = 273 \text{ lbs} = 2.5 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.41 \text{ spacing} = 3.5 \text{ in o.c.} \quad T_{applied} = 554.2 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 7 \text{ in o.c.} \quad V_{applied} = 349.7 \text{ lbs}$$

Try using 4 bolts
spaced at 6.33 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.92$$

Use 4 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 6.3 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: 80-265-49**			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 3 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD 5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	STEEL 5/8" ϕ A307 bolts	CONCRETE 3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	5 @ 9.63 in o.c.	2 @ 34.5 in o.c.	5 @ 8.63 in o.c.
SHORT DIRECTION	3 @ 11.5 in o.c.	2 @ 19 in o.c.	4 @ 6.33 in o.c.