



MOUR GROUP
ENGINEERING + DESIGN

Wind Calculations
for
York CDR Prestige Series (Large Chassis)
Rooftop Equipment

Kit #80-265-46**
2017 Florida Building Code requirements




Prepared for:

PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: January 25, 2019
Project Number: PV1807

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



STEEL ANGLE BY OTHERS

CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE *	
80-265-49	2 @ 34.5" o.c.	2 @ 19" o.c.	LXS
80-265-50	2 @ 34.5" o.c.	2 @ 29" o.c.	LXL
80-265-13	2 @ 61" o.c.	2 @ 25.3" o.c.	SUNLINE 3-6 TON
80-265-45	2 @ 58.4" o.c.	2 @ 28.2" o.c.	PRESTIGE SMALL
80-265-46	2 @ 72" o.c.	2 @ 41" o.c.	PRESTIGE LARGE
80-265-29	3 @ 34.7" o.c.	2 @ 39.5" o.c.	PREDATOR
80-265-19	3 @ 51.6" o.c.	2 @ 72" o.c.	SUNLINE ULTRA
80-265-18	4 @ 38.1" o.c.	3 @ 36" o.c.	SUNLINE MAGNA

WOOD ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø WOOD LAG SCREWS (3.5" MIN. EMBED. INTO WOOD FRAMING)



CURB KIT	NO. OF ANCHORAGE SCREWS REQUIRED		UNIT
	LONG SIDE	SHORT SIDE	
80-265-49	5 @ 9.6" o.c.	3 @ 11.5" o.c.	LXS
80-265-50	5 @ 9.6" o.c.	5 @ 8.3" o.c.	LXL
80-265-13	8 @ 9.3" o.c.	4 @ 9.8" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 12.5" o.c.	3 @ 16.1" o.c.	PRESTIGE SMALL
80-265-46	6 @ 15.2" o.c.	4 @ 15" o.c.	PRESTIGE LARGE
80-265-29	14 @ 5.6" o.c.	7 @ 7.3" o.c.	PREDATOR
80-265-19	15 @ 7.7" o.c.	12 @ 6.9" o.c.	SUNLINE ULTRA
80-265-18	23 @ 5.4" o.c.	14 @ 5.8" o.c.	SUNLINE MAGNA

FOUR INCHES FROM EACH CORNER EVENLY SPACED.

WIND LOAD ROOF ANCHORAGE DETAIL

Meets wind requirements for the following codes:
FBC 2017
based on ASCE 7-10.

Wind:

190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max

CONCRETE ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THROD ROD IN HILTI HIT-HY 200 EPOXY, 4" MIN. EMBED INTO CONCRETE.




- NORMAL WEIGHT CONC SLAB
- f_c=4000 PSI MIN
- 6" MIN THICK CONC.
- SPECIAL INSPECTION REQUIRED (ESR-3187)

NO. OF ANCHORAGE BOLTS REQUIRED


CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE **	
80-265-49	5 @ 8.6" o.c.	4 @ 6.3" o.c.	LXS
80-265-50	5 @ 8.6" o.c.	5 @ 7.25" o.c.	LXL
80-265-13	9 @ 7.63" o.c.	6 @ 5.1" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 11.7" o.c.	4 @ 9.4" o.c.	PRESTIGE SMALL
80-265-46	6 @ 14.4" o.c.	5 @ 10.25" o.c.	PRESTIGE LARGE
80-265-29	16 @ 4.63" o.c.	10 @ 4.4" o.c.	PREDATOR
80-265-19	15 @ 7.4" o.c.	12 @ 6.5" o.c.	SUNLINE ULTRA
80-265-18	22 @ 5.4" o.c.	17 @ 4.5" o.c.	SUNLINE MAGNA

STEEL AND CONCRETE ANCHORS ARE 6" FROM EACH CORNER EVENLY SPACED

CONCRETE OVER METAL DECK



NOTE: FOR CONC OVER METAL DECK OVER STEEL FRAMING USE STEEL ATTACHMENT



SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

1625 DIPLOMAT DRIVE
CARROLLTON, TX 75006
PHONE (972) 247-7447
FAX (972) 243-0940

RRS ROOFTOP SYSTEMS

FORM NO:
CB-25A

DATE: 01/07/19
REV: 1
DRAWN BY: FMM

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-25A.

Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)


CALCULATED WIND ROOF CURBS FOR YORK UNITS

ZX 08-14, XX 08-12
ZY 07-12, XY 07-09

ProVent P/N	A	WEIGHT
80-265-4614	14"	136 Lbs
80-265-4618	18"	160 Lbs

Meets wind requirements for the following codes:
FBC 2017
based on ASCE 7-10.

Wind:
190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max



RRS ROOFTOP SYSTEMS	SUBMITTED TO: COMPANY: 1625 DIPLOMAT DRIVE CARROLTON, TX 75006 JOB NAME: PHONE (972) 247-7447 EQUIPMENT: FAX (972) 243-0940 NOTES:	FORM NO: CBKD-163A	PART NUMBER: 80-265-46
	DATE: 01/23/19	REV: 2	DRAWN BY: ALL




Client: ProVent PV1807
Description: 80-265-46**
Unit: York CDR Prestige Series (Large Chassis) Rooftop Equipment

Curb Information

Hcurb = 18 in (Height of curb)
Lcurb = 84 in (Length of curb)
wcurb = 53 in (Width of curb)
WGTcurb = 160 lbs (Weight of curb)

Unit Information

WGTunit = 1008 lbs (Weight of Unit)
Wtmax = 213 lbs (Maximum corner weight)
Wtmin = 154 lbs (Minimum corner weight)
Hunit = 40.56 in (Height of unit above curb)
Hcm = 20.28 in (Height to center of mass)
Lunit = 87.1875 in (Length of unit)
Wunit = 61.69 in (Width of unit)



Seismic Loading - 2017 FBC/2015 IBC

Ss = 0.15 (Worst Case for state of Florida)
Fa = 2.5 (Worst case Site class E from Table 11.4-1 ASCE 7-10)
Sms = 0.375 (Fa*Ss)
Sds = 0.250 (2/3*Sms)
Ip = 1.5 (Importance Factor Category III or IV Building)
Fpmax = 0.6000 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 423 lbs (0.7*Fpmax)
FpmaxASD = 491 lbs (unit and curb)

Wind Loading - 2017 FBC/2015 IBC

*** Exposure Category D ***

Kz = 1.31 (For 60 ft roof height, Exposure D - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 190 (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat D)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 102.9 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 4159 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 2943 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 3459 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 603 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 33 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 118 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 2972 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 543 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = -26 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = -764 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 2091 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 603 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2972 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 543 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2091 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



MOUR GROUP

ENGINEERING + DESIGN


6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ___ of ___

Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.644 in = A' - (2r+t)
B' = 3.000 in	a' = 17.929 in = A' - t
C' = 1.000 in [0 if no lips]	b = 2.644 in = B' - [r+t/2 + a(r+t/2)]
o = 1.000 [0 - no Lip; 1 w/ lip]	b' = 2.929 in = B' - [t/2 + at/2]
R = 0.1069 (Inside bend radius)	c = 0.822 in = o[C' - (r+t/2)]
t = 0.0713 in	c' = 0.964 in = o[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = $\pi r/2$
x = 0.544 in (Distance between centroid and web centerline)	
Ix = 76.324 in (Moment of Inertia about X-Axis)	
Iy = 1.759 in (Moment of Inertia about Y-Axis)	
A = 1.82 in ²	
rx = 6.48 in	
ry = 0.984 in	
rmin = 0.984 in	



Axial Compression

Pu = 2.080 k	(Max Axial Comp)	$\Omega_c = 1.80$
Pn/ Ω_c = 36.083 k		
Fe = 62.46 ksi		
$\lambda_c = 0.89$		
Fu = 35.76 ksi		
Ly = 84 in		
KyLy/r _y = 68		

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 18 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 252.45 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
$\Omega_w = 1.75$	N/h = 0.388889 ≤ 2.0	C _h = 0.02	
P _n = 2.296 k	R/t = 1.50 ≤ 9.0		
P _n / Ω_w = 1.312 k			
Long side: Pu _{Trans} = 0.301 k	O.K. # clips = 2	$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: Pu _{Long} = 0.543 k	O.K. # clips = 1		

***h/t > 200; use web stiffeners

Check Web Stiffener

width of stiffener = 7.000 in	16Ga x 3/4" x 7" (C-channel)	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in		Rs = 0.0849 in
***Check w/ts ≤ 1.28vE/Fys		$\Omega_c = 1.70$
w/ts = 118.675		
1.28vE/Fys = 31.091	--> w/ts over limit Use C3.7.2	
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}		
P _{wc} = 2.296 k	A _e = 0.380 in ²	
P _n = 14.913 k	P _n / Ω = 8.773 k	

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1040 lbs	Max[F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections]
Vcrnmax = 1486 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.4	
# of Bolts required for Shear = 1.4	
# of Bolts Used = 2.0	
Check Combined Stress in Bolts & Inserts: 0.888 O.K.	StressComb = 0.592 O.K.

***If combined fails:
USE --> 3.0

Check 1/8" welded connection

Assume L/t > 25: 25*t = 1.783 in	<--- USE WELD	$\Omega = 2.35$
Lreq'd = 1.005 in	$P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$	$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

Connection Unit to Curb Clip

#12 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.216$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2703$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2703$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.70 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.70 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.86 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.86 k

$P_{ns}/\Omega = 901$ #

$P_{ss}/\Omega = 840$ # <- Controls

Tension: $P_{not} = 1.214$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 405$ # <- Controls

$P_{ts}/\Omega = 845$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.159	2	2.08	840 #	3	3.00 in
Short side:	2.943	1	2.94	840 #	4	2.00 in

clip width (in) = 7.00

clip height = 2.5 in

min spacing = 0.65 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.410$ in²


$A_{nt} = 0.081$ in²

$R_n/\Omega = 8.647$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX}	4383 lbs	Shear _{MAX}	2080 lbs
Compression _{SEISMIC}	959 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$		
Tension _{SEISMIC}	299 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	1625 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$		
Tension _{WIND}	4383 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$		
Longitudinal:	Uplift _{MAX}	2720 lbs	Shear _{MAX}	1472 lbs
Compression _{SEISMIC}	828 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$		
Tension _{SEISMIC}	168 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	-38 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$		
Tension _{WIND}	2720 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$		

Wood Attachment: Use 5/8" ϕ wood lag screws w/ 3.5" Min. Embed

Tall_{metal} = 946.67 lbs Vall_{metal} = 1043.33 lbs

Tall_{wood} = 1195.95 lbs Vall_{wood} = 1024 lbs

Transverse:

of Screws Req'd for Uplift = 4.63

of Screws Req'd for Shear = 2.03

Total # of screws Required = 6

COMBINED LOADING: 0.949 O.K.

Screw Spacing = 15.2 in o.c.

Use 5/8" ϕ wood lag screws @ 15.2 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 2.9

of Screws Req'd for Shear = 1.4

Total # of screws Required = 4

COMBINED LOADING: 0.928 O.K.

Screw Spacing = 15.0 in o.c.

Use 5/8" ϕ wood lag screws @ 15 in o.c. along short side of curb

Steel Deck Attachment: Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolt} = 6903 lbs Vall_{bolt} = 3682 lbs

Transverse:

of Bolts Req'd for Uplift = 0.64

of Bolts Req'd for Shear = 0.56

Total # of Bolts Required = 2

COMBINED LOADING: 0.269 O.K.

Bolt Spacing = 72.0 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.39

of Bolts Req'd for Shear = 0.40

Total # of Bolts Required = 2

COMBINED LOADING: 0.135 O.K.

Req'd Min Spacing = 41.0 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 41 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$T_{all,LRFD} = 1722 \text{ lbs} \quad V_{all,LRFD} = 2032 \text{ lbs} \quad \alpha = (1 + 0.2S_{DS})D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

Transverse:	Uplift _{MAX} = 4383 lbs	Shear _{MAX} = 2080 lbs
-------------	----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 1490 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 830 \text{ lbs} = \text{Comp}_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 613 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 4.76 \text{ spacing} = 15.00 \text{ in o.c.} \quad T_{applied} = 730.6 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 60 \text{ in o.c.} \quad V_{applied} = 346.6 \text{ lbs}$$

Try using	6 bolts
spaced at	14.40 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.11$$

Use 6 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 14.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal:	Uplift _{MAX} = 2720 lbs	Shear _{MAX} = 2080 lbs
---------------	----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 1163 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 503 \text{ lbs} = \text{Comp}_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 613 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.95 \text{ spacing} = 14.5 \text{ in o.c.} \quad T_{applied} = 680.1 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 29 \text{ in o.c.} \quad V_{applied} = 519.9 \text{ lbs}$$

Try using	4 bolts
spaced at	13.67 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.22$$

Use 4 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 13.7 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: 80-265-46**			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 3 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
	6 @ 15.2 in o.c.	2 @ 72 in o.c.	6 @ 14.4 in o.c.
LONG DIRECTION	6 @ 15.2 in o.c.	2 @ 72 in o.c.	6 @ 14.4 in o.c.
SHORT DIRECTION	4 @ 15 in o.c.	2 @ 41 in o.c.	4 @ 13.67 in o.c.