



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBWC-300 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.

FEATURES


- Roof curb sides and ends are 16 Ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Pitched curbs and taller curbs are available.

Notes


Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS


ZX 04-07
ZY, ZQ, XY 04-06




ATTACH TO CURB WITH
(5) #12X 3/4" @ 3 O.C. TEK SCREW,
EACH SIDE (LONG SIDE)
(3) #10X 3/4" @ 3 O.C. TEK SCREW
EACH SIDE (SHORT SIDE)



HOLD DOWN DETAIL




CURB DETAIL



DETAIL B

PROVENT P/N	A	EST. WEIGHT
CBWCPRS08	8"	125 Lbs.
CBWCPRS11	11"	136 Lbs.
CBWCPRS14	14	147 Lbs.
CBWCPRS24	24"	186 Lbs.

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBWC-300


DATE:
9/27/2018

PART NUMBER:
CBWCPRS SERIES

REV:
6

DRAWN BY:
ALL

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBWC-300 (CBWCPRS**)
Unit: ZX 04-07; ZY, ZQ, XY 04-06

Curb Information

Hcurb = 24 in (Height of curb)
Lcurb = 70.375 in (Length of curb)
wcurb = 40.1875 in (Width of curb)
WGTcurb = 186 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 711 lbs (Weight of Unit)
Wtmax = 181 lbs (Maximum corner weight)
Wtmin = 142 lbs (Minimum corner weight)
Hunit = 40.56 in (Height of unit above curb)
Hcm = 20.28 in (Height to center of mass)
Lunit = 74.05 in (Length of unit)
Wunit = 48.88 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category U)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1891 lbs (0.7*Fpmax) FpmaxASD = 2386 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh, ASD trans = 1231 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh, ASD long = 812 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert, ASD = 736 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1413 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1175 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 470 lbs = [Fh, transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 779 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:


Compression_{SEISMIC} = 1003 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 766 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 83 lbs = [Fh, transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 393 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1413 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1175 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1003 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 766 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0566$ 16 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 24.000$ in $a = 23.717$ in $= A' - (2r + t)$
 $B' = 3.000$ in $a' = 23.943$ in $= A' - t$
 $C' = 1.000$ in [0 if no lips] $b = 2.717$ in $= B' - (r + t/2 + a(r + t/2))$
 $d = 1.000$ in [0 - no Lip; 1 w/ lip] $b' = 2.943$ in $= B' - (t/2 + at/2)$
 $R = 0.0849$ [Inside bend radius] $c = 0.859$ in $= a[C' - (r + t/2)]$
 $t = 0.0566$ in $c' = 0.972$ in $= a[C' - t/2]$
 $r' = 0.113$ in $= R + t/2$ $u = 0.178$ in $= \pi r/2$
 $x = 0.446$ in [Distance between centroid and web centerline]
 $I_x = 125.486$ in [Moment of Inertia about X-Axis]
 $I_y = 1.511$ in [Moment of Inertia about Y-Axis]
 $A = 1.79$ in²
 $r_x = 8.38$ in
 $r_y = 0.919$ in
 $r_{min} = 0.919$ in



Axial Compression

$P_u = 0.946$ k [Max Axial Comp] $\Omega_c = 1.80$
 $P_n/\Omega_c = 33.817$ k
 $F_e = 54.49$ ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
 $\lambda_c = 0.96$ $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$ $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
 $F_n = 34.06$ ksi
 $L_y = 84$ in Lateral unbraced length
 $k_y L_y/r_y = 73$ (assume $k=0.8$)

Compression Check = O.K.

Check Web Crippling

$h = 24$ in -- Check limits: $C = 4.00$
 $t = 0.0566$ in $h/t = 424.03 \leq 200$ $C_R = 0.14$
 $N = 7.00$ $N/t = 123.67 \leq 210$ $C_N = 0.35$
 $\Omega_w = 1.75$ $N/h = 0.291667 \leq 2.0$ $C_n = 0.02$ [See table C3.4.1-2, fastened to support, one flange, end loading]
 $P_n = 1.366$ k $R/t = 1.50 \leq 9.0$
 $P_n/\Omega_w = 0.780$ k
Long side: $P_{u,trans} = 0.706$ k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_n \sqrt{\frac{h}{t}} \right)$
Short side: $P_{u,Long} = 1.003$ k **O.K.** # clips = 2
web stiffener REQ'D # clips = 1
*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in $t_s = 0.0566$ 16 Gauge
web of stiff. $w = 6.717$ in $R_s = 0.0849$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_s F_y) \geq P_{wc}$
 $P_{wc} = 1.366$ k $A_e = 0.380$ in²
 $P_n = 14.262$ k $P_n/\Omega = 8.390$ k
O.K.

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded Inserts
 $T_{crnmax} = 473$ lbs $\text{Max}(F_{pmASD}/4 - \text{OR} - F_{HASDtrans}/4 \text{ corner connections})$
 $V_{crnmax} = 588$ lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.5
of Bolts Used = 1.0
***If combined fails: USE --> 2.0
Check Combined Stress in Bolts & Inserts: 0.727 **O.K.** StressComb = 0.363 **O.K.**

Check 1/8" welded connection

Assume $L/t > 25$: $25^*t = 1.415$ in $\Omega = 2.35$
 $L_{req'd} = 0.500$ in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{nov} = 2.069$ k (screw pull-over strength)

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.891	2	0.95	540 #	2	6.00 in
Short side:	1.891	1	1.89	540 #	4	2.00 in

clip width (in) = 7.00

min spacing = 0.57 in

clip height = 1.4 in

edge distance = 0.5 in (min. 1.5d)

thinnest part = 0.0566 AISI BSR applies

Check Block shear rupture: 0.K.

$F_y = 50$ ksi


$A_{gv} = 0.368$ in²

$R_n/\Omega = 5.954$ k

BSR O.K.

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX}	2897 lbs	Shear _{MAX}	1193 lbs
Compression _{SEISMIC}	3197 lbs	= [F _{pmaxASD} * (H _{cm} + H _{curb}) + (1 + 0.14S _{DS}) * (W _{GT} * unit + curb) / 2] * w _{curb} / w _{curb}		
Tension _{SEISMIC}	2897 lbs	= Comp _{SEISMIC} - (0.6 - 0.14S _{DS}) * (W _{GT} * unit + curb)		
Compression _{WIND}	1257 lbs	= [F _{htransASD} * (H _{cm} + H _{curb}) + 0.6 * (W _{GT} * unit + curb) / 2] * w _{curb} - F _{vertASD} * w _{curb} / 2 / w _{curb}		
Tension _{WIND}	1455 lbs	= [F _{htransASD} * (H _{cm} + H _{curb}) - 0.6 * (W _{GT} * unit + curb) / 2] * w _{curb} + F _{vertASD} * w _{curb} / 2 / w _{curb}		
Longitudinal:	Uplift _{MAX}	1769 lbs	Shear _{MAX}	1193 lbs
Compression _{SEISMIC}	2069 lbs	= [F _{pmaxASD} * (H _{cm} + H _{curb}) + (1 + 0.14S _{DS}) * (W _{GT} * unit + curb) / 2] * L _{curb} / L _{curb}		
Tension _{SEISMIC}	1769 lbs	= Comp _{SEISMIC} - (0.6 - 0.14S _{DS}) * (W _{GT} * unit + curb)		
Compression _{WIND}	412 lbs	= [F _{htransASD} * (H _{cm} + H _{curb}) + 0.6 * (W _{GT} * unit + curb) / 2] * L _{curb} - F _{vertASD} * L _{curb} / 2 / L _{curb}		
Tension _{WIND}	610 lbs	= [F _{htransASD} * (H _{cm} + H _{curb}) - 0.6 * (W _{GT} * unit + curb) / 2] * L _{curb} + F _{vertASD} * L _{curb} / 2 / L _{curb}		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Transverse: Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 3.06

of Screws Req'd for Shear = 1.17

Total # of screws Required = 4

COMBINED LOADING: 0.562 O.K.

Screw Spacing = 20.8 in o.c.

Use 5/8" ϕ wood lag screws @ 20.8 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 1.9

COMBINED LOADING: 0.515 O.K.

of Screws Req'd for Shear = 1.2

Screw Spacing = 16.1 in o.c.

Total # of screws Required = 3

Use 5/8" ϕ wood lag screws @ 16.1 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Transverse: Tall_{bolts} = 6903 lbs

Vall_{bolts} = 3682 lbs

of Bolts Req'd for Uplift = 0.42

COMBINED LOADING: 0.122 O.K.

of Bolts Req'd for Shear = 0.32

Bolt Spacing = 58.4 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 58.4 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.26

COMBINED LOADING: 0.081 O.K.

of Bolts Req'd for Shear = 0.32

Req'd Min Spacing = 28.2 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 28.2 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

(619)727-4800

Page ____ of ____

For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7Q_o E$ ($Q_o = 2.5$)

Concrete Attachment: $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors w/ $4"$ embed

$$T_{all,LRFD} = 1722 \text{ lbs} \quad V_{all,LRFD} = 2032 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

$$\text{Transverse: } Uplift_{MAX} = 6841 \text{ lbs} \quad Shear_{MAX} = 2983 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 7140 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{UNIT+CURB}/2) \cdot w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 6841 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{UNIT+CURB})$$

$$\text{Shear}_{SEISMIC} = 2983 \text{ lbs} = 2.5 \cdot F_{pmaxASD}/2$$

$$\text{Min Bolts Req'd Uplift} = 7.43 \text{ spacing} = 6.63 \text{ in o.c.} \quad T_{applied} = 760.1 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.74 \text{ spacing} = 23.1875 \text{ in o.c.} \quad V_{applied} = 331.4 \text{ lbs}$$

Try using 9 bolts
spaced at 7.30 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.13$$

Use 9 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 7.3 in o.c. max. along long side of curb w/ $4"$ embed

$$\text{Longitudinal: } Uplift_{MAX} = 4021 \text{ lbs} \quad Shear_{MAX} = 2983 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 4321 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{UNIT+CURB}/2) \cdot L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 4021 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{UNIT+CURB})$$

$$\text{Shear}_{SEISMIC} = 2983 \text{ lbs} = 2.5 \cdot F_{pmaxASD}/2$$

$$\text{Min Bolts Req'd Uplift} = 4.37 \text{ spacing} = 4.046875 \text{ in o.c.} \quad T_{applied} = 574.5 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.74 \text{ spacing} = 8.09375 \text{ in o.c.} \quad V_{applied} = 426.1 \text{ lbs}$$

Try using 7 bolts
spaced at 4.70 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.02$$

Use 7 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 4.7 in o.c. max. along short side of curb w/ $4"$ embed

CURB DESIGN SUMMARY: CBWC-300			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x $3/4"$ x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x $3/4"$ x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 2 - $1/4"$ ϕ SAE Grade 8 bolts w/ $1/4$ -20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	$5/8"$ ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	$5/8"$ ϕ A307 bolts	$3/4"$ ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 20.79 in o.c.	2 @ 58.38 in o.c.	9 @ 7.3 in o.c.
SHORT DIRECTION	3 @ 16.09 in o.c.	2 @ 28.19 in o.c.	7 @ 4.7 in o.c.