



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBWC-300 Series
CBWCPRS



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: October 11, 2021

Project Number: PV2101

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS

PROVENT P/N	A	EST. WEIGHT
CBWCPRS08	8"	128 Lbs.
CBWCPRS11	11"	139 Lbs.
CBWCPRS14	14"	150 Lbs.
CBWCPRS24	24"	189 Lbs.



ZX 04-07, XX A7,
ZXA7, ZY, ZQ, XY, XQ, ZL 04-06

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018


- FEATURES**
- Roof curb sides and ends are 16 Ga. galvanized steel.
 - Gasketing package provided.
 - Heat treated wood nailer provided.
 - Pitched curbs and taller curbs are available.

Notes


Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.




B




HOLD DOWN DETAIL



CURB DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799


SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-300
DATE:
10/7/2021

PART NUMBER:
CBWCPRS SERIES
REV:
9
DRAWN BY:
ALL

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" (OR 5/8" FOR MIL SERIES ONLY) Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 39" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SLU180	3 @ 51.38" O.C.	2 @ 71.5" O.C.
SLM1830	3 @ 56.88" O.C.	3 @ 35.75" O.C.

ASSUMES:

CONC SLAB
f_c= 4000PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 11.5" O.C.	3 @ 9.5" O.C.
LXL	4 @ 11.5" O.C.	3 @ 14.5" O.C.
SUN3672	4 @ 20.17" O.C.	3 @ 12.38" O.C.
PRD3715	9 @ 8.61" O.C.	7 @ 6.5" O.C.
PRS	5 @ 14.72" O.C.	4 @ 9.56" O.C.
PRL	6 @ 14.4" O.C.	5 @ 10.38" O.C.
SLU180	8 @ 14.68" O.C.	7 @ 11.92" O.C.
SLM1830	12 @ 10.34" O.C.	10 @ 7.94" O.C.

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018


ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SLU180	SLU180
SLM1830	SLM1830

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø SIMPSON SDS OR EQUIVALENT SCREWS (3 1/2" MIN. EMBED. INTO WOOD FRAMING)

5/8" Ø LAG SCREW W/MIN. 3.5" EMBED (SGMIN=0.43) (FOR MIL SERIES ONLY)

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	9 @ 9.11" O.C.	8 @ 6.14" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.34" O.C.
PRL	5 @ 19" O.C.	4 @ 15.17" O.C.
SLU180	9 @ 13.34" O.C.	7 @ 12.58" O.C.
SLM1830	13 @ 9.81" O.C.	12 @ 6.86" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
10/07/2021

REV:
7

DRAWN BY:
FMM




Client:	ProVent PV2101	Previous:	PV1806
Description:	CBWC-300	CBWCPRS	
Unit:	ZX 04-07; XX A7; ZX A7; ZY, ZQ, XY, XQ, ZL 04-06		

Curb Information

Hcurb =	24 in	(Height of curb)
Lcurb =	70.875 in	(Length of curb)
wcurb =	40.6875 in	(Width of curb)
WGTCurb =	186 lbs	(Weight of curb)
# Clips long side =	2	# Clips short side = 1

Unit Information

WGTunit =	711 lbs	(Weight of Unit)
Wtmax =	181 lbs	(Maximum corner weight)
Wtmin =	142 lbs	(Minimum corner weight)
Hunit =	40.56 in	(Height of unit above curb)
Hcm =	20.28 in	(Height to center of mass)
Lunit =	74.05 in	(Length of unit)
Wunit =	48.88 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.2	Default Site Class D
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Ip =	1.50	(Importance Factor Category III Building)
Fpmax =	1.710 Wp	(0.4*Sds*Ip)*Wp*3/Rp
FpmaxASD =	851 lbs	(0.7*Fpmax)
		FpmaxASD = 1074 lbs (unit and curb)

Wind Loading - 2018 IBC/2019 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
F _h ASD trans =	1231 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _h ASD long =	812 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert} ASD =	736 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	902 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	702 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	463 lbs	= [F _h trans ASD *Hcm+2*0.6*Wtmax*wcurb-F _{vert} ASD *wcurb/2]/wcurb
Tension _{WIND} =	772 lbs	= Comp _{WIND} +F _{vert} -0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	721 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	521 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	82 lbs	= [F _h trans ASD *Hcm+2*0.6*Wtmax*Lcurb-F _{vert} ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	391 lbs	= Comp _{WIND} +F _{vert} -0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} =	902 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	772 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	721 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	521 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 **16 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.717 in = A' - (2r+t)
B' = 1.750 in	a' = 23.943 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.609 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.722 in = B' - (t/2+αt/2)
R = 0.0849 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0566 in	c' = 0.000 in = α[C' - t/2]
r' = 0.113 in = R+t/2	u = 0.178 in = πr/2
x = 0.109 in (Distance between centroid and web centerline)	
I _x = 91.935 in (Moment of Inertia about X-Axis)	
I _y = 0.174 in (Moment of Inertia about Y-Axis)	
A = 1.54 in ²	
r _x = 7.71 in	
r _y = 0.336 in	
r _{min} = 0.336 in	



Axial Compression

P _u = 0.615 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 7.886 k		
F _e = 10.48 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ _c ≤ 1.5; F _n = (0.658λ _c ²) F _y	λ _c = √(F _y /F _e) F _e = π ² E / (kl/r) ²
λ _c = 2.18	If λ _c > 1.5; F _n = 0.877 / λ _c ² F _y	
F _n = 9.19 ksi		
L _y = 70 in	Lateral unbraced length	
k _y L _y /r _y = 167	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 24 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0566 in	h/t = 424.03 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 123.67 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.291667 ≤ 2.0	C _h = 0.02	
P _n = 1.366 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 0.780 k			
Long side: P _{uTrans} = 0.451 k	O.K. # clips = 2	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{uLong} = 0.721 k	O.K. # clips = 1		

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/F _y	Ω _c = 1.70
w/ts = 118.675	
1.28√(E/F _y) = 31.091	--> w/ts over limit Use C3.7.2
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}	
P _{wc} = 1.366 k	A _e = 0.380 in ²
P _n = 14.262 k	P _n /Ω = 8.390 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 308 lbs	Max(F _{pmaxASD} /4 -OR- F _{HASDTrans} /4 corner connections)
V _{crnmax} = 386 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	V _{all} = 1096 lbs
Threaded Insert: Tall = 2860 lbs	V _{all} = 1714 lbs
# of Bolts required for Tension = 0.1	
# of Bolts required for Shear = 0.4	
# of Bolts Used = 1.0	***If combined fails: USE --> 2.0
Check Combined Stress in Bolts & Inserts: 0.476 O.K.	StressComb = 0.238 O.K.

Check 1/8" welded connection

---- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.415 in	P _n /Ω = 1/Ω * 0.75tL F _u ≥ V _{req}	L _{req'd} = V _{req} Ω / 0.75tF _u
L _{req'd} = 0.329 in		



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 1887$ # $P_{ns} = 3.86$ k

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ # $P_{ns} = 3.86$ k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension:

$P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.069$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.231	2	0.62	540 #	2	6.00 in
Short side:	0.851	1	0.85	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0566 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²

$A_{nv} = 0.352$ in²


$A_{nt} = 0.034$ in²

$R_n/\Omega = 5.954$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} =	1508 lbs	Shear _{MAX} =	615 lbs
Compression _{SEISMIC}	1760 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})] + [1+0.14S _{DS}]*(WGT _{unit+curb} /2)*w _{curb} /w _{curb}		
Tension _{SEISMIC}	1508 lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*(WGT _{unit+curb})		
Compression _{WIND}	1241 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})] + 0.6*(WGT _{unit+curb} /2)*w _{curb} - F _{vertASD} *w _{curb} /2/w _{curb}		
Tension _{WIND}	1438 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})] - 0.6*(WGT _{unit+curb} /2)*w _{curb} + F _{vertASD} *w _{curb} /2/w _{curb}		
Longitudinal:	Uplift _{MAX} =	1011 lbs	Shear _{MAX} =	537 lbs
Compression _{SEISMIC}	1262 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})] + [1+0.14S _{DS}]*(WGT _{unit+curb} /2)*L _{curb} /L _{curb}		
Tension _{SEISMIC}	1011 lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*(WGT _{unit+curb})		
Compression _{WIND}	409 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})] + 0.6*(WGT _{unit+curb} /2)*L _{curb} - F _{vertASD} *L _{curb} /2/L _{curb}		
Tension _{WIND}	606 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})] - 0.6*(WGT _{unit+curb} /2)*L _{curb} + F _{vertASD} *L _{curb} /2/L _{curb}		

Wood Attachment:

1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded emt (SG_{min} = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 400 lbs
	# of Screws Req'd for Uplift = 2.45	COMBINED LOADING: 0.645 O.K.
	# of Screws Req'd for Shear = 1.54	Screw Spacing = 21.0 in o.c.
	Total # of screws Required = 4	

1/4" φ x 3.5" Simpson SDS screws @ 21 in o.c. along long side of curb

Longitudinal:

	# of Screws Req'd for Uplift = 1.6	COMBINED LOADING: 0.627 O.K.
	# of Screws Req'd for Shear = 1.3	Screw Spacing = 16.3 in o.c.
	Total # of screws Required = 3	

1/4" φ x 3.5" Simpson SDS screws @ 16.3 in o.c. along short side of curb

Steel Deck Attachment:

1/2" φ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 1656 lbs	Vall _{metal} = 1756 lbs
	# of Bolts Req'd for Uplift = 0.91	COMBINED LOADING: 0.101 O.K.
	# of Bolts Req'd for Shear = 0.35	Bolt Spacing = 58.9 in o.c.
	Total # of Bolts Required = 2	

1/2" φ A307 Bolts to steel angle below deck @ 58.9 in o.c. along long side of curb

Longitudinal:

	# of Bolts Req'd for Uplift = 0.61	COMBINED LOADING: 0.182 O.K.
	# of Bolts Req'd for Shear = 0.31	Req'd Min Spacing = 28.7 in o.c.
	Total # of Bolts Required = 2	

1/2" φ A307 Bolts to steel angle below deck @ 28.7 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)

Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

Tall_{LRFD} = 1722 lbs Vall_{LRFD} = 2032 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87

Tall_{ASD} = Tall_{LRFD}/α = 920.9 lbs Vall_{ASD} = Vall_{LRFD}/α = 1086.6 lbs (D = 0.465, E = 0.535)

Transverse:	Uplift _{MAX} = 3261 lbs	Shear _{MAX} = 1342 lbs
--------------------	----------------------------------	---------------------------------

Compression_{SEISMIC} = 3513 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb

Tension_{SEISMIC} = 3261 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})

Shear_{SEISMIC} = 1342 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 3.54 spacing = 15.63 in o.c. T_{applied} = 652.2 lbs

Min Bolts Req'd Shear = 2.00 spacing = 46.875 in o.c. V_{applied} = 268.4 lbs

Try using 5 bolts spaced at 14.72 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.96$
---	--

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 14.7 in o.c. max. along long side of curb w/ 4" embed

Longitudinal:	Uplift _{MAX} = 2017 lbs	Shear _{MAX} = 1342 lbs
----------------------	----------------------------------	---------------------------------

Compression_{SEISMIC} = 2269 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb

Tension_{SEISMIC} = 2017 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})

Shear_{SEISMIC} = 1342 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 2.19 spacing = 8.34375 in o.c. T_{applied} = 504.2 lbs

Min Bolts Req'd Shear = 2.00 spacing = 16.6875 in o.c. V_{applied} = 335.5 lbs

Try using 4 bolts spaced at 9.56 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.86$
--	--

Use 4 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 9.6 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBWC-300			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 2 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ Simpson SDS screw w/ 2.25" threaded embed (SGmin=0.43)	1/2" φ A307 bolts	3/4" φ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 20.96 in o.c.	2 @ 58.88 in o.c.	5 @ 14.72 in o.c.
SHORT DIRECTION	3 @ 16.34 in o.c.	2 @ 28.69 in o.c.	4 @ 9.56 in o.c.