




MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBWC-301 Series
CBWCPRL



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: October 7, 2021
Project Number: PV2101

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS

ZX, 08-14; XX 08-12; XYA7, ZYA7
ZY 07-12; XY 07-09; ZL 08-14

PROVENT P/N	A	EST. WEIGHT
CBWCPRL08	8"	168 Lbs.
CBWCPRL11	11"	182 Lbs.
CBWCPRL14	14"	197 Lbs.
CBWCPRL24	24"	245 Lbs.



Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES


- Roof curb sides and ends are 16 Ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

Notes


- Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.
- Through the curbs utilities are available. Contact your York distributor or ProVent directly.




ATTACH TO CURB WITH
(3) # 10 x 3/4" TEK SCREWS




HOLD DOWN DETAIL



CURB DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-301

DATE:
10/7/2021


PART NUMBER:
CBWCPRL SERIES

REV:
9

DRAWN BY:
ALL

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" (OR 5/8" FOR MIL SERIES ONLY) Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 39" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SLU180	3 @ 51.38" O.C.	2 @ 71.5" O.C.
SLM1830	3 @ 56.88" O.C.	3 @ 35.75" O.C.

ASSUMES:

CONC SLAB
f_c= 4000PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 11.5" O.C.	3 @ 9.5" O.C.
LXL	4 @ 11.5" O.C.	3 @ 14.5" O.C.
SUN3672	4 @ 20.17" O.C.	3 @ 12.38" O.C.
PRD3715	9 @ 8.61" O.C.	7 @ 6.5" O.C.
PRS	5 @ 14.72" O.C.	4 @ 9.56" O.C.
PRL	6 @ 14.4" O.C.	5 @ 10.38" O.C.
SLU180	8 @ 14.68" O.C.	7 @ 11.92" O.C.
SLM1830	12 @ 10.34" O.C.	10 @ 7.94" O.C.

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018


ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SLU180	SLU180
SLM1830	SLM1830

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø SIMPSON SDS OR EQUIVALENT SCREWS (3 1/2" MIN. EMBED. INTO WOOD FRAMING)

5/8" Ø LAG SCREW W/MIN. 3.5" EMBED (SGMIN=0.43) (FOR MIL SERIES ONLY)

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	9 @ 9.11" O.C.	8 @ 6.14" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.34" O.C.
PRL	5 @ 19" O.C.	4 @ 15.17" O.C.
SLU180	9 @ 13.34" O.C.	7 @ 12.58" O.C.
SLM1830	13 @ 9.81" O.C.	12 @ 6.86" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
10/07/2021

REV:
7

DRAWN BY:
FMM




Client:	ProVent PV2101	Previous:	PV1806
Description:	CBWC-301	CBWCPRL	
Unit:	ZX, ZL 08-14; XX 08-12; XYA7, ZYA7; ZY 07-12; XY 07-09		

Curb Information

Hcurb =	24	in	(Height of curb)
Lcurb =	84	in	(Length of curb)
wcurb =	53.5	in	(Width of curb)
WGTcurb =	245	lbs	(Weight of curb)
# Clips long side =	2		
# Clips short side =	2		

Unit Information

WGTunit =	1152	lbs	(Weight of Unit)
Wtmax =	312	lbs	(Maximum corner weight)
Wtmin =	212	lbs	(Minimum corner weight)
Hunit =	55.26	in	(Height of unit above curb)
Hcm =	27.63	in	(Height to center of mass)
Lunit =	87.2	in	(Length of unit)
Wunit =	61.7	in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.2	Default Site Class D
Sms =	3.420	[Fa*Ss]
Sds =	2.280	[2/3*Sms]
Ip =	1.50	(Importance Factor Category III Building)
Fpmax =	1.710	[0.4*Sds*Ip]*Wp*3/Rp
FpmaxASD =	1379	lbs (0.7*Fpmax)
	(unit only)	FpmaxASD = 1672
		lbs (unit and curb)

Wind Loading - 2018 IBC/2019 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ACSE 7-16)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ACSE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ACSE 7-16)
qz =	32.5	psf = 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ACSE 7-16)
Fh ASD trans =	1779	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1259	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	1093	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	1535	lbs	= [FpmaxASD*Hcm+2*(1+0.14SDS)*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1212	lbs	= Comp _{SEISMIC} - [0.6-0.14SDS]*WGTunit
Compression _{WIND} =	747	lbs	= [Fh trans ASD *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1149	lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	1277	lbs	= [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	953	lbs	= Comp _{SEISMIC} - [0.6-0.14SDS]*WGTunit
Compression _{WIND} =	242	lbs	= [Fh trans ASD *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	644	lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} =	1535	lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	1212	lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	1277	lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	953	lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.717 in = A' - (2r+t)
B' = 1.750 in	a' = 23.943 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.609 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.722 in = B' - (t/2+αt/2)
R = 0.0849 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0566 in	c' = 0.000 in = α[C' - t/2]
r' = 0.113 in = R+t/2	u = 0.178 in = πr/2
x = 0.109 in (Distance between centroid and web centerline)	
I _x = 91.935 in ⁴ (Moment of Inertia about X-Axis)	
I _y = 0.174 in ⁴ (Moment of Inertia about Y-Axis)	
A = 1.54 in ²	
r _x = 7.71 in	
r _y = 0.336 in	
r _{min} = 0.336 in	



Axial Compression

P_u = 0.890 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 15.456 k
F_e = 20.54 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.56 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 18.01 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 50 in Lateral unbraced length
k_yL_y/r_y = 119 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 24 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 424.03 ≤ 200 C_R = 0.14
N = 7.00 N/t = 123.67 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.291667 ≤ 2.0 C_h = 0.02
P_n = 1.366 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 0.780 k
Long side: P_{uTrans} = 0.768 k **O.K.** # clips = 2
Short side: P_{uLong} = 0.638 k **O.K.** # clips = 2

(See table C3.4.1-2, fastened to support, one flange, end loading)

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 118.675
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 1.366 k P_n/Ω = 8.390 k
P_n = 14.262 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 445 lbs Max(F_{pmaxASD}/4 -OR- F_{HASDTrans}/4 corner connections)
V_{crnmax} = 606 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.6 ***If combined fails:
of Bolts Used = 1.0 USE --> 2.0
Check Combined Stress in Bolts & Inserts: 0.732 **O.K.** StressComb = 0.366 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.415 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.516 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in
 $t_2 = 0.1017$ in (unit base rail thickness)
 $d = 0.190$ in (screw diameter)
 $t_2/t_1 = 1.8$

$F_{u1} = 65$ ksi
 $F_{u2} = 65$ ksi
 $d_w = 0.375$ in (nom. washer diameter)

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 1887$ #
 $P_{ns} = 2.7t_1dF_{u1}$ 3.86 k
 $P_{ns} = 2.7t_2dF_{u2}$ 1.89 k
 $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #
 $P_{ns} = 2.7t_1dF_{u1}$ 1.89 k
 $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension:

$P_{not} = 1.068$ k (screw pull-out strength)

$P_{nov} = 2.069$ k (screw pull-over strength)

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.779	2	0.89	540 #	2	6.00 in
Short side:	1.379	2	0.69	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0566 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²

$A_{nv} = 0.352$ in²


$A_{nt} = 0.034$ in²

$R_n/\Omega = 5.954$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} =	2143 lbs	Shear _{MAX} =	890 lbs
Compression _{SEISMIC}	=	$[F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$		
Tension _{SEISMIC}	=	$Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	=	$[F_{h trans ASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * w_{curb} - F_{vert ASD} * w_{curb} / 2] / w_{curb}$		
Tension _{WIND}	=	$[F_{h trans ASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * w_{curb} + F_{vert ASD} * w_{curb} / 2] / w_{curb}$		
Longitudinal:	Uplift _{MAX} =	1557 lbs	Shear _{MAX} =	836 lbs
Compression _{SEISMIC}	=	$[F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$		
Tension _{SEISMIC}	=	$Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	=	$[F_{h trans ASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * L_{curb} - F_{vert ASD} * L_{curb} / 2] / L_{curb}$		
Tension _{WIND}	=	$[F_{h trans ASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * L_{curb} + F_{vert ASD} * L_{curb} / 2] / L_{curb}$		

Wood Attachment:

1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded emt (SGmin = 0.43)

Transverse:	$T_{all metal} = 997$ lbs	$V_{all metal} = 1097$ lbs
	$T_{all wood} = 616$ lbs	$V_{all wood} = 400$ lbs
# of Screws Req'd for Uplift =	3.48	COMBINED LOADING: 0.806 O.K.
# of Screws Req'd for Shear =	2.22	Screw Spacing = 19.0 in o.c.
Total # of screws Required =	5	

1/4" φ x 3.5" Simpson SDS screws @ 19 in o.c. along long side of curb

Longitudinal:

# of Screws Req'd for Uplift =	2.5	COMBINED LOADING: 0.804 O.K.
# of Screws Req'd for Shear =	2.1	Screw Spacing = 15.2 in o.c.
Total # of screws Required =	4	

1/4" φ x 3.5" Simpson SDS screws @ 15.2 in o.c. along short side of curb

Steel Deck Attachment:

1/2" φ A307 Bolts to steel angle below deck

Transverse:	$T_{all bolt} = 3927$ lbs	$V_{all bolt} = 2209$ lbs
	$T_{all metal} = 1656$ lbs	$V_{all metal} = 1756$ lbs
# of Bolts Req'd for Uplift =	1.29	COMBINED LOADING: 0.585 O.K.
# of Bolts Req'd for Shear =	0.51	Bolt Spacing = 72.0 in o.c.
Total # of Bolts Required =	2	

1/2" φ A307 Bolts to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.94	COMBINED LOADING: 0.376 O.K.
# of Bolts Req'd for Shear =	0.48	Req'd Min Spacing = 41.5 in o.c.
Total # of Bolts Required =	2	

1/2" φ A307 Bolts to steel angle below deck @ 41.5 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)

Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

Tall_{LRFD} = 1722 lbs Vall_{LRFD} = 2032 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87

Tall_{ASD} = Tall_{LRFD}/α = 920.9 lbs Vall_{ASD} = Vall_{LRFD}/α = 1086.6 lbs (D = 0.465, E = 0.535)

Transverse:	Uplift _{MAX} = 4564 lbs	Shear _{MAX} = 2090 lbs
--------------------	----------------------------------	---------------------------------

Compression_{SEISMIC} = 4956 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb

Tension_{SEISMIC} = 4564 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})

Shear_{SEISMIC} = 2090 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 4.96 spacing = 15.00 in o.c. T_{applied} = 760.6 lbs

Min Bolts Req'd Shear = 2.00 spacing = 60 in o.c. V_{applied} = 348.4 lbs

Try using 6 bolts spaced at 14.40 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$
---	--

Use 6 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 14.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal:	Uplift _{MAX} = 3099 lbs	Shear _{MAX} = 2090 lbs
----------------------	----------------------------------	---------------------------------

Compression_{SEISMIC} = 3491 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb

Tension_{SEISMIC} = 3099 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})

Shear_{SEISMIC} = 2090 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 3.37 spacing = 9.833333 in o.c. T_{applied} = 619.7 lbs

Min Bolts Req'd Shear = 2.00 spacing = 29.5 in o.c. V_{applied} = 418.1 lbs

Try using 5 bolts spaced at 10.38 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.06$
---	--

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 10.4 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBWC-301			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 2 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD 1/4" φ Simpson SDS screw w/ 2.25" threaded embed (SGmin=0.43)	STEEL 1/2" φ A307 bolts	CONCRETE 3/4" φ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	5 @ 19 in o.c.	2 @ 72 in o.c.	6 @ 14.4 in o.c.
SHORT DIRECTION	4 @ 15.17 in o.c.	2 @ 41.5 in o.c.	5 @ 10.38 in o.c.