EST. WEIGHT PROVENT P/N STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR DIRECT For wood, concrete, and steel CBWCPRL08 8" 168 Lbs. attachments, see Roof Anchorage FIT (SUN CORE) LARGE CABINET UNITS Detail. Form No. CB-60. CBWCPRL11 11" 182 Lbs. ZX08-14; XX08-12; XYA7, ZYA7 CBWCPRL14 14" 197 Lbs **FEATURES** ZY07-12; XY07-09; ZL08-14 CBWCPRL24 245 Lbs. Roof curb sides and ends are 16 Ga. 84" Meets seismic requirements for the galvanized steel. following codes: CBC 2022 IBC 2021 81 3/4" Gasketing package provided. 15 13/16" 1 3/4" Typ. Heat treated wood nailer provided. Insulated deck pans provided. Pitched curbs and taller curbs are available **NOTES** S/A 31 1/2" Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support 50" 53 1/2" ductwork below the curb. Thru the curbs utilities are available. Contact your York distributor or ProVent directly. 15 1/2" R/A ATTACH TO CURB WITH 40 3/16" **UNIT HOLD DOWN** (3) #10x 3/4" TEK SCREWS, (1) EACH SIDE **EACH SIDE** 78 1/4" UNIT BASE RAIL ATTACH TO UNIT WITH 3/8" Typ. (3) #10 TEK SCREWS, PER CLIP REGISTER 14 GA. UNIT HOLD "A" (24" MAX. FOR SINEER DOWN PITCHED HEIGHTS) FULL PERIMETER WOOD NAILER CURB, 16 GA. 2" STIFFENER, 16 GA. OF CAL IFORM 7" Typ. 3/4" x 7" x CURB HEIGHT **CURB DETAIL** HOLD DOWN DETAIL **DETAIL K** SUBMITED TO: __ FORM NO: PART NUMBER: 3847 WABASH DR. ProVent MIRA LOMA, CA 91752 COMPANY: _ **CBWC-301 CBWCPRL SERIES** JOB NAME: _ DATE: REV: **DRAWN BY:** PHONE (951) 685-1101 EQUIPMENT: FAX (619) 872-9799 7/27/2023 10 JG

NOTES: