



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBWC-121 Series
CBWCSAV1518 SERIES**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: September 25, 2023
Project Number: PV2312

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR SUNCHOICE UNITS

PROVENT P/N	A	EST. WEIGHT
CBWCSAV151808	08"	230 Lbs.
CBWCSAV151811	11"	265 Lbs.
CBWCSAV151814	14"	300 Lbs.
CBWCSAV151824	24"	415 Lbs.

FEATURES



- Roof curb sides and ends are 14 Ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated sloped deck pans provided.
- Pitched curbs and taller curbs are available.

Notes


Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.

AV 15-18, AD 15-18, AH 15, AL 15, HV 13


Meets seismic requirements for the following codes:
CBC 2022
IBC 2021




ATTACH TO CURB WITH
TEK SCREW




HOLD DOWN DETAIL



CURB DETAIL



DETAIL A



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-121

DATE:
8/28/2023


PART NUMBER:
CBWCSAV1518 SERIES

REV:
1

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

ASSUMES:


CONC SLAB
f_c= 4000PSI MINIMUM
4" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-60

DATE:
8/28/2023

REV:
10

DRAWN BY:
FMM




Client:	ProVent	PV2312
Description:	CBWC-121	SAV1518
Unit:	AV 15-18; AD 15-18; AH/AL 15; HV 13	

Curb Information

Hcurb =	24 in	(Height of curb)
Lcurb =	121.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	420 lbs	(Weight of curb)
# Clips long side =	3	
# Clips short side =	2	

Unit Information

WGUnit =	2385 lbs	(Oper. Weight of Unit)
Wtmax =	716 lbs	(Maximum corner weight)
Wtmin =	507 lbs	(Minimum corner weight)
Hunit =	49.25 in	(Height of unit above curb)
Hcm =	24.625 in	(Height to center of mass)
Lunit =	129.75 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2855 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 3358 lbs
		(unit and curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2447 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1674 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2340 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:		
Compression _{SEISMIC} =	2765 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	593 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	440 lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	1314 lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:		
Compression _{SEISMIC} =	2468 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	296 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	29 lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	902 lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:		
(on long edge)	Comp _{MAX} = 2765 lbs	---> Along long edge of curb.
	Tens _{MAX} = 1314 lbs	---> Along long edge of curb.
Longitudinal:		
(on short edge)	Comp _{MAX} = 2468 lbs	---> Along short edge of curb.
	Tens _{MAX} = 902 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.644 in = A' - (2r+t)
B' = 1.500 in	a' = 23.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.080 in (Distance between centroid and web centerline)	
I _x = 110.108 in ⁴	r _x = 7.60 in
I _y = 0.137 in ⁴	r _y = 0.268 in
A = 1.91 in ²	r _{min} = 0.268 in



Axial Compression

P_u = 1.427 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 5.104 k
F_e = 5.50 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658^{λ_c}) F_y
λ_c = 3.02 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 4.82 ksi
L_y = 77.125 in Lateral unbraced length
k_yL_y/r_y = 230 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 24 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 336.61 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.291667 ≤ 2.0 C_h = 0.02
P_n = 2.130 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.217 k
Long side: P_u_{Trans} = 0.922 k **O.K.** # clips = 3 $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Short side: P_u_{Long} = 1.234 k **web stiffener REQ'D** # clips = 2

***h/t > 260; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)
width of stiffener = 6.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 101.007
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.130 k A_e = 0.324 in²
P_n = 12.817 k P_n/Ω = 7.539 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crn}max = 839 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 1383 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 1.1
of Bolts Used = 3.0

Check Combined Stress in Bolts & Inserts: 0.494 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.935 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2 F_{u2} \sqrt{t_2^3 d}$

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{not} = 0.85 t_c d F_{u2}$

$P_{nov} = 2.607$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{nov} = 1.5 t_1 d_w F_{u1}$

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.855	3	0.95	540 #	2	6.00 in
Short side:	2.855	2	1.43	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.430$ in²


$A_{nt} = 0.042$ in²

$R_n/\Omega = 7.500$ k

$R_n = 0.6 F_y A_{gv} + F_u A_{nt} \leq 0.6 F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14 S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 1814 lbs	Shear _{MAX} = 1679 lbs
Compression _{SEISMIC} =	3888 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1644 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1156 lbs	$= [F_h ASD trans * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vert ASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1814 lbs	$= [F_h ASD trans * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vert ASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 1001 lbs	Shear _{MAX} = 1679 lbs
Compression _{SEISMIC} =	3198 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	954 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	343 lbs	$= [F_h ASD long * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vert ASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	1001 lbs	$= [F_h ASD long * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vert ASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: 1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

$T_{all metal} = 997$ lbs

$V_{all metal} = 1097$ lbs

Transverse: $T_{all wood} = 616$ lbs

$V_{all wood} = 672$ lbs

of Screws Req'd for Uplift = 2.94

COMBINED LOADING: 0.907 O.K.

of Screws Req'd for Shear = 2.50

Screw Spacing = 22.6 in o.c.

Total # of screws Required = 6

1/4" ϕ x 3.5" Simpson SDS screws @ 22.6 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

of Screws Req'd for Uplift = 1.6

COMBINED LOADING: 0.824 O.K.

of Screws Req'd for Shear = 2.5

Screw Spacing = 18.0 in o.c.

Total # of screws Required = 5

1/4" ϕ x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

$T_{all bolt} = 3927$ lbs

$V_{all bolt} = 2209$ lbs

Transverse: $T_{all metal} = 2086$ lbs

$V_{all metal} = 2192$ lbs

of Bolts Req'd for Uplift = 0.87

COMBINED LOADING: 0.230 O.K.

of Bolts Req'd for Shear = 0.77

Bolt Spacing = 54.6 in o.c.

Total # of Bolts Required = 3

1/2" ϕ A307 Bolts to steel angle below deck @ 54.6 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.48

COMBINED LOADING: 0.295 O.K.

of Bolts Req'd for Shear = 0.77

Req'd Min Spacing = 68.1 in o.c.

Total # of Bolts Required = 2

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_oE Q_o = 2.0

Concrete Attachment: 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'c = 3000 psi
h = 4 in (concrete thickness, t_{min} = h_{ef} + 2do) O.K.
h_{ef} = 2.75 in (effective embedment)
da = 0.5 in (anchor diameter) do = 0.625 in (hole diameter)
n = 2 (number of dummy anchors to check capacity with spacing effect)
s = 16.9 in (initial spacing estimate)
tk,cr / uncr = 1135 / 2220 psi (from ESR 4868, Table 14, Temp range B)
tk,cr / uncr = 1156 / 2261 psi If f'c > 2500, multiply by (f'c/2500)^{0.1}
c_{Na} = 7.15 in (min. edge distance for full capacity); c_{Na} = 10d_a√(τ_{uncr}/1100)

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 408.98 \text{ in}^2$$

$$A_{Na0} = 204.49 \text{ in}^2$$

$$N_{ba} = 4943 \text{ lbs}$$

$$N_{ag} = 9886 \text{ lbs (group)}$$

$$\phi N_{ag} = 4820 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$$

$$\alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.8 \text{ for light}$$

**Breakout
strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 207.4875 \text{ in}^2$$

$$A_{Nco} = 68.0625 \text{ in}^2$$

$$N_{cbg} = 12945 \text{ lbs (group)}$$

$$\phi N_{cbg} = 7281 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 4246 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 4940 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 1927$$

$$T_{all,LRFD} = 2410 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E$$

$$T_{all,ASD} = T_{all,LRFD} / \alpha = 1411 \text{ lbs}$$

$$V_{all,ASD} = V_{all,LRFD} / \alpha = 1796 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 3681 lbs Shear_{MAX} = 3358 lbs

$$\text{Compression}_{SEISMIC} = 5925 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3681 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3358 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.61 \text{ spacing} = 54.56 \text{ in o.c.}$$

$$T_{applied} = 920.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 109.13 \text{ in o.c.}$$

$$V_{applied} = 559.6 \text{ lbs}$$

Try using 4 bolts
spaced at 36.38 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.96 \quad \text{O.K.}$$

Use 4 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 36.4 in o.c. max. along long side of curb w/ 2.75in embed

Longitudinal: Uplift_{MAX} = 2302 lbs Shear_{MAX} = 3358 lbs

$$\text{Compression}_{SEISMIC} = 4546 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 2302 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 3358 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.63 \text{ spacing} = 34.06 \text{ in o.c.}$$

$$T_{applied} = 1151.0 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 68.13 \text{ in o.c.}$$

$$V_{applied} = 559.6 \text{ lbs}$$

Try using 2 bolts
spaced at 68.13 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.13 \quad \text{O.K.}$$

Use 2 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 2.75in embed

CURB DESIGN SUMMARY:				Unit:
CURB RAIL THICKNESS: 0.0713 in 14 Gauge				AV 15-18; AD 15-18; AH/AL 15;
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge				HV 13
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip				
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip				
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip				
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip				
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts				
CURB ANCHORAGE	WOOD	STEEL	CONCRETE	
	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" φ A307 Bolts to steel angle below deck	1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed	
LONG DIRECTION	6 @ 22.63 in o.c.	3 @ 54.56 in o.c.	4 @ 36.38 in o.c.	
SHORT DIRECTION	5 @ 18.03 in o.c.	2 @ 68.13 in o.c.	2 @ 68.13 in o.c.	

