



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBWC-122 Series
CBWCSAV2025 SERIES**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: September 25, 2023
Project Number: PV2312

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR SUNCORE UNITS

PROVENT P/N	A	EST. WEIGHT
CBWCSAV202508	08"	305
CBWCSAV202511	11"	340
CBWCSAV202514	14"	375
CBWCSAV202524	24"	469

FEATURES




- Roof curb sides and ends are 14 Ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated sloped deck pans provided.
- Pitched curbs and taller curbs are available.

Notes


Attached ductwork to roof curb.
Flanges of duct rest on top of curb.
Support ductwork below the curb.

AV 20-25, AD 20-25, AE 13-15, AW 13-15, AH 18-20, AL 18-20, HV 15-20


Meets seismic requirements for the following codes:
CBC 2022
IBC 2021




HOLD DOWN DETAIL



CURB DETAIL



DETAIL A



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-122

DATE:
8/28/2023


PART NUMBER:
CBWCSAV2025 Series

REV:
1

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

ASSUMES:


CONC SLAB
f_c= 4000PSI MINIMUM
4" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 7-1/4" EDGE DISTANCE

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19.0" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 24.75" O.C.
PRD3715	4 @ 22.96" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	3 @ 36" O.C.	2 @ 41.5" O.C.
SAV1518	4 @ 36.38" O.C.	2 @ 68.13" O.C.
SAV2025	4 @ 41.04" O.C.	3 @ 34.06" O.C.
SAV28	5 @ 34.88" O.C.	3 @ 34.06" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	7 @ 12.15" O.C.	5 @ 10.75" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.35" O.C.
PRL	6 @ 15.2" O.C.	4 @ 15.17" O.C.
SAV1518	6 @ 22.63" O.C.	5 @ 18.03" O.C.
SAV2025	7 @ 21.19" O.C.	5 @ 18.03" O.C.
SAV28	8 @ 20.5" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-60

DATE:
8/28/2023

REV:
10

DRAWN BY:
FMM




Client:	ProVent	PV2312
Description:	CBWC-122	SAV2025
Unit:	AV/AD 20-25; AE/AW 13-15; AH/AL 18-20; HV 15-20	

Curb Information

Hcurb =	24 in	(Height of curb)
Lcurb =	135.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	469 lbs	(Weight of curb)
# Clips long side =	3	
# Clips short side =	2	

Unit Information

WGUnit =	2655 lbs	(Oper. Weight of Unit)
Wtmax =	797 lbs	(Maximum corner weight)
Wtmin =	564 lbs	(Minimum corner weight)
Hunit =	57.25 in	(Height of unit above curb)
Hcm =	28.625 in	(Height to center of mass)
Lunit =	143.8125 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3178 lbs	(0.7*Fpmax)
	(unit only)	
		ap = 2.5
		Rp = 6
		FpmaxASD = 3739 lbs
		(unit and curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	3008 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1856 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2594 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	3237 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	819 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	733 lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	1695 lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	2775 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	356 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	52 lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	1013 lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	3237 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	1695 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	2775 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1013 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.644 in = A' - (2r+t)
B' = 1.500 in	a' = 23.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.080 in (Distance between centroid and web centerline)	
I _x = 110.108 in ⁴	r _x = 7.60 in
I _y = 0.137 in ⁴	r _y = 0.268 in
A = 1.91 in ²	r _{min} = 0.268 in



Axial Compression

P_u = 1.589 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 5.104 k
F_e = 5.50 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 3.02 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 4.82 ksi
L_y = 77.125 in Lateral unbraced length
k_yL_y/r_y = 230 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 24 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 336.61 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.291667 ≤ 2.0 C_h = 0.02
P_n = 2.130 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.217 k
Long side: P_u_{Trans} = 1.079 k **O.K.** # clips = 3 $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Short side: P_u_{Long} = 1.387 k **web stiffener REQ'D** # clips = 2

***h/t > 260; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 6" (C-channel)
width of stiffener = 6.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 101.007
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.324 in²
P_{wc} = 2.130 k P_n/Ω = 7.539 k
P_n = 12.817 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crn}max = 935 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 1618 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs V_{all} = 1208 lbs
Threaded Insert: Tall = 2860 lbs V_{all} = 1536 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.3
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.572 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 1.094 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.178	3	1.06	540 #	2	6.00 in
Short side:	3.178	2	1.59	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.430$ in²


$A_{nt} = 0.042$ in²

$R_n/\Omega = 7.500$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 2336 lbs	Shear _{MAX} = 1870 lbs
Compression _{SEISMIC} =	4517 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	2017 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1616 lbs	$= [F_h ASD trans * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vert ASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	2336 lbs	$= [F_h ASD trans * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vert ASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 1083 lbs	Shear _{MAX} = 1870 lbs
Compression _{SEISMIC} =	3517 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	1018 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	363 lbs	$= [F_h ASD long * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vert ASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	1083 lbs	$= [F_h ASD long * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vert ASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: 1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emb (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	3.79	COMBINED LOADING: 0.939 O.K.
# of Screws Req'd for Shear =	2.78	Screw Spacing = 21.2 in o.c.
Total # of screws Required =	7	

1/4" ϕ x 3.5" Simpson SDS screws @ 21.2 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift =	1.8	COMBINED LOADING: 0.908 O.K.
# of Screws Req'd for Shear =	2.8	Screw Spacing = 18.0 in o.c.
Total # of screws Required =	5	

1/4" ϕ x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 2086 lbs	Vall _{metal} = 2192 lbs
# of Bolts Req'd for Uplift =	1.12	COMBINED LOADING: 0.316 O.K.
# of Bolts Req'd for Shear =	0.85	Bolt Spacing = 61.6 in o.c.
Total # of Bolts Required =	3	

1/2" ϕ A307 Bolts to steel angle below deck @ 61.6 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.52	COMBINED LOADING: 0.347 O.K.
# of Bolts Req'd for Shear =	0.85	Req'd Min Spacing = 68.1 in o.c.
Total # of Bolts Required =	2	

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_oE Q_o = 2.0

Concrete Attachment: 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'c = 3000 psi
h = 4 in (concrete thickness, t_{min} = h_{ef} + 2do) O.K.
h_{ef} = 2.75 in (effective embedment)
da = 0.5 in (anchor diameter) do = 0.625 in (hole diameter)
n = 2 (number of dummy anchors to check capacity with spacing effect)
s = 16.9 in (initial spacing estimate)
tk_{cr} / uncr = 1135 / 2220 psi (from ESR 4868, Table 14, Temp range B)
tk_{cr} / uncr = 1156 / 2261 psi If f'c > 2500, multiply by (f'c/2500)^{0.1}
c_{Na} = 7.15 in (min. edge distance for full capacity); c_{Na} = 10d_a√(τ_{uncr}/1100)

Tension:

Bond strength

***Bond strength will govern over concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 408.98 \text{ in}^2$$

$$A_{Na0} = 204.49 \text{ in}^2$$

$$N_{ba} = 4943 \text{ lbs}$$

$$N_{ag} = 9886 \text{ lbs (group)}$$

$$\phi N_{ag} = 4820 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic}$$

$$\alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.8 \text{ for light}$$

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$A_{Nc} = 207.4875 \text{ in}^2$$

$$A_{Nco} = 68.0625 \text{ in}^2$$

$$N_{cbg} = 12945 \text{ lbs (group)}$$

$$\phi N_{cbg} = 7281 \text{ lbs (group)}$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$N_b = 4246 \text{ lbs}$$

$$k_c = 17$$

$$\phi_{conc} = 0.75$$

$$\phi_{bond} = 0.65$$

$$\phi_{seis} = 0.75$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 4940 \text{ (from ESR4868, Table 11)}$$

$$\phi V_{sa,eq} = 1927$$

$$T_{all,LRFD} = 2410 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E$$

$$T_{all,ASD} = T_{all,LRFD} / \alpha = 1411 \text{ lbs}$$

$$V_{all,ASD} = V_{all,LRFD} / \alpha = 1796 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 4473 lbs Shear_{MAX} = 3739 lbs

$$\text{Compression}_{SEISMIC} = 6973 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 4473 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3739 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 3.17 \text{ spacing} = 41.04 \text{ in o.c.}$$

$$T_{applied} = 1118.4 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.08 \text{ spacing} = 61.56 \text{ in o.c.}$$

$$V_{applied} = 534.2 \text{ lbs}$$

Try using 4 bolts

spaced at 41.04 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.09 \quad \text{O.K.}$$

Use 4 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 41 in o.c. max. along long side of curb w/ 2.75in embed

Longitudinal: Uplift_{MAX} = 2474 lbs Shear_{MAX} = 3739 lbs

$$\text{Compression}_{SEISMIC} = 4973 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 2474 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 3739 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.75 \text{ spacing} = 34.06 \text{ in o.c.}$$

$$T_{applied} = 824.7 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.08 \text{ spacing} = 34.06 \text{ in o.c.}$$

$$V_{applied} = 534.2 \text{ lbs}$$

Try using 3 bolts

spaced at 34.06 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.88 \quad \text{O.K.}$$

Use 3 - 1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 34.1 in o.c. max. along short side of curb w/ 2.75in embed

CURB DESIGN SUMMARY:		Unit:
CURB RAIL THICKNESS: 0.0713 in 14 Gauge		AV/AD 20-25; AE/AW 13-15;
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge		AH/AL 18-20; HV 15-20
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 3/4" x 6" (C-channel) stiffener at each clip		
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts		
CURB ANCHORAGE	WOOD	STEEL
	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" φ A307 Bolts to steel angle below deck
LONG DIRECTION	7 @ 21.19 in o.c.	3 @ 61.56 in o.c.
SHORT DIRECTION	5 @ 18.03 in o.c.	2 @ 68.13 in o.c.
		CONCRETE
		1/2" φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 2.75in embed
		4 @ 41.04 in o.c.
		3 @ 34.06 in o.c.

