



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

Structural Calculations
for
Predator & Sunline Magna Series
ISCALSUN3672 Roof Curb**
Form No. ISCAL-126



Prepared for:

PROVENT

3847 Wabash Drive
Mira Loma, CA 91725

Date: September 18, 2019

Project Number: PV1906



STRUCTURALLY CALCULATED VIBRATION ISOLATION CURBS FOR YORK UNITS

ZR 036-060, XP 036-060, ZF 036-072

ProVent P/N (2" Deflection)	A	B	WEIGHT	ProVent P/N (3" Deflection)	A	B	WEIGHT
ISCALSUN367218**	8"	18"	354 Lbs	ISCALSUN3672193**	8"	19"	404 Lbs
ISCALSUN367221**	11"	21"	368 Lbs	ISCALSUN3672223**	11"	22"	418 Lbs
ISCALSUN367224**	14"	24"	383 Lbs	ISCALSUN3672253**	14"	25"	433 Lbs

**Note: Spring configuration must be added to part number at time of order.

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-24A.

Welded isolation spring housings are standard. For bolted spring housings, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. ISCAL-131.

FEATURES

- Roof curb sides and ends are 16 ga. galvanized steel.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn QSHPD pre-approved 2" or 3" deflection seismic restraints. (OPA-0070), (JOA).

NOTES

Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.



3847 WABASH DR.
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799


SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
ISCAL-126

PART NUMBER:
ISCALSUN3672 SERIES
DATE:
09/13/19
REV:
6
DRAWN BY:
ALL

STEEL ATTACHMENT


CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS TO STEEL ANGLE BELOW.



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	2 @ 62.13 in o.c.	2 @ 24.75 in o.c.

WOOD ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø SIMPSON SDS SCREWS W/3.0" MIN. EMBED INTO WOOD (SG MIN = 0.43)



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	14 @ 5.09 in o.c.	10 @ 3.19 in o.c.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	13 @ 5.18 in o.c.	8 @ 3.54 in o.c.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
f_c = 4000PSI MINIMUM
5 1/2" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT
WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRDD RODS IN HILTI HIT-HY 200 EPOXY W/ 4" EMBED INTO CONCRETE.



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	13 @ 5.18 in o.c.	8 @ 3.54 in o.c.

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series	ISCAL Series
SUN3672	SUN3672	SUN3672



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-24A

DATE:
09/18/19

REV:
13

DRAWN BY:
ALL




Client:	ProVent PV1906	Upper curb tube
Curb:	ISCAL-126 Iso Curb (ISCALSUN3672**)	
Unit:	ZE 036-072; XN 036-060; ZR/XP/ZF 036-072	

Curb Information

Hcurb upper =	6.5 in	(Height of upper curb tube)
Lcurb =	74.125 in	(Length of curb)
wcurb =	36.75 in	(Width of curb)
WGTCurb =	148 lbs	(Weight of upper curb)
# Clips long side =	2	# Clips short side = 2

Unit Information

WGTunit =	665 lbs	(Weight of Unit)
Wtmax =	399 lbs	(Maximum corner weight)
Wtmin =	266 lbs	(Minimum corner weight)
Hunit =	32.625 in	(Height of unit above curb)
Hcm =	16.3125 in	(Height to center of mass)
Lunit =	82.25 in	(Length of unit)
Wunit =	44.875 in	(Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	(Fa*Ss)
Sds =	1.900	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	4,560 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	2123 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 2595 lbs
		(unit and upper curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ACSE 7-10)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-10)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr _(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-10)
GCr _(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-10)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² [Eq. 29.3-1 ASCE 7-10]
F _{h ASD trans} =	828 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) [Eq. 29.5-2]
F _{h ASD long} =	452 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
F _{vert ASD} =	750 lbs	= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression _{SEISMIC} =	1952 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1730 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	471 lbs	= [F _{h transASD} *Hcm+2*0.6*Wtmax*wcurb-F _{vertASD} *wcurb/2]/wcurb
Tension _{WIND} =	823 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	1477 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1255 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	203 lbs	= [F _{h transASD} *Hcm+2*0.6*Wtmax*Lcurb-F _{vertASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	554 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	1952 lbs	----> Along long edge of curb.
	Tens _{MAX} =	1730 lbs	----> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	1477 lbs	----> Along short edge of curb.
	Tens _{MAX} =	1255 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.1242 10 Gauge
E = 29500 ksi

Tube Curb Design

Section Properties of Tube - 6.5x1.5x10Ga

Fy = 50 ksi	Ag = 1.996 in ²	R = 0.1875	d = 6.125
Fu = 65 ksi	Ix = 4.613 in ⁴	ly = 0.444 in ⁴	wt = 122.094
E = 29500 ksi	Sx = 1.419 in ³	Sy = 0.593 in ³	
height = 6.5 in	rx = 1.520 in	ry = 0.472 in	b/t = 12.07729
width = 1.5 in	Zx = 1.862 in ³	Zy = 0.639 in ³	d/t = 49.31562
t = 0.1242 in			

Check weak axis bending of tube:

<u>Long side</u>		<u>Short side</u>	
# clips = 2		# clips = 2	
compression = 28.636 lb/in		compression = 57.760 lb/in	
clip spacing = 66.13 in		clip spacing = 28.75 in	
Mmax = 15.7 k-in		Mmax = 5.97 k-in	
Yielding My = 29.63 k-in		Mp _y /Ω = 17.74 k-in	O.K.
Flange local buckling Mn = 29.63 k-in	<--Section is compact, FLB does not apply		
Web local buckling Mn = 29.63 k-in	<--Section is compact, WLB does not apply		

Axial Compression

Pa = 1.061 k (Max Axial Comp) Ω_c = 1.80
Pn/Ω_c = 8.429 k
Fe = 15.41 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y λ_c = √(F_y/F_e) F_e = (π²E)/(kl/r)²
λ_c = 1.801 If λ_c > 1.5; F_n = (0.877/λ_c²) F_y
Fn = 13.52 ksi
Ly = 70.13 in Lateral unbraced length
k_yL_y/r_y = 137 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 6.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.1242 in	h/t = 52.33 ≤ 200	C _R = 0.08	
N = 7.00	N/t = 56.36 ≤ 210	C _N = 0.12	
Ω _w = 1.75	N/h = 1.077 ≤ 2.0	C _h = 0.048	
P _n = 5.786 k	R/t = 1.51 ≤ 12.0		

Long side: Pa_{Trans} = 0.976 k **O.K.** # clips = 2
Short side: Pa_{Long} = 0.739 k **O.K.** # clips = 2

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \frac{R}{\sqrt{t}} \right) \left(1 + C_N \frac{N}{\sqrt{t}} \right) \left(1 - C_h \frac{h}{\sqrt{t}} \right)$$

Check Web Stiffener

N/A
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ω_c = 1.70
w/ts = 118.675
1.28V(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} Ae = 0.380 in²
P_{wc} = 5.786 k
P_n = 17.357 k
Pn/Ω_c = 10.210 k **Not Req'd**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 531 lbs Max(F_{pmaxASD}/4 -OR- F_{HASDtrans}/4 corner connections)
Vcrnmax = 865 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.8 ***If combined fails:
of Bolts Used = 1.0 USE --> 2.0
Check Combined Stress in Bolts & Inserts: 1.003 **N.G.** StressComb = 0.502 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 3.105 in P_n/Ω = 1/Ω * 0.75tL_{F_u} ≥ V_{req} L_{req}'d = V_{req}Ω / 0.75tF_u
Lreq'd = 0.336 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$


$t_1 = 0.1017$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.1242$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.2$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 3391$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 3391$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 5.21 k $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k
 $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k $P_{ns} = 2.7t_2dF_{u2}$ 4.14 k
 $P_{ns} = 2.7t_2dF_{u2}$ 4.14 k
 $P_{ns}/\Omega = 1130$ #
 $P_{ss}/\Omega = 540$ # <- Controls
Tension: $P_{not} = 1.304$ k (screw pull-out strength) $P_{not} = 0.85t_c dF_{u2}$
 $P_{nov} = 3.718$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ns}/\Omega = 435$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.123	2	1.06	540 #	4	2.00 in
Short side:	2.123	2	1.06	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)
thinnest part = 0.1017 in (min. 1.5d)
Check Block shear rupture: O.K. $\Omega = 2.22$ bolt/screw connection
 $F_y = 50$ ksi $A_{nv} = 0.661$ in² $A_{nt} = 0.117$ in²
 $R_n/\Omega = 12.372$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)

BSR O.K.



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 1952 lbs
	Tens _{MAX} = 1730 lbs
	Shear _{MAX} = 1061 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1477 lbs
	Tens _{MAX} = 1255 lbs
	Shear _{MAX} = 1061 lbs


Loads at each Isolator Type: JQA

Transverse loading: (on long edge) # isolators: 2	Comp _{MAX} = 976.2 lbs
	Tens _{MAX} = 865.2 lbs
	Shear _{MAX} = 265.3 lbs
Longitudinal loading: (on short edge) # isolators: 2	Comp _{MAX} = 738.7 lbs
	Tens _{MAX} = 627.6 lbs
	Shear _{MAX} = 265.3 lbs

Max compression force on isolator: 0.976 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 0.865 k ≤ 1.660 k **O.K.**
Max shear on isolator: 0.265 k ≤ 0.800 k **O.K.**

Forces on top bolt:

$d_b = 0.375$ in
upper rail, $t = 0.1242$ in
Tension = 0.865 k
Shear = 0.265 k



Shear on curb rail: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 8.073$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.691$ k $A_n = 0.202$ in

N.S.R. O.K.

$$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063 \text{ ksi}$$

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.633$ k $d/t = 3.02$

Bearing O.K.

$$C = 3.00 \quad m_f = 1.00$$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt} \quad f_v = 2.40 \text{ ksi} \quad \text{O.K.}$$

Combined Not Applicable $F'_{nt} = 40.50$ ksi $F_{nv}/\Omega = 10.00$ ksi




Client:	ProVent PV1906	Base curb
Project:	ISCAL-126 Iso Curb (ISCALSUN3672**)	
Unit:	ZE 036-072; XN 036-060; ZR/XP/ZF 036-072	

Curb Information

Hcurb =	23	in	(Height of curb)
Lcurb =	74.125	in	(Length of curb)
wcurb =	36.75	in	(Width of curb)
WGTcurb =	433	lbs	(Weight of curb)
# springs long side =	2		# springs short side = 2

Unit Information

WGTunit =	665	lbs	(Weight of Unit)
Wtmax =	399	lbs	(Maximum corner weight)
Wtmin =	266	lbs	(Minimum corner weight)
Hunit =	32.625	in	(Height of unit above curb)
Hcm =	27.3125	in	(Ht to ctr mass + 11")
Lunit =	82.25	in	(Length of unit)
Wunit =	44.875	in	(Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	(Fa*Ss)
Sds =	1.900	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	4.560 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	2595 lbs	(0.7*Fpmax)
	(unit + upper curb only - from upper rail calc)	FpmaxASD = 3505 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-10)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr _(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-10)
GCr _(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-10)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 29.3-1 ASCE 7-10)
F _{h ASD trans} =	1178 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
F _{h ASD long} =	643 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	750 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	2939 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	2717 lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	979 lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*wcurb-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1330 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	1966 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1744 lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	341 lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*Lcurb-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	692 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} =	2939 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} =	2717 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	1966 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1744 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 23.000 in	a = 22.717 in = A' - (2r+t)
B' = 1.750 in	a' = 22.943 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.609 in = B' - [r+t/2+a(r+t/2)]
a = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.722 in = B' - (t/2+at/2)
R = 0.0849 (Inside bend radius)	c = 0.000 in = a[C' - (r+t/2)]
t = 0.0566 in	c' = 0.000 in = a[C' - t/2]
r' = 0.113 in = R+t/2	u = 0.178 in = πr/2
x = 0.113 in (Distance between centroid and web centerline)	
I _x = 81.932 in (Moment of Inertia about X-Axis)	
I _y = 0.174 in (Moment of Inertia about Y-Axis)	
A = 1.49 in ²	
r _x = 7.42 in	
r _y = 0.342 in	
r _{min} = 0.342 in	



Axial Compression

Pa = 1.298 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 7.149 k		
F _e = 9.86 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$F_n = \begin{cases} (0.658\lambda_c^2) F_y & \text{If } \lambda_c \leq 1.5; \\ \frac{0.877}{\lambda_c^2} F_y & \text{If } \lambda_c > 1.5; \end{cases}$
λ _c = 2.25		$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
F _n = 8.65 ksi		$F_e = \frac{\pi^2 E}{(kl/r)^2}$
L _y = 73.38 in	Lateral unbraced length	
k _y L _y /r _y = 172	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 23 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0566 in	h/t = 406.36 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 123.67 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.304348 ≤ 2.0	C _h = 0.02	
P _n = 1.386 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 0.792 k			
Long side: P _{aTrans} = 1.469 k	web stiffener REQ'D # clips = 2	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{aLong} = 0.983 k	web stiffener REQ'D # clips = 2		

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28V/E/F _y	Ω _c = 1.70
w/ts = 118.675	
1.28V[E/F _y] = 31.091	--> w/ts over limit Use C3.7.2
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}	
P _{wc} = 1.386 k	A _e = 0.380 in ²
P _n = 14.276 k	
P _n /Ω _c = 8.398 k	O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 649 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
V _{crnmax} = 1358 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.3	
# of Bolts required for Shear = 1.2	
# of Bolts Used = 2.0	

***If combined fails:

USE --> 4.0

Check Combined Stress in Bolts & Inserts: 0.751 **O.K.** StressComb = 0.375 **O.K.**



Check 1/8" welded connection <--- USE WELD

Assume L/t > 25: 25*t = 1.415 in
Lreq'd = 1.157 in

$\Omega = 2.35$
 $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$

Curb Loads

Transverse: (on long edge)	Comp _{MAX} = 2939 lbs Tens _{MAX} = 2717 lbs Shear _{MAX} = 1298 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1966 lbs Tens _{MAX} = 1744 lbs Shear _{MAX} = 1298 lbs

Loads at each Isolator

Transverse loading: (on long edge)	Comp _{MAX} = 1469.5 lbs Tens _{MAX} = 1358.4 lbs # isolators: 2 Shear _{MAX} = 648.8 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 983.2 lbs Tens _{MAX} = 872.2 lbs # isolators: 2 Shear _{MAX} = 648.8 lbs

Max compression force on isolator: 1.469 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 1.358 k ≤ 1.660 k **O.K.**
Max shear on isolator: 0.649 k ≤ 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, t = 0.0566 in
Tension = 0.679 k / bolt
Shear = 0.324 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 3.679$ k e = 1.0 in

Shear O.K.

Net section rupture: $P_n = A_nF_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 4.691$ k $A_n = 0.085$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.207$ k d/t = 8.83

Bearing O.K. C = 3.00 m_f = 1.00



Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ F_{nt} = 45.0 ksi A_b = 0.1963 in²
P_{nt}/Ω = 3.927 k **Bolt tension O.K.** Ω_t = 2.25

Shear $P_{nv} = A_b F_{nv}$ F_{nv} = 27.0 ksi Ω_v = 2.40
P_{nv}/Ω = 2.209 k **Bolt shear O.K.** ***[Table E3.4-1, AISI]***

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ f_v = 1.65 ksi
F'nt = 45.0 ksi F_{nv}/Ω = 11.25 ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: {0.6-0.14SDS}D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 5127 lbs	Shear _{MAX} = 1752 lbs
Compression _{SEISMIC} =	5493 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb}) + (1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}
Tension _{SEISMIC} =	5127 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	1567 lbs	= [F _{h transASD} *(H _{cm} +H _{curb}) + 0.6*(WGT _{unit+curb} /2)*w _{curb} - F _{vertASD} *w _{curb}]/w _{curb}
Tension _{WIND} =	1658 lbs	= [F _{h transASD} *(H _{cm} +H _{curb}) - 0.6*(WGT _{unit+curb} /2)*w _{curb} + F _{vertASD} *w _{curb}]/w _{curb}
Longitudinal:	Uplift _{MAX} = 2707 lbs	Shear _{MAX} = 1752 lbs
Compression _{SEISMIC} =	3074 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb}) + (1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}
Tension _{SEISMIC} =	2707 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	390 lbs	= [F _{h transASD} *(H _{cm} +H _{curb}) + 0.6*(WGT _{unit+curb} /2)*L _{curb} - F _{vertASD} *L _{curb}]/L _{curb}
Tension _{WIND} =	482 lbs	= [F _{h transASD} *(H _{cm} +H _{curb}) - 0.6*(WGT _{unit+curb} /2)*L _{curb} + F _{vertASD} *L _{curb}]/L _{curb}

Wood Attachment: 1/4" φ Simpson SDS screws w/ 3.0" min. embed (SG_{min} = 0.43)

Transverse:	Tall _{metal} = 946.67 lbs	Vall _{metal} = 1043.33 lbs
	Tall _{wood} = 552 lbs	Vall _{wood} = 400 lbs
	# of Screws Req'd for Uplift = 9.29	COMBINED LOADING: 0.976 O.K.
	# of Screws Req'd for Shear = 4.38	Req'd Min Spacing = 5.1 in o.c.
	Total # of screws required = 14	

Use 14 - 1/4" φ Simpson SDS screws @ 5.1 in o.c. along long side of curb w/ 3.0" min. embed



Longitudinal:

of Screws Req'd for Uplift = 4.90 COMBINED LOADING: 0.929 O.K.
of Screws Req'd for Shear = 4.38 Screw Spacing = 3.2 in o.c.
Total # of screws required = 10

Use 10 - 1/4" ϕ Simpson SDS screws @ 3.2 in o.c. along short side of curb w/ 3.0" min. embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse: $T_{all,bolt} = 6903$ lbs $V_{all,bolt} = 3682$ lbs
of Bolts Req'd for Uplift = 0.74 COMBINED LOADING: 0.609 O.K.
of Bolts Req'd for Shear = 0.48 Bolt Spacing = 62.1 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 62.1 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.39 COMBINED LOADING: 0.434 O.K.
of Bolts Req'd for Shear = 0.48 Bolt Spacing = 24.8 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 24.8 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

$T_{all,LRFD} = 1919$ lbs $V_{all,LRFD} = 3188$ lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 $T_{all,ASD} = T_{all,LRFD}/\alpha = 1026.2$ lbs $V_{all,ASD} = V_{all,LRFD}/\alpha = 1704.8$ lbs ($D = 0.465, E = 0.535$)

Transverse: Uplift_{MAX} = 12324 lbs Shear_{MAX} = 4381 lbs

Compression_{SEISMIC} = 12691 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$
Tension_{SEISMIC} = 12324 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$
Shear_{SEISMIC} = 4381 lbs = $2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 12.01 spacing = 4.18 in o.c. T_{applied} = 948.0 lbs
Min Bolts Req'd Shear = 2.57 spacing = 25.0625 in o.c. V_{applied} = 337.0 lbs

Try using 13 bolts spaced at 5.18 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12$

Use 13 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.2 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 6276 lbs Shear_{MAX} = 4381 lbs

Compression_{SEISMIC} = 6642 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$
Tension_{SEISMIC} = 6276 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$
Shear_{SEISMIC} = 4381 lbs = $2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 6.12 spacing = 2.125 in o.c. T_{applied} = 784.4 lbs
Min Bolts Req'd Shear = 2.57 spacing = 6.375 in o.c. V_{applied} = 547.6 lbs

Try using 8 bolts spaced at 3.54 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.09$

Use 8 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 3.5 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		ISCAL-126 (ISCALSUN3672**)		Unit: ZE 036-072; XN 036-060; ZR/XP/ZF 036-072
UPPER CURB TUBE THICKNESS: 0.1242 in 10 Gauge				
UNIT CLIP THICKNESS: 0.1017 in 12 Gauge				
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
VIBRATION ISOLATOR TYPE: JQA Top stud diameter: 3/8				
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16				
BASE CURB THICKNESS: 0.0566 in 16 Gauge				
WEB STIFFENER: 16Ga x 1.5in x 7in [C-channel] stiffener at each clip on base curb				
CORNER CONNECTION: Use minimum 1/8" welded connection				
CURB ANCHORAGE	WOOD	STEEL	CONCRETE	
	1/4" ϕ Simpson SDS screws w/ 3.0" min. embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed	
LONG DIRECTION	14 @ 5.09 in o.c.	2 @ 62.13 in o.c.	13 @ 5.18 in o.c.	
SHORT DIRECTION	10 @ 3.19 in o.c.	2 @ 24.75 in o.c.	8 @ 3.54 in o.c.	