



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBISC-02 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725



Date: July 29, 2019
Project Number: PV1805

Welded Isolation springs
housing are standard. For bolted
spring housing, neoprene pads and
spring cups see Weldment and
Bolting Detail, Form No. CB-61

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.


- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.

P***B CABINET



****Note:** Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



PHONE (951) 685-1101
FAX (619) 872-9799


FORM NO:
CBISC-02

PART NUMBER:

DRAWN BY:
ALL



STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL

WELDMENT AND BOLTING DETAIL




BASE CURB SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL




Client: ProVent PV1805
Project: CBISC-02 Iso Curb (CBISCLXL**) Upper curb rail
Unit: ALL YORK P**B CABINETS

Curb Information

Hcurb upper = 5.5 in (Height of upper curb rail)
Lcurb = 46.5 in (Length of curb)
wcurb = 41 in (Width of curb)
WGTCurb = 239 lbs (Weight of curb)
Clips long side = 1 # Clips short side = 1

Unit Information

WGTunit = 420 lbs (Weight of Unit)
Wtmax = 141 lbs (Maximum corner weight)
Wtmin = 78 lbs (Minimum corner weight)
Hunit = 55 in (Height of unit above curb)
Hcm = 27.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 45.75 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1117 lbs (0.7*Fpmax)

FpmaxASD = 1753 lbs
(unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr [horizontal] = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr [vertical] = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
Fh ASD trans = 798 lbs = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD long = 713 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) (Eq. 29.5-2)
Fvert ASD = 477 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper) (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1106 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 966 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 466 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 691 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1018 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 877 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 352 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 577 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1106 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 966 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1018 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 877 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0713$ 14 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 5.500$ in	$a = 5.144$ in $= A' \cdot [2r+t]$
$B' = 1.500$ in	$a' = 5.429$ in $= A' \cdot t$
$C' = 0.000$ in [0 if no lips]	$b = 1.322$ in $= B' \cdot [r+t/2+o(r+t/2)]$
$o = 0.000$ [0 - no Lip; 1 w/ lip]	$b' = 1.464$ in $= B' \cdot [t/2+o(t/2)]$
$R = 0.1069$ (Inside bend radius)	$c = 0.000$ in $= a[C' \cdot (r+t/2)]$
$t = 0.0713$ in	$c' = 0.000$ in $= a[C' \cdot t/2]$
$r = 0.143$ in $= R+t/2$	$u = 0.224$ in $= \pi r/2$
$x = 0.261$ in [Distance between centroid and web centerline]	
$I_x = 2.424$ in ⁴ [Moment of Inertia about X-Axis]	
$I_y = 0.109$ in ⁴ [Moment of Inertia about Y-Axis]	
$A = 0.59$ in ²	
$r_x = 2.03$ in	
$r_y = 0.432$ in	
$r_{min} = 0.432$ in	



Axial Compression

$P_u = 0.559$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 9.561$ k
 $F_e = 39.18$ ksi $\lambda_c = \frac{F_y}{F_e} = \frac{50}{39.18} = 1.277$
 $\lambda_c = 1.13$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
 $F_n = 29.31$ ksi If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$
 $L_y = 46.50$ in Lateral unbraced length (assume $k=0.8$)
 $k_y L_y/r_y = 86$

Compression Check = **O.K.**

Check Web Crippling

$h = 5.5$ in $t = 0.0713$ in $N = 7.00$
 $\Omega_w = 1.75$ $P_n = 1.947$ k $P_n/\Omega_w = 1.112$ k
Long side: $P_{u,trans} = 1.106$ k
Short side: $P_{u,Long} = 1.018$ k

-- Check limits:
 $h/t = 77.14 \leq 200$
 $N/t = 98.18 \leq 210$
 $N/h = 1.273 \leq 2.0$
 $R/t = 1.50 \leq 12.0$

$C = 7.50$
 $C_R = 0.08$
 $C_N = 0.12$
 $C_h = 0.048$

[See table C3.4.1-2, fastened to support, two flange, end loading]

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
O.K. # clips = 1
O.K. # clips = 1

Check Web Stiffener

N/A
width of stiffener = 7.000 in $t_s = 0.0713$ 14 Gauge
web of stiff. $w = 6.644$ in $R_s = 0.1069$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 93.178$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_o F_y) \geq P_{wc}$
 $P_{wc} = 1.947$ k $A_e = 0.474$ in²
 $P_n = 17.942$ k
 $P_n/\Omega_c = 10.554$ k

Not Req'd

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded Inserts
 $T_{crnmax} = 279$ lbs $Max[F_{pmASD}/4 - OR - F_{hASDtrans}/4 \text{ corner connections}]$
 $V_{crnmax} = 483$ lbs [Max Ten/2 corner connections per side]
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.4
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.553 **O.K.** $StressComb = 0.277$ **O.K.**
***If combined fails: USE --> 2.0

Check 1/8" welded connection

Assume $L/t > 25$: $25 \cdot t = 1.783$ in $\Omega = 2.35$
 $L_{req'd} = 0.327$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____


Client: ProVent PV1805
Project: CBISC-02 Iso Curb (CBISCLXL**) Base curb
Unit: ALL YORK P***B CABINETS

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 50.5 in (Length of curb)
wcurb = 45 in (Width of curb)
WGTCurb = 239 lbs (Weight of curb)
Clips long side = 1 # Clips short side = 1

Unit Information

WGUnit = 420 lbs (Weight of Unit)
Wtmax = 141 lbs (Maximum corner weight)
Wtmin = 78 lbs (Minimum corner weight)
Hunit = 55 in (Height of unit above curb)
Hcm = 27.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 45.75 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1117 lbs (0.7*Fpmax)
FpmaxASD = 1753 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
FhASDtrans = 1056 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
FhASDlong = 942 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 477 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

CompressionSEISMIC = 1040 lbs = [FpmaxASD*Hcm+2*(1+0.14Sds)*Wtmax*wcurb]/wcurb
TensionSEISMIC = 899 lbs = CompSEISMIC-[0.6-0.14Sds]*WGTunit
CompressionWIND = 576 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
TensionWIND = 800 lbs = CompWIND+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

CompressionSEISMIC = 965 lbs = [FpmaxASD*Hcm+2*(1+0.14Sds)*Wtmax*Lcurb]/Lcurb
TensionSEISMIC = 825 lbs = CompSEISMIC-[0.6-0.14Sds]*WGTunit
CompressionWIND = 444 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
TensionWIND = 669 lbs = CompWIND+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	CompMAX = 1040 lbs	----> Along long edge of curb.
(on long edge)	TensMAX = 899 lbs	----> Along long edge of curb.
Longitudinal:	CompMAX = 965 lbs	----> Along short edge of curb.
(on short edge)	TensMAX = 825 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.

San Diego, CA 92120

(619)727-4800

Page ___ of ___

Curb Design

Fy = 50 ksi

Fu = 65 ksi

t = 0.0713 14 Gauge

E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in

B' = 1.750 in

C' = 0.000 in (0 if no lips)

a = 0.000 (0 - no Lip; 1 w/ lip)

R = 0.1069 (Inside bend radius)

t = 0.0713 in

r = 0.143 in = R+t/2

x = 0.104 in (Distance between centroid and web centerline)

Ix = 128.737 in (Moment of Inertia about X-Axis)

Iy = 0.218 in (Moment of Inertia about Y-Axis)

A = 2.01 in²

rx = 8.00 in

ry = 0.329 in

rmin = 0.329 in

a = 24.644 in = A' - (2r+t)

a' = 24.929 in = A' - t


b = 1.572 in = B' - [r+t/2+a(r+t/2)]

b' = 1.714 in = B' - [t/2+at/2]

c = 0.000 in = a[C' - (r+t/2)]

c' = 0.000 in = a[C' - t/2]

u = 0.224 in = $\pi r/2$



Axial Compression

Pu = 0.559 k

(Max Axial Comp)

$\Omega_c = 1.80$

Pn/ Ω_c = 18.917 k

Fe = 19.29 ksi

$\lambda_c = 1.61$

F_n = 16.91 ksi

Ly = 50.50 in

K_yL_y/r_y = 123

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Lateral unbraced length
(assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 25 in

t = 0.0713 in

N = 7.00

$\Omega_w = 1.75$

P_n = 2.105 k

P_n/ Ω_w = 1.203 k

Long side: P_{uTrans} = 1.040 k

Short side: P_{uLong} = 0.965 k

-- Check Limits:

h/t = 350.63 ≤ 200

N/t = 98.18 ≤ 210

N/h = 0.28 ≤ 2.0

R/t = 1.50 ≤ 9.0

C = 4.00

C_R = 0.14

C_N = 0.35

C_h = 0.02

(See table C3.4.1-2, fastened to support, one flange, end loading)

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

O.K. # clips = 1

O.K. # clips = 1

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in

web of stiff. w = 6.717 in

***Check w/ts ≤ 1.28√E/F_y

w/ts = 118.675

1.28√E/F_y = 31.091 --> w/ts over limit Use C3.7.2

P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}

P_{wc} = 2.105 k

P_n = 14.780 k

P_n/ Ω_c = 8.694 k

A_e = 0.380 in²

O.K.

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 279 lbs

V_{crnmax} = 450 lbs

Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)

(Max Ten/2 corner connections per side)

Bolt: Tall = 2480 lbs

Vall = 1096 lbs

Threaded Insert: Tall = 2860 lbs

Vall = 1714 lbs

of Bolts required for Tension = 0.1

of Bolts required for Shear = 0.4

of Bolts Used = 1.0

***If combined fails:

USE --> 4.0

Check Combined Stress in Bolts & Inserts: 0.523 **O.K.**

StressComb = 0.131 **O.K.**



Check 1/8" welded connection

<--- USE WELD

$\Omega = 2.35$

Assume $L/t > 25: 25 \cdot t =$

1.783 in

$L_{req'd} = 0.304$ in

$$P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$$

$$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

Curb Loads (copied from upper rail calcs)

Transverse:	Comp _{MAX} = 1106 lbs
(on long edge)	Tens _{MAX} = 966 lbs
	Shear _{MAX} = 559 lbs
Longitudinal:	Comp _{MAX} = 1018 lbs
(on short edge)	Tens _{MAX} = 877 lbs
	Shear _{MAX} = 559 lbs

Loads at each Isolator

Type: JOA

Transverse loading:	Comp _{MAX} = 1106.4 lbs
(on long edge)	Tens _{MAX} = 966.1 lbs
# isolators: 1	Shear _{MAX} = 558.6 lbs
Longitudinal loading:	Comp _{MAX} = 1017.7 lbs
(on short edge)	Tens _{MAX} = 877.4 lbs
# isolators: 1	Shear _{MAX} = 558.6 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**

Max uplift on isolator: 0.966 k ≤ 1.660 k **O.K.**

Max shear on isolator: 0.559 k ≤ 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in

base curb, $t = 0.0713$ in

Tension = 0.483 k / bolt

Shear = 0.279 k / bolt

Shear on base curb:

$P_n = t e F_u$

$P_n / \Omega = 4.635$ k

Shear O.K.

Net section rupture:

$P_n = A_n F_t$

$P_n / \Omega = 5.909$ k

N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m_t d t F_u$

$P_n / \Omega = 2.781$ k

Bearing O.K.

Shear and tension in bolt:

Tension

$P_{nt} = A_b F_{nt}$

$P_{nt} / \Omega = 3.927$ k

Shear

$P_{nv} = A_b F_{nv}$

$P_{nv} / \Omega = 2.209$ k

$\Omega = 2.00$

(Appendix A, Section E3.1 AISI)

$e = 1.0$ in

$\Omega = 2.22$

(Appendix A, Section E3.2 AISI)

$A_n = 0.107$ in

$F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$ ksi

$\Omega = 2.50$

(Section E3.3.1 AISI)

$d/t = 7.01$

$C = 3.00$

$m_t = 1.00$

(Appendix A, Section E3.4 AISI)

$F_{nt} = 45.0$ ksi

$A_b = 0.1963$ in²

$F_{nv} = 27.0$ ksi

$\Omega_t = 2.25$

$\Omega_v = 2.40$

Bolt tension O.K.

Bolt shear O.K.



[Table E3.4-1, AISI]

$$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

$f_v = 1.42$ ksi

$F_{nv} / \Omega = 11.25$ ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$

WIND: $0.6 D + W$

Transverse:	Uplift _{MAX} = 2242 lbs	Shear _{MAX} = 876 lbs
Compression _{SEISMIC} =	2462 lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) w_{curb}] / w_{curb}$
Tension _{SEISMIC} =	2242 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14 S_{DS}] (WGT_{unit+curb})$
Compression _{WIND} =	1191 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) w_{curb} - F_{vertASD} w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1272 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) w_{curb} + F_{vertASD} w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 2019 lbs	Shear _{MAX} = 876 lbs
Compression _{SEISMIC} =	2240 lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) L_{curb}] / L_{curb}$
Tension _{SEISMIC} =	2019 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14 S_{DS}] (WGT_{unit+curb})$
Compression _{WIND} =	939 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) L_{curb} - F_{vertASD} L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	1020 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) L_{curb} + F_{vertASD} L_{curb} / 2] / L_{curb}$

Wood Attachment:

1/4" ϕ wood lag screws

w/ 3.5" Min. Embed (SGmin = 0.43)

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Tall_{wood} = 671.25 lbs

Vall_{wood} = 224 lbs

Transverse:

of Screws Req'd for Uplift = 3.34

of Screws Req'd for Shear = 3.91

Total # of screws required = 8

COMBINED LOADING: 0.907 O.K.

Req'd Min Spacing = 6.1 in o.c.

Use 8 - 1/4" ϕ wood lag screws @ 6.1 in o.c. along long side of curb w/ 3.5" Min. Embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

Longitudinal:

of Screws Req'd for Uplift = 3.01
of Screws Req'd for Shear = 3.91
Total # of screws required = 8

COMBINED LOADING: 0.865 O.K.
Screw Spacing = 5.3 in o.c.

Use 8 - 1/4" ϕ wood lag screws @ 5.3 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 6903 lbs
6903 lbs

Vall_{bolt} = 3682 lbs
3682 lbs

of Bolts Req'd for Uplift = 0.32
of Bolts Req'd for Shear = 0.24
Total # of bolts required = 2

COMBINED LOADING: 0.281 O.K.
Bolt Spacing = 38.5 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 38.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.29
of Bolts Req'd for Shear = 0.24
Total # of bolts required = 2

COMBINED LOADING: 0.265 O.K.
Bolt Spacing = 33.0 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 33 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Q_eE (Q_e = 2.5)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs (D = 0.465, E = 0.535)

Transverse: Uplift_{MAX} = 5310 lbs Shear_{MAX} = 2191 lbs

Compression_{SEISMIC} = 5530 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 5310 lbs = $Comp_{SEISMIC} - (0.6 - 0.14SDS) \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 2191 lbs = $2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 5.17 spacing = 5.30 in o.c. T_{applied} = 885.0 lbs

Min Bolts Req'd Shear = 1.29 spacing = 26.5 in o.c. V_{applied} = 365.2 lbs

Try using 6 bolts
spaced at 7.70 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.08$

Use 6 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.7 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 4753 lbs Shear_{MAX} = 2191 lbs

Compression_{SEISMIC} = 4973 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 4753 lbs = $Comp_{SEISMIC} - (0.6 - 0.14SDS) \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 2191 lbs = $2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 4.63 spacing = 5.25 in o.c. T_{applied} = 792.2 lbs

Min Bolts Req'd Shear = 1.29 spacing = 21 in o.c. V_{applied} = 365.2 lbs

Try using 6 bolts
spaced at 6.60 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.99$

Use 6 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.6 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: (CBISCLXL** (CBISCLXL** Unit: ALL YORK P***B CABINETS			
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQA Top stud diameter: 3/8			
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	8 @ 6.07 in o.c.	2 @ 38.5 in o.c.	6 @ 7.7 in o.c.
SHORT DIRECTION	8 @ 5.29 in o.c.	2 @ 33 in o.c.	6 @ 6.6 in o.c.