



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

## **Structural Calculations**

**for**

**CBISC-05 Series**

**CBISCPRS\*\* Curb**



**Prepared for:**

**PROVENT / RRS**

**3847 Wabash Drive  
Mira Loma, CA 91725**

**Date: April 2, 2021**

**Project Number: PV2101**

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

**FEATURES**


- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

**NOTES**

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.

**STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR YORK UNITS**

ZX 04-07; XX A7, ZX A7, ZY, ZQ, XY, XQ 04-06




PROVENT P/N	A	B	EST. WEIGHT
CBISPRS18**	8"	18"	305 Lbs.
CBISPRS21**	11"	21"	320 Lbs.
CBISPRS24**	14"	24"	335 Lbs.



\*\*Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:  
CBC 2019  
IBC 2018

(4) #10 TEK SCREWS



**PROFILE DETAIL**



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBISC-05


DATE:  
4/2/2021

PART NUMBER:

REV:  
2

DRAWN BY:  
ALL

**STEEL ATTACHMENT**



**NO. OF ANCHORAGE BOLTS REQUIRED**


CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 38.5" O.C.	2 @ 23" O.C.
LXL	2 @ 38.5" O.C.	2 @ 33" O.C.
SUN3672	2 @ 63" O.C.	2 @ 27.25" O.C.
PRD3715	3 @ 35.69" O.C.	2 @ 41.5" O.C.
PRS	2 @ 61.38" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	3 @ 58.13" O.C.	3 @ 37" O.C.
SLM1830	4 @ 38.75" O.C.	3 @ 37" O.C.

**ASSUMES:**

CONC SLAB  
 $f_c = 4000$ PSI MINIMUM  
 6" MIN THICKNESS  
 NORMAL WEIGHT CONCRETE  
 OR SAND LIGHT WEIGHT

**CONCRETE ATTACHMENT**

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED


**NO. OF ANCHORAGE BOLTS REQUIRED**

CURB	LONG SIDE	SHORT SIDE
LXS	9 @ 4.81" O.C.	6 @ 4.6" O.C.
LXL	8 @ 5.5" O.C.	7 @ 5.5" O.C.
SUN3672	9 @ 7.88" O.C.	5 @ 6.81" O.C.
PRD3715	18 @ 4.2" O.C.	12 @ 3.77" O.C.
PRS	11 @ 6.14" O.C.	7 @ 5.19" O.C.
PRL	14 @ 5.56" O.C.	10 @ 4.89" O.C.
SLU180	18 @ 6.84" O.C.	13 @ 6.17" O.C.
SLM1830	23 @ 5.28" O.C.	16 @ 4.93" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
 \*\* CENTERED.

**WOOD ATTACHMENT**

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø SIMPSON SDS OR EQUIVALENT SCREWS (3 1/2" MIN. EMBED. INTO WOOD FRAMING)

5/8" Ø LAG SCREW W/MIN. 3.5" EMBED (SGMIN=0.43) (FOR MIL SERIES ONLY)

**NO. OF ANCHORAGE SCREWS REQUIRED**

CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	6 @ 7.4" O.C.
SUN3672	8 @ 9.57" O.C.	5 @ 7.81" O.C.
PRD3715	16 @ 5.03" O.C.	11 @ 4.55" O.C.
PRS	10 @ 7.26" O.C.	7 @ 5.88" O.C.
PRL	13 @ 6.35" O.C.	9 @ 6" O.C.
SLU180	18 @ 7.07" O.C.	13 @ 6.5" O.C.
SLM1830	23 @ 5.47" O.C.	17 @ 4.88" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED

Meets seismic requirements for the following codes:  
 CBC 2019  
 IBC 2018

ROOF ANCHORAGE DETAIL

**CBISC Series**

LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830



3847 WABASH DRIVE  
 MIRA LOMA, CA 91725

PHONE (951) 685-1101  
 FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_  
 JOB NAME: \_\_\_\_\_  
 EQUIPMENT: \_\_\_\_\_  
 NOTES: \_\_\_\_\_

FORM NO:

CB-62

DATE:  
 3/30/2021

REV:  
 -

DRAWN BY:  
 ALL




Client:	ProVent PV2101	Previous:	PV1805
Project:	CBISC-05 Iso Curb	CBISCPRS	Upper curb rail
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06		

**Curb Information**

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	70.375 in	(Length of curb)
wcurb =	40.1875 in	(Width of curb)
WGTcurb =	335 lbs	(Weight of curb)
# Clips long side =	3	# Clips short side = 2

**Unit Information**

WGTunit =	787 lbs	(Weight of Unit)
Wtmax =	243 lbs	(Maximum corner weight)
Wtmin =	151 lbs	(Minimum corner weight)
Hunit =	40.56 in	(Height of unit above curb)
Hcm =	20.28 in	(Height to center of mass)
Lunit =	74.05 in	(Length of unit)
Wunit =	48.88 in	(Width of unit)



**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2826 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 4029 lbs
		(unit and curb)

**Wind Loading - 2018 IBC/2019 CBC**

Kz =	1.13	*** Exposure Category C ***
Kzt =	1.00	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kd =	0.85	(Max. assumed topographic factor)
Ke =	1.00	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	110	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
GCr (horiz) =	1.9	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr (vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	803 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	530 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	673 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Curb Loading**

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	2145 lbs	= [FpmaxASD*Hcm+2*(1+0.14SDS)*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	2049 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14SDS)*WGTunit
Compression <sub>WIND</sub> =	360 lbs	= [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	561 lbs	= Comp <sub>WIND</sub> +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	1533 lbs	= [FpmaxASD*Hcm+2*(1+0.14SDS)*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	1438 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14SDS)*WGTunit
Compression <sub>WIND</sub> =	108 lbs	= [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	309 lbs	= Comp <sub>WIND</sub> +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

**Governing Reactions:**

<b>Transverse:</b>		
(on long edge)	Comp <sub>MAX</sub> = 2145 lbs	---> Along long edge of curb.
	Tens <sub>MAX</sub> = 2049 lbs	---> Along long edge of curb.
<b>Longitudinal:</b>		
(on short edge)	Comp <sub>MAX</sub> = 1533 lbs	---> Along short edge of curb.
	Tens <sub>MAX</sub> = 1438 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




**Curb Design**

Fy = 50 ksi      Fu = 65 ksi      t = 0.0713 14 Gauge  
E = 29500 ksi

**Calculate Section Properties of Curb**

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in (Distance between centroid and web centerline)	
Ix = 2.424 in (Moment of Inertia about X-Axis)	
Iy = 0.109 in (Moment of Inertia about Y-Axis)	
A = 0.59 in <sup>2</sup>	
rx = 2.03 in	
ry = 0.432 in	
rmin = 0.432 in	



**Axial Compression**

Pu = 1.413 k (Max Axial Comp)      Ωc = 1.80  
Pn/Ωc = 4.894 k  
Fe = 17.11 ksi  
λc = 1.71      If λc ≤ 1.5; F<sub>n</sub> = (0.658λ<sup>2</sup>)F<sub>y</sub>      λc =  $\sqrt{\frac{F_y}{F_e}}$       F<sub>e</sub> =  $\frac{\pi^2 E}{(kl/r)^2}$   
If λc > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$   
Fn = 15.00 ksi  
Ly = 70.38 in      Lateral unbraced length (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	C <sub>R</sub> = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C <sub>N</sub> = 0.12	
Ω <sub>w</sub> = 1.75	N/h = 1.273 ≤ 2.0	C <sub>h</sub> = 0.048	
P <sub>n</sub> = 1.947 k	R/t = 1.50 ≤ 12.0		
P <sub>n</sub> /Ω <sub>w</sub> = 1.112 k			
Long side: Pu <sub>trans</sub> = 0.715 k	<b>O.K.</b> # clips = 3	$P_n = C t^2 F_y \sin(90) \left( 1 - C_R \frac{R}{t} \right) \left( 1 + C_N \frac{N}{t} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$	
Short side: Pu <sub>long</sub> = 0.767 k	<b>O.K.</b> # clips = 2		

**Check Web Stiffener**      N/A

width of stiffener = 7.000 in      ts = 0.0566 16 Gauge  
web of stiff. w = 6.717 in      Rs = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28VE/Fys      Ωc = 1.70  
w/ts = 118.675  
1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>      Ae = 0.380 in<sup>2</sup>  
P<sub>wc</sub> = 1.947 k  
P<sub>n</sub> = 14.669 k  
P<sub>n</sub>/Ω<sub>c</sub> = 8.629 k      **Not Req'd**

**Corner Connections**      1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 707 lbs      Max[F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections]  
V<sub>crnmax</sub> = 1025 lbs      (Max Ten/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1096 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1714 lbs  
# of Bolts required for Tension = 0.3  
# of Bolts required for Shear = 0.9      \*\*\*If combined fails:  
# of Bolts Used = 1.0      USE --> 3.0  
Check Combined Stress in Bolts & Inserts: 1.220 N.G.      StressComb = 0.407 **O.K.**

**Check 1/8" welded connection**

<--- USE WELD      Ω = 2.35  
Assume L/t > 25\*t = 1.783 in      P<sub>n</sub>/Ω =  $\frac{1}{\Omega} 0.75tL F_u \geq V_{req}$       L<sub>req</sub>'d =  $\frac{V_{req} \Omega}{0.75t F_u}$   
L<sub>req</sub>'d = 0.693 in



**Connection Unit to Curb Clip** #10 SMS screw  $\Omega = 3.0$


$t_1 = 0.0713$  in (clip thickness)  $F_{u1} = 65$  ksi  
 $t_2 = 0.1017$  in (unit base rail thickness)  $F_{u2} = 65$  ksi  
 $d = 0.190$  in (screw diameter)  $d_w = 0.375$  in (nom. washer diameter)  
 $t_2/t_1 = 1.4$

For  $t_2/t_1 \leq 1.0$ :  $P_{ns} = 2377$  # For  $t_2/t_1 \geq 2.5$ :  $P_{ns} = 2377$  #  
**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^2d} = 3.86$  k  $P_{ns} = 2.7t_1dF_{u1} = 2.38$  k  
 $P_{ns} = 2.7t_2dF_{u2} = 3.39$  k  $P_{ns} = 2.7t_2dF_{u2} = 3.39$  k  
 $P_{ns}/\Omega = 792$  #

**Tension:**  $P_{not} = 1.068$  k (screw pull-out strength)  $P_{not} = 0.85t_c d F_{u2}$   
 $P_{nov} = 2.607$  k (screw pull-over strength)  $t_c = \min(t_1, t_2)$   
 $P_{ts}/\Omega = 356$  # <- Controls  $P_{nov} = 1.5t_1 d_w F_{u1}$   
 $P_{ts}/\Omega = 820$  # (full tensile screw capacity)

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	2.826	3	0.94	540 #	4	2.00 in
Short side:	2.826	2	1.41	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in  
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)  
Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies  
 $F_y = 50$  ksi  $\Omega = 2.22$  bolt/screw connection  
 $A_{gv} = 0.463$  in<sup>2</sup>  $A_{nv} = 0.416$  in<sup>2</sup>  $A_{nt} = 0.082$  in<sup>2</sup>  
 $R_n/\Omega = 8.674$  k  $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$  (AISI Sect. E5.3)



**Curb Loads** (copied from above)

Transverse: (on long edge)	Comp <sub>MAX</sub> = 2145 lbs
	Tens <sub>MAX</sub> = 2049 lbs
	Shear <sub>MAX</sub> = 1413 lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> = 1533 lbs
	Tens <sub>MAX</sub> = 1438 lbs
	Shear <sub>MAX</sub> = 1413 lbs


**Loads at each Isolator** Type: JQA

Transverse loading: (on long edge)	Comp <sub>MAX</sub> = 1072.4 lbs
	Tens <sub>MAX</sub> = 1024.7 lbs
	Shear <sub>MAX</sub> = 706.5 lbs
Longitudinal loading: (on short edge)	Comp <sub>MAX</sub> = 766.6 lbs
	Tens <sub>MAX</sub> = 718.9 lbs
	Shear <sub>MAX</sub> = 706.5 lbs

Max compression force on isolator: 1.072 k  $\leq 1.660$  k **O.K.**  
Max uplift on isolator: 1.025 k  $\leq 1.660$  k **O.K.**  
Max shear on isolator: 0.707 k  $\leq 0.800$  k **O.K.**

**Forces on top bolt:**

$d_b = 0.375$  in  
upper rail, t = 0.1017 in  
Tension = 1.025 k  
Shear = 0.707 k



**Shear on curb rail:**  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n/\Omega = 6.611$  k  $e = 1.0$  in

**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n/\Omega = 7.117$  k  $A_n = 0.165$  in

**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $F_t = (0.1 + 3d/s) F_u \leq F_u = 43.063$  ksi  
 $P_n/\Omega = 2.975$  k  $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $d/t = 3.69$   
 $C = 3.00$   $m_f = 1.00$

**Bearing O.K.**

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>  
 $P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega_t = 2.25$  (Table E3.4-1, AISI)  
Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega_v = 2.40$  (Table E3.4-1, AISI)  
 $P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 9.28$  ksi  $f_v = 6.40$  ksi **O.K.**  
 $F'_{nt} = 26.74$  ksi  $F_{nv}/\Omega = 10.00$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt}/\Omega = 1.313$  k **Combined O.K.**




Client:	ProVent PV2101	Previous:	PV1805
Project:	CBISC-05 Iso Curb	CBISCPRS	Base curb
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06		

**Curb Information**

Hcurb =	25	in	(Height of curb)
Lcurb =	73.375	in	(Length of curb)
wcurb =	43.125	in	(Width of curb)
WGTCurb =	335	lbs	(Weight of curb)
# Springs long side =	2	# Springs short side =	2

**Unit Information**

WGTunit =	787	lbs	(Weight of Unit)
WTmax =	243	lbs	(Maximum corner weight)
Wtmin =	151	lbs	(Minimum corner weight)
Hunit =	40.56	in	(Height of unit above curb)
Hcm =	20.28	in	(Height to center of mass)
Lunit =	74.05	in	(Length of unit)
Wunit =	48.88	in	(Width of unit)



**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	2826	lbs
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	4029	lbs
	(unit and curb)	

**Wind Loading - 2018 IBC/2019 CBC**

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr <sub>(horiz)</sub> =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr <sub>(vert)</sub> =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf = 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
F <sub>h</sub> ASD trans =	1143	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F <sub>h</sub> ASD long =	755	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F <sub>vert</sub> ASD =	673	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Curb Loading**

**Transverse:**

Compression <sub>SEISMIC</sub> =	2048	lbs	= [FpmaxASD*Hcm + 2*(1+0.14*SDS)*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	1952	lbs	= Comp <sub>SEISMIC</sub> - [0.6-0.14*SDS]*WGTunit
Compression <sub>WIND</sub> =	493	lbs	= [F <sub>h</sub> transASD*Hcm + 2*0.6*Wtmax*wcurb - F <sub>vert</sub> ASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	694	lbs	= Comp <sub>WIND</sub> + F <sub>vert</sub> - 0.6*WGTunit

----> Negative values indicate opposite load.

**Longitudinal:**

Compression <sub>SEISMIC</sub> =	1500	lbs	= [FpmaxASD*Hcm + 2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	1404	lbs	= Comp <sub>SEISMIC</sub> - [0.6-0.14*SDS]*WGTunit
Compression <sub>WIND</sub> =	164	lbs	= [F <sub>h</sub> transASD*Hcm + 2*0.6*Wtmax*Lcurb - F <sub>vert</sub> ASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	365	lbs	= Comp <sub>WIND</sub> + F <sub>vert</sub> - 0.6*WGTunit

----> Negative values indicate opposite load.

**Governing Reactions:**

<b>Transverse:</b>	Comp <sub>MAX</sub> =	2048	lbs	----> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	1952	lbs	----> Along long edge of curb.
<b>Longitudinal:</b>	Comp <sub>MAX</sub> =	1500	lbs	----> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	1404	lbs	----> Along short edge of curb.

----> Negative values indicate opposite load.






**Curb Design**

Fy = 50 ksi      Fu = 65 ksi      t = 0.0713 14 Gauge  
E = 29500 ksi

**Calculate Section Properties of Curb**

A' = 25.000 in	a = 24.644 in = A' - (2r+t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in (Moment of Inertia about X-Axis)	
Iy = 0.218 in (Moment of Inertia about Y-Axis)	
A = 2.01 in <sup>2</sup>	
rx = 8.00 in	
ry = 0.329 in	
rmin = 0.329 in	



**Axial Compression**

Pu = 1.413 k (Max Axial Comp)      Ωc = 1.80  
Pn/Ωc = 8.960 k  
Fe = 9.14 ksi       $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$       If λc ≤ 1.5; Fn = (0.658λc<sup>2</sup>)Fy  
λc = 2.34      If λc > 1.5; Fn =  $\frac{0.877}{\lambda_c^2} F_y$       λc =  $\sqrt{\frac{F_y}{F_e}}$       Fe =  $\frac{\pi^2 E}{(kl/r)^2}$   
Fn = 8.01 ksi      Lateral unbraced length  
Ly = 73.38 in      (assume k=0.8)  
kyLy/ry = 179

**Compression Check = O.K.**

**Check Web Crippling**

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	CR = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.28 ≤ 2.0	Ch = 0.02	
Pn = 2.105 k	R/t = 1.50 ≤ 9.0		
Pn/Ωw = 1.203 k			
Long side: PuTrans = 1.024 k	<b>O.K.</b> : springs = 2	$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: PuLong = 0.750 k	<b>O.K.</b> : springs = 2		

**\*\*\*h/t > 200; use web stiffeners**

**Check Web Stiffener**

16Ga x 1.5in x 7in (C-channel)  
width of stiffener = 7.000 in      ts = 0.0566 16 Gauge  
web of stiff. w = 6.717 in      Rs = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28√E/Fys      Ωc = 1.70  
w/ts = 118.675  
1.28√(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2  
Pn = 0.7(Pwc + AeFy) ≥ Pwc      Ae = 0.380 in<sup>2</sup>  
Pwc = 2.105 k  
Pn = 14.780 k  
Pn/Ωc = 8.694 k      **O.K.**

**Corner Connections**      1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 707 lbs      Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)  
Vcrnmax = 976 lbs      (Max Ten/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1096 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1714 lbs  
# of Bolts required for Tension = 0.3  
# of Bolts required for Shear = 0.9      \*\*\*If combined fails:  
# of Bolts Used = 1.0      USE --> 3.0  
Check Combined Stress in Bolts & Inserts: 1.176 **N.G.**      StressComb = 0.392 **O.K.**





**Check 1/8" welded connection**

Assume  $L/t > 25$ :  $25 * t = 1.783$  in  
 $L_{req'd} = 0.660$  in  
 $\Omega = 2.35$   
 $P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$   
 $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

**Curb Loads** [copied from upper rail calcs]

Transverse: (on long edge)	Comp <sub>MAX</sub> = 2145 lbs
	Tens <sub>MAX</sub> = 2049 lbs
	Shear <sub>MAX</sub> = 1413 lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> = 1533 lbs
	Tens <sub>MAX</sub> = 1438 lbs
	Shear <sub>MAX</sub> = 1413 lbs

**Loads at each Isolator** Type: **JQA**

Transverse loading: (on long edge) # isolators: 2	Comp <sub>MAX</sub> = 1072.4 lbs
	Tens <sub>MAX</sub> = 1024.7 lbs
	Shear <sub>MAX</sub> = 706.5 lbs
Longitudinal loading: (on short edge) # isolators: 2	Comp <sub>MAX</sub> = 766.6 lbs
	Tens <sub>MAX</sub> = 718.9 lbs
	Shear <sub>MAX</sub> = 706.5 lbs

Max compression force on isolator: 1.072 k ≤ 1.660 k **O.K.**  
 Max uplift on isolator: 1.025 k ≤ 1.660 k **O.K.**  
 Max shear on isolator: 0.707 k ≤ 0.800 k **O.K.**

**Forces on bottom bolts:**

$d_b = 0.5$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 0.512 k / bolt  
 Shear = 0.353 k / bolt



**Shear on base curb:**  $P_n = t e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n / \Omega = 4.635$  k  $e = 1.0$  in  
**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n / \Omega = 5.909$  k  $A_n = 0.107$  in  
 $F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$  ksi  
**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n / \Omega = 2.781$  k  $d/t = 7.01$   
 $C = 3.00$   $m_f = 1.00$   
**Bearing O.K.**

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)  
 Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt} / \Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$   
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv} / \Omega = 2.209$  k **Bolt shear O.K.** **\*\*\*[Table E3.4-1, AISI]\*\*\***

**Combined Shear and tension in bolt:**  
 $F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nv}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 5.22$  ksi  $f_v = 1.80$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv} / \Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$   $P'_{nt} / \Omega = 3.927$  k **Combined Not Applicable -> F'nt = Fnt**



**Connection of Curb to Supporting Structure**

**Roof Loading** SEISMIC:  $(0.6-0.14S_{DS})D + 0.7E$  WIND:  $0.6D + W$

Transverse:	Uplift <sub>MAX</sub> = 4924 lbs	Shear <sub>MAX</sub> = 2015 lbs
Compression <sub>SEISMIC</sub> =	5060 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$
Tension <sub>SEISMIC</sub> =	4924 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Compression <sub>WIND</sub> =	1201 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * w_{curb} - F_{vertASD} * w_{curb} / 2] / w_{curb}$
Tension <sub>WIND</sub> =	1201 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * w_{curb} + F_{vertASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift <sub>MAX</sub> = 3180 lbs	Shear <sub>MAX</sub> = 2015 lbs
Compression <sub>SEISMIC</sub> =	3316 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$
Tension <sub>SEISMIC</sub> =	3180 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Compression <sub>WIND</sub> =	466 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * L_{curb} - F_{vertASD} * L_{curb} / 2] / L_{curb}$
Tension <sub>WIND</sub> =	466 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * L_{curb} + F_{vertASD} * L_{curb} / 2] / L_{curb}$

**Wood Attachment:** 1/4" φ x 3.5" Simpson SDS screw w/ 2.25" threaded emt (SGmin = 0.43)

Tall <sub>metal</sub> = 946.67 lbs	Vall <sub>metal</sub> = 1043.33 lbs
Transverse: Tall <sub>wood</sub> = 616 lbs	Vall <sub>wood</sub> = 672 lbs
# of Screws Req'd for Uplift = 7.99	COMBINED LOADING: 0.976 O.K.
# of Screws Req'd for Shear = 3.00	Req'd Min Spacing = 7.3 in o.c.
Total # of screws required = 10	

Use 10 - 1/4" φ x 3.5" Simpson SDS screws @ 7.3 in o.c. along long side of curb w/ 2.25" threaded embed



Longitudinal:

# of Screws Req'd for Uplift = 5.16  
# of Screws Req'd for Shear = 3.00  
Total # of screws required = 7

COMBINED LOADING: 0.914 O.K.  
Screw Spacing = 5.9 in o.c.

Use 7 - 1/4" φ x 3.5" Simpson SDS screws @ 5.9 in o.c. along short side of curb w/ 2.25" threaded embed

**Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck**

Tall<sub>bolt</sub> = 4418 lbs  
Transverse: 4418 lbs

Vall<sub>bolt</sub> = 2356 lbs  
2356 lbs

# of Bolts Req'd for Uplift = 1.11  
# of Bolts Req'd for Shear = 0.86  
Total # of bolts required = 2

COMBINED LOADING: 0.985 O.K.  
Bolt Spacing = 61.4 in o.c.

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 61.4 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 0.72  
# of Bolts Req'd for Shear = 0.86  
Total # of bolts required = 2

COMBINED LOADING: 0.787 O.K.  
Bolt Spacing = 31.1 in o.c.

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 31.1 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14SDS)D + 0.7Ω<sub>o</sub>E (Ω<sub>o</sub> = 2.5)

**Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed**

Tall<sub>LRFD</sub> = 1919 lbs Vall<sub>LRFD</sub> = 3188 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87  
Tall<sub>ASD</sub> = Tall<sub>LRFD</sub>/α = 1026.2 lbs Vall<sub>ASD</sub> = Vall<sub>LRFD</sub>/α = 1704.8 lbs (D = 0.465, E = 0.535)

Transverse: Uplift<sub>MAX</sub> = 11270 lbs Shear<sub>MAX</sub> = 5036 lbs

Compression<sub>SEISMIC</sub> = 11406 lbs = [2.5 \* F<sub>pmaxASD</sub> \* (H<sub>cm</sub> + H<sub>curb</sub>) + (1 + 0.14S<sub>DS</sub>) \* (WGT<sub>unit+curb</sub>/2) \* w<sub>curb</sub>] / w<sub>curb</sub>

Tension<sub>SEISMIC</sub> = 11270 lbs = Comp<sub>SEISMIC</sub> - (0.6 - 0.14S<sub>DS</sub>) \* (WGT<sub>unit+curb</sub>)

Shear<sub>SEISMIC</sub> = 5036 lbs = 2.5 \* F<sub>pmaxASD</sub> / 2

Min Bolts Req'd Uplift = 10.98 spacing = 6.14 in o.c. T<sub>applied</sub> = 1024.5 lbs

Min Bolts Req'd Shear = 2.95 spacing = 30.6875 in o.c. V<sub>applied</sub> = 279.8 lbs

Try using 11 bolts spaced at 6.14 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$

Use 11 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.1 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift<sub>MAX</sub> = 6910 lbs Shear<sub>MAX</sub> = 5036 lbs

Compression<sub>SEISMIC</sub> = 7046 lbs = [2.5 \* F<sub>pmaxASD</sub> \* (H<sub>cm</sub> + H<sub>curb</sub>) + (1 + 0.14S<sub>DS</sub>) \* (WGT<sub>unit+curb</sub>/2) \* L<sub>curb</sub>] / L<sub>curb</sub>

Tension<sub>SEISMIC</sub> = 6910 lbs = Comp<sub>SEISMIC</sub> - (0.6 - 0.14S<sub>DS</sub>) \* (WGT<sub>unit+curb</sub>)

Shear<sub>SEISMIC</sub> = 5036 lbs = 2.5 \* F<sub>pmaxASD</sub> / 2

Min Bolts Req'd Uplift = 6.73 spacing = 5.1875 in o.c. T<sub>applied</sub> = 987.1 lbs

Min Bolts Req'd Shear = 2.95 spacing = 15.5625 in o.c. V<sub>applied</sub> = 279.8 lbs

Try using 7 bolts spaced at 5.19 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.13$

Use 7 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-05	CBISCPRS	Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06
UPPER CURB RAIL THICKNESS:		0.0713 in	14 Gauge		
UNIT CLIP THICKNESS:		0.0713 in	14 Gauge		
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: NOT REQUIRED					
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: NOT REQUIRED					
VIBRATION ISOLATOR TYPE:		JQA	Top stud diameter: 3/8	(2) - JQA Isolators long side	
			Anchor bolt diameter: 1/2	Anchor hole diameter: 9/16	(2) - JQA Isolators short side
BASE CURB THICKNESS:		0.0713 in	14 Gauge		
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
CORNER CONNECTION: Use minimum 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
CURB ANCHORAGE	WOOD	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed (SG <sub>min</sub> =		STEEL	1/2" φ A307 Bolts to steel angle below deck
	CONCRETE				3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION		10 @ 7.26 in o.c.			2 @ 61.38 in o.c.
SHORT DIRECTION		7 @ 5.85 in o.c.			11 @ 6.14 in o.c.
					7 @ 31.13 in o.c.
					7 @ 5.19 in o.c.