



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBISC-06 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1805

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-60.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

FEATURES



- Roof curbs sides and ends are 12 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES


- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or ProVent directly.

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR YORK UNITS

ZX08-14; XX08-12; ZY07-12; XY07-09



PROFILE DETAIL



PROVENT P/N	A	B	EST. WEIGHT
CBISCPRL18**	8"	18"	380 Lbs.
CBISCPRL21**	11"	21"	405 Lbs.
CBISCPRL24**	14"	24"	425 Lbs.

**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBISC-06


DATE:
9/27/2018

PART NUMBER:

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL

WELDMENT AND BOLTING DETAIL




BASE CURB SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL




Client: ProVent PV1805
Project: CBISC-06 Iso Curb (CBISCPR1**) Upper curb rail
Unit: ZX 08-14; XX 08-12; ZY 07-12; XY 07-09

Curb Information

Hcurb upper = 5.5 in (Height of upper curb rail)
Lcurb = 84 in (Length of curb)
wcurb = 53 in (Width of curb)
WGTcurb = 425 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 2

Unit Information

WGTunit = 1167 lbs (Weight of Unit)
Wtmax = 359 lbs (Maximum corner weight)
Wtmin = 211 lbs (Minimum corner weight)
Hunit = 48.56 in (Height of unit above curb)
Hcm = 24.28 in (Height to center of mass)
Lunit = 87.18 in (Length of unit)
Wunit = 61.69 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp [1.6*Sds*Ip]*Wp
FpmaxASD = 3104 lbs [0.7*Fpmax] FpmaxASD = 4235 lbs (unit and curb)
[unit only]

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(henz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
Fh ASD trans = 1213 lbs
Fh ASD long = 859 lbs
Fvert ASD = 1093 lbs
= 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) [Eq. 29.5-2]
= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression_{SEISMIC} = 2330 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1940 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 440 lbs = [F_{h trans ASD}*Hcm+2*0.6*Wtmax*wcurb-F_{vert ASD}*wcurb/2]/wcurb
Tension_{WIND} = 832 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1805 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1415 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 132 lbs = [F_{h trans ASD}*Hcm+2*0.6*Wtmax*Lcurb-F_{vert ASD}*Lcurb/2]/Lcurb
Tension_{WIND} = 525 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 2330 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1940 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1805 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1415 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.1017$ 12 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 5.500$ in $a = 4.992$ in $= A' - [2r + t]$
 $B' = 1.500$ in $a' = 5.398$ in $= A' - t$
 $C' = 0.000$ in [0 if no lips] $b = 1.246$ in $= B' - [r + t/2 + a(r + t/2)]$
 $a = 0.000$ in [0 - no Lip; 1 w/ lip] $b' = 1.449$ in $= B' - [t/2 + at/2]$
 $R = 0.1525$ (Inside bend radius) $c = 0.000$ in $= a[C' - (r + t/2)]$
 $t = 0.1017$ in $c' = 0.000$ in $= a[C' - t/2]$
 $r' = 0.203$ in $= R + t/2$ $u = 0.319$ in $= \pi r/2$
 $x = 0.259$ in [Distance between centroid and web centerline]
 $I_x = 3.349$ in [Moment of Inertia about X-Axis]
 $I_y = 0.151$ in [Moment of Inertia about Y-Axis]
 $A = 0.83$ in²
 $r_x = 2.01$ in
 $r_y = 0.427$ in
 $r_{min} = 0.427$ in



Axial Compression

$P_u = 1.552$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 4.739$ k
 $F_e = 11.77$ ksi
 $\lambda_c = 2.06$
 $F_n = 10.33$ ksi
 $L_y = 84.00$ in
 $k_y L_y/r_y = 157$

If $\lambda_c \leq 1.5$: $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$: $F_n = \frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length
(assume $k=0.8$)

Compression Check = O.K.

Check Web Crippling

$h = 5.5$ in
 $t = 0.1017$ in
 $N = 7.00$
 $\Omega_{wc} = 1.75$
 $P_n = 4.038$ k
 $P_n/\Omega_{wc} = 2.308$ k
Long side: $P_{u,trans} = 1.165$ k
Short side: $P_{u,long} = 0.903$ k

-- Check limits:

$h/t = 54.08 \leq 200$
 $N/t = 68.83 \leq 210$
 $N/h = 1.273 \leq 2.0$
 $R/t = 1.50 \leq 12.0$

$C = 7.50$
 $C_R = 0.08$
 $C_N = 0.12$
 $C_h = 0.048$

[See table C3.4.1-2, fastened to support, two flange, end loading]

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

O.K. # clips = 2
O.K. # clips = 2

Check Web Stiffener

N/A
width of stiffener = 7.000 in
web of stiff. $w = 6.717$ in
***Check $w/ts \leq 1.28\sqrt{E/F_y}$
 $w/ts = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/ts over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_s F_y) \geq P_{wc}$
 $P_{wc} = 4.038$ k
 $P_n = 16.133$ k
 $P_n/\Omega_c = 9.490$ k
 $A_e = 0.380$ in²

Not Req'd

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded Inserts
 $T_{crnmax} = 776$ lbs $\text{Max}[F_{tmaxASD}/4 \text{ -OR- } F_{hASDtrans}/4 \text{ corner connections}]$
 $V_{crnmax} = 970$ lbs $[\text{Max Ten}/2 \text{ corner connections per side}]$
Bolt: Tall = 2480 lbs Tall = 2860 lbs
Threaded Insert: Tall = 1096 lbs Tall = 1714 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 0.9
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 1.198 N.G. StressComb = 0.599 O.K.

***If combined fails: USE --> 2.0

Check 1/8" welded connection

Assume $L/t > 25$: $25 \cdot t = 2.543$ in $\Omega = 2.35$
 $L_{req'd} = 0.460$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.1017$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 2377$ # $P_{ns} = 2377$ #
 Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k


$P_{ns}/\Omega = 792$ #
 $P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 356$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side: 3.104	2	1.55	540 #	4	2.00 in
Short side: 3.104	2	1.55	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
 min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)
 Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies
 $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.463$ in² $A_{nv} = 0.416$ in² $A_{nt} = 0.082$ in²
 $R_n/\Omega = 8.676$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]

BSR O.K.



Curb Loads (copied from above)

Transverse: (on long edge)	Comp _{MAX} = 2330 lbs Tens _{MAX} = 1940 lbs Shear _{MAX} = 1552 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1805 lbs Tens _{MAX} = 1415 lbs Shear _{MAX} = 1552 lbs

Max compression force on isolator: 1.165 k ≤ 1.660 k **O.K.**
 Max uplift on isolator: 0.970 k ≤ 1.660 k **O.K.**
 Max shear on isolator: 0.776 k ≤ 0.800 k **O.K.**

Forces on top bolt:

$d_b = 0.375$ in
 upper rail, $t = 0.1017$ in
 Tension = 0.970 k
 Shear = 0.776 k

Shear on curb rail:

$P_n = teF_u$ $\Omega = 2.00$ [Appendix A, Section E3.1 AISI]
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ [Appendix A, Section E3.2 AISI]
 $P_n/\Omega = 7.117$ k $A_n = 0.165$ in

N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m f d t F_u$ $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi
 $P_n/\Omega = 2.975$ k $\Omega = 2.50$ [Section E3.3.1 AISI]
 $d/t = 3.69$
 $C = 3.00$ $m f = 1.00$

Bearing O.K.

Shear and tension in bolt:


Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ [Table E3.4-1, AISI]
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ [Table E3.4-1, AISI]
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_p \leq F_{nt}$$

Combined Not Applicable

$F'_{nt} = 24.19$ ksi

$f_v = 7.03$ ksi **O.K.**
 $F_{nv}/\Omega = 10.00$ ksi






Client: ProVent PV1805
Project: CBISC-06 Iso Curb (CBISCPRL**) Base curb
Unit: ZX 08-14; XX 08-12; ZY 07-12; XY 07-09

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 84.25 in (Length of curb)
wcurb = 56 in (Width of curb)
WGTcurb = 425 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 2

Unit Information

WGUnit = 1167 lbs (Weight of Unit)
Wtmax = 359 lbs (Maximum corner weight)
Wtmin = 211 lbs (Minimum corner weight)
Hunit = 48.56 in (Height of unit above curb)
Hcm = 24.28 in (Height to center of mass)
Lunit = 87.18 in (Length of unit)
Wunit = 61.69 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 3104 lbs (0.7*Fpmax) FpmaxASD = 4235 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
Fh ASD trans = 1651 lbs
Fh ASD long = 1168 lbs
Fvert ASD = 1093 lbs
= 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 2254 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1864 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGUnit
Compression_{WIND} = 600 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb]/wcurb
Tension_{WIND} = 992 lbs = Comp_{WIND}+Fvert-0.6*WGUnit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1803 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1413 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGUnit
Compression_{WIND} = 220 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb]/Lcurb
Tension_{WIND} = 613 lbs = Comp_{WIND}+Fvert-0.6*WGUnit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 2254 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1864 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1803 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1413 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0713$ **14 Gauge**
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 25.000$ in	$a = 24.644$ in $= A' - (2r + t)$
$B' = 1.750$ in	$a' = 24.929$ in $= A' - t$
$C' = 0.000$ in (0 if no lips)	$b = 1.572$ in $= B' - [r + t/2 + a(r + t/2)]$
$\alpha = 0.000$ (0 - no Lip; 1 w/ lip)	$b' = 1.714$ in $= B' - [t/2 + \alpha t/2]$
$R = 0.1069$ (Inside bend radius)	$c = 0.000$ in $= \alpha[C' - (r + t/2)]$
$t = 0.0713$ in	$c' = 0.000$ in $= \alpha[C' - t/2]$
$r' = 0.143$ in $= R + t/2$	$u = 0.224$ in $= \pi r/2$
$x = 0.104$ in (Distance between centroid and web centerline)	
$I_x = 128.737$ in (Moment of Inertia about X-Axis)	
$I_y = 0.218$ in (Moment of Inertia about Y-Axis)	
$A = 2.01$ in ²	
$r_x = 8.00$ in	
$r_y = 0.329$ in	
$r_{min} = 0.329$ in	



Axial Compression

$P_u = 1.552$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 8.960$ k
 $F_e = 9.14$ ksi $\lambda_c = 2.34$
 $F_n = 8.01$ ksi
 $L_y = 73.38$ in
 $k_y L_y/r_y = 179$

If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume $k=0.8$)

Compression Check = O.K.

Check Web Crippling

$h = 25$ in $t = 0.0713$ in $N = 7.00$ $\Omega_w = 1.75$ $P_n = 2.105$ k $P_n/\Omega_w = 1.203$ k
Long side: $P_{u_{Trans}} = 1.127$ k
Short side: $P_{u_{Long}} = 0.901$ k

-- Check limits:

$h/t = 350.63 \leq 200$	$C = 4.00$
$N/t = 98.18 \leq 210$	$C_R = 0.14$
$N/h = 0.28 \leq 2.0$	$C_N = 0.35$
$R/t = 1.50 \leq 9.0$	$C_h = 0.02$

(See table C3.4.1-2, fastened to support, one flange, end loading)

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

O.K. # clips = 2

*** $h/t > 200$; use web stiffeners

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in $t_s = 0.0566$ **16 Gauge**
web of stiff. $w = 6.717$ in $R_s = 0.0849$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
 $P_{wc} = 2.105$ k $A_e = 0.380$ in²
 $P_n = 14.780$ k
 $P_n/\Omega_c = 8.694$ k

O.K.

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4"-20-UNC Threaded inserts

$T_{crnmax} = 776$ lbs $\text{Max}(F_{pmaxASD}/4 \text{ -OR- } F_{hASDtrans}/4 \text{ corner connections})$
 $V_{crnmax} = 932$ lbs (Max Ten/2 corner connections per side)
Bolt: $T_{all} = 2480$ lbs $V_{all} = 1096$ lbs
Threaded Insert: $T_{all} = 2860$ lbs $V_{all} = 1714$ lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 0.9
of Bolts Used = 1.0

***If combined fails:

USE --> 4.0

Check Combined Stress in Bolts & Inserts: 1.163 **N.G.**

StressComb = 0.291 **O.K.**



Check 1/8" welded connection

--- USE WELD

$\Omega = 2.35$

Assume $L/t > 25: 25 \cdot t =$

1.783 in

$L_{req'd} = 0.630$ in

$$P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$$

$$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

Curb Loads (copied from upper rail calcs)

Transverse:	Comp _{MAX} = 2330 lbs
(on long edge)	Tens _{MAX} = 1940 lbs
	Shear _{MAX} = 1552 lbs
Longitudinal:	Comp _{MAX} = 1805 lbs
(on short edge)	Tens _{MAX} = 1415 lbs
	Shear _{MAX} = 1552 lbs

Max compression force on isolator: 1.165 k ≤ 1.660 k **O.K.**

Max uplift on isolator: 0.970 k ≤ 1.660 k **O.K.**

Max shear on isolator: 0.776 k ≤ 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in

base curb, $t = 0.0713$ in

Tension = 0.485 k / bolt

Shear = 0.388 k / bolt

Shear on base curb:

$$P_n = t_e F_u$$

$\Omega = 2.00$

(Appendix A, Section E3.1 AISI)

$$P_n / \Omega = 4.635$$

$e = 1.0$ in

Shear O.K.

Net section rupture:

$$P_n = A_n F_t$$

$\Omega = 2.22$

(Appendix A, Section E3.2 AISI)

$$P_n / \Omega = 5.909$$

$A_n = 0.107$ in

N.S.R. O.K.

$$F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250 \text{ ksi}$$

Bolt Bearing Strength:

$$P_n = C m_y d t F_u$$

$\Omega = 2.50$

(Section E3.3.1 AISI)

$$P_n / \Omega = 2.781$$

$d/t = 7.01$

Bearing O.K.

$C = 3.00$

$m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

$$P_{nt} = A_b F_{nt}$$

$F_{nt} = 45.0$ ksi

$A_b = 0.1963$ in²

$$P_{nt} / \Omega = 3.927$$

Bolt tension O.K.

$\Omega t = 2.25$

$$P_{nv} = A_b F_{nv}$$

$F_{nv} = 27.0$ ksi

$\Omega v = 2.40$

$$P_{nv} / \Omega = 2.209$$

Bolt shear O.K.

[Table E3.4-1, AISI]

$$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nv}}{F_{nv}} f_v \leq F_{nt}$$



$f_v = 1.98$ ksi

O.K.

Combined Not Applicable

$F'_{nt} = 45.0$ ksi

$F_{nv} / \Omega = 11.25$ ksi



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$

WIND: $0.6 D + W$

Transverse:	Uplift _{MAX} = 4203 lbs	Shear _{MAX} = 2117 lbs
Compression _{SEISMIC} =	4734 lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$
Tension _{SEISMIC} =	4203 lbs	$= \text{Comp}_{SEISMIC} - (0.6 - 0.14 S_{DS}) (WGT_{unit+curb})$
Compression _{WIND} =	1384 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) * w_{curb} - F_{vertASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1522 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) * w_{curb} + F_{vertASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 2953 lbs	Shear _{MAX} = 2117 lbs
Compression _{SEISMIC} =	3485 lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$
Tension _{SEISMIC} =	2953 lbs	$= \text{Comp}_{SEISMIC} - (0.6 - 0.14 S_{DS}) (WGT_{unit+curb})$
Compression _{WIND} =	614 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) * L_{curb} - F_{vertASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	752 lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) * L_{curb} + F_{vertASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment:

1/4" ϕ wood lag screws

w/ 3.5" Min. Embed (SGmin = 0.43)

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Tall_{wood} = 671.25 lbs

Vall_{wood} = 224 lbs

Transverse:

of Screws Req'd for Uplift = 6.26

COMBINED LOADING: 1.048 NO GOOD

of Screws Req'd for Shear = 9.45

Req'd Min Spacing = 5.4 in o.c.

Total # of screws required = 15

Use 15 - 1/4" ϕ wood lag screws @ 5.4 in o.c. along long side of curb w/ 3.5" Min. Embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.

San Diego, CA 92120

(619)727-4800

Page ___ of ___

Longitudinal:

of Screws Req'd for Uplift = 4.40
 # of Screws Req'd for Shear = 9.45
 Total # of screws required = 13

COMBINED LOADING: 1.066 NO GOOD

Screw Spacing = 4.0 in o.c.

Use 13 - 1/4" ϕ wood lag screws @ 4 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Tall_{bolt} = 6903 lbs Vall_{bolt} = 3682 lbs
 Transverse: 6903 lbs 3682 lbs

of Bolts Req'd for Uplift = 0.61
 # of Bolts Req'd for Shear = 0.58
 Total # of bolts required = 2

COMBINED LOADING: 0.592 O.K.

Bolt Spacing = 72.3 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 72.3 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.43
 # of Bolts Req'd for Shear = 0.58
 Total # of bolts required = 2

COMBINED LOADING: 0.501 O.K.

Bolt Spacing = 44.0 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 44 in o.c. along short side of curb

For Concrete anchorage: SEISMIC [0.6-0.14SDS]D + 0.7Q_eE (Q_e = 2.5)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs (D = 0.465, E = 0.535)

Transverse: Uplift_{MAX} = 9792 lbs Shear_{MAX} = 5293 lbs

Compression_{SEISMIC} = 10324 lbs = [2.5*F_{maxASD}*(H_{cm}+H_{curb})+(1+0.14SDS)*(WGT_{unit+curb}/2)*w_{curb}]/w_{curb}

Tension_{SEISMIC} = 9792 lbs = Comp_{SEISMIC} - [0.6-0.14SDS]*(WGT_{unit+curb})

Shear_{SEISMIC} = 5293 lbs = 2.5*F_{maxASD}/2

Min Bolts Req'd Uplift = 9.54 spacing = 6.69 in o.c. T_{applied} = 890.2 lbs

Min Bolts Req'd Shear = 3.10 spacing = 20.08333 in o.c. V_{applied} = 481.2 lbs

Try using 11 bolts spaced at 7.23 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$

Use 11 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.2 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 6669 lbs Shear_{MAX} = 5293 lbs

Compression_{SEISMIC} = 7200 lbs = [2.5*F_{maxASD}*(H_{cm}+H_{curb})+(1+0.14SDS)*(WGT_{unit+curb}/2)*L_{curb}]/L_{curb}

Tension_{SEISMIC} = 6669 lbs = Comp_{SEISMIC} - [0.6-0.14SDS]*(WGT_{unit+curb})

Shear_{SEISMIC} = 5293 lbs = 2.5*F_{maxASD}/2

Min Bolts Req'd Uplift = 6.50 spacing = 5.333333 in o.c. T_{applied} = 833.6 lbs

Min Bolts Req'd Shear = 3.10 spacing = 10.66667 in o.c. V_{applied} = 661.7 lbs

Try using 8 bolts spaced at 6.29 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.20$

Use 8 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.3 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: (CBISCPRL* (CBISCPRL** Unit: ZX 08-14; XX 08-12; ZY 07-12; XY 07-09			
UPPER CURB RAIL THICKNESS: 0.1017 in 12 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQA Top stud diameter: 3/8			
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	15 @ 5.45 in o.c.	2 @ 72.25 in o.c.	11 @ 7.23 in o.c.
SHORT DIRECTION	13 @ 4 in o.c.	2 @ 44 in o.c.	8 @ 6.29 in o.c.