



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations

for

CBISC-08 Series

CBISCSLM1830 Curb**



Prepared for:

PROVENT / RRS

**3847 Wabash Drive
Mira Loma, CA 91725**

Date: April 2, 2021

Project Number: PV2101

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



**VIBRATION ISOLATION ROOF CURBS
YORK UNITS**

ZJ, ZR 180-300; XP 180-240
ZF 210-300; ZT 180-276


PROVENT P/N	A	B	EST. WEIGHT
CBISCSLM183018**	8"	18"	556 Lbs
CBISCSLM183021**	11"	21"	606 Lbs
CBISCSLM183024**	14"	24"	656 Lbs

**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-08

DATE:
4/2/2021


PART NUMBER:
-

REV:
2

DRAWN BY:
ALL

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" (OR 5/8" FOR MIL SERIES ONLY) Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 38.5" O.C.	2 @ 23" O.C.
LXL	2 @ 38.5" O.C.	2 @ 33" O.C.
SUN3672	2 @ 63" O.C.	2 @ 27.25" O.C.
PRD3715	3 @ 35.69" O.C.	2 @ 41.5" O.C.
PRS	2 @ 61.38" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	3 @ 58.13" O.C.	3 @ 37" O.C.
SLM1830	4 @ 38.75" O.C.	3 @ 37" O.C.

ASSUMES:

CONC SLAB
 f_c= 4000PSI MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	9 @ 4.81" O.C.	6 @ 4.6" O.C.
LXL	8 @ 5.5" O.C.	7 @ 5.5" O.C.
SUN3672	9 @ 7.88" O.C.	5 @ 6.81" O.C.
PRD3715	18 @ 4.2" O.C.	12 @ 3.77" O.C.
PRS	11 @ 6.14" O.C.	7 @ 5.19" O.C.
PRL	14 @ 5.56" O.C.	10 @ 4.89" O.C.
SLU180	18 @ 6.84" O.C.	13 @ 6.17" O.C.
SLM1830	23 @ 5.28" O.C.	16 @ 4.93" O.C.


* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

Meets seismic requirements for the following codes:
 CBC 2019
 IBC 2018

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830

WOOD ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø SIMPSON SDS OR EQUIVALENT SCREWS (3 1/2" MIN. EMBED. INTO WOOD FRAMING)

5/8" Ø LAG SCREW W/MIN. 3.5" EMBED (SGMIN=0.43) (FOR MIL SERIES ONLY)

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	6 @ 7.4" O.C.
SUN3672	8 @ 9.57" O.C.	5 @ 7.81" O.C.
PRD3715	16 @ 5.03" O.C.	11 @ 4.55" O.C.
PRS	10 @ 7.26" O.C.	7 @ 5.88" O.C.
PRL	13 @ 6.35" O.C.	9 @ 6" O.C.
SLU180	18 @ 7.07" O.C.	13 @ 6.5" O.C.
SLM1830	23 @ 5.47" O.C.	17 @ 4.88" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
 MIRA LOMA, CA 91725

PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 3/30/2021

REV:
 -

DRAWN BY:
 ALL




Client:	ProVent PV2101	Previous:	PV1805
Project:	CBISC-08 Iso Curb	CBISCLM1830	Upper curb rail
Unit:	ZJ,ZR 180-300; XP 180-240, ZF 210-300		

Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	125.75 in	(Length of curb)
wcurb =	83.5 in	(Width of curb)
WGTcurb =	656 lbs	(Weight of curb)
# Clips long side =	3	# Clips short side = 3

Unit Information

WGTunit =	3061.3 lbs	(Weight of Unit)
Wtmax =	908 lbs	(Maximum corner weight)
Wtmin =	306 lbs	(Minimum corner weight)
Hunit =	52.625 in	(Height of unit above curb)
Hcm =	26.3125 in	(Height to center of mass)
Lunit =	136.25 in	(Length of unit)
Wunit =	92 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	10993 lbs	(0.7*Fpmax)
	(unit only)	ap = 2.5
		Rp = 2
		FpmaxASD = 13349 lbs
		(unit and curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	*** Exposure Category C ***
Kzt =	1.00	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kd =	0.85	(Max. assumed topographic factor)
Ke =	1.00	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	110	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
GCr _(horiz) =	1.9	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	1865 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	1260 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2331 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:		
Compression _{SEISMIC} =	6150 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	5779 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	512 lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*wcurb-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1006 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Longitudinal:		
Compression _{SEISMIC} =	4986 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	4615 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	188 lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*Lcurb-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	682 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	6150 lbs	---> Along long edge of curb.
	Tens _{MAX} =	5779 lbs	---> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	4986 lbs	---> Along short edge of curb.
	Tens _{MAX} =	4615 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2 + a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - [t/2 + αt/2]
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
Ix = 2.687 in (Moment of Inertia about X-Axis)	
Iy = 0.169 in (Moment of Inertia about Y-Axis)	
A = 0.62 in ²	
rx = 2.08 in	
ry = 0.521 in	
rmin = 0.521 in	



Axial Compression

Pu = 5.497 k (Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 5.848 k	
Fe = 19.27 ksi	
λc = 1.61	
Fn = 16.90 ksi	
Ly = 80.00 in	
kyLy/ry = 123	

Lateral unbraced length (assume k=0.8)

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658 \lambda_c^2) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{0.877}{\lambda_c^2} F_y \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	CR = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.12	
Ωw = 1.75	N/h = 1.273 ≤ 2.0	Ch = 0.048	
Pn = 1.947 k	R/t = 1.50 ≤ 12.0		
Pn/Ωw = 1.112 k			

Long side: PuTrans = 2.050 k **web stiffener REQ'D** # clips = 3

Short side: PuLong = 1.662 k **web stiffener REQ'D** # clips = 3

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 3/4in x 7in (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys	Ωc = 1.70
w/ts = 118.675	
1.28v(E/Fys) = 31.091	--> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc	
Pwc = 1.947 k	Ae = 0.380 in ²
Pn = 14.669 k	
Pn/Ωc = 8.629 k	O.K.

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 2748 lbs	Max[FpmaxASD/4 -OR- FhASDtrans/4 corner connections]
Vcrnmax = 2889 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs

of Bolts required for Tension = 1.1
of Bolts required for Shear = 2.6
of Bolts Used = 3.0

***If combined fails:
USE --> 4.0

Check Combined Stress in Bolts & Inserts: 1.248 N.G. StressComb = 0.936 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} a = \frac{V_{req} \Omega}{0.75 t F_u}$
Lreq'd = 1.953 in




Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.1017$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $dw = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2377$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2377$ #
Shear: $P_{ns} = 2.7t_1dF_{u1}$ 3.86 k $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k
 $P_{ns}/\Omega = 792$ #
 $P_{ss}/\Omega = 540$ # <- Controls
Tension: $P_{not} = 1.068$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 356$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	5.497	3	1.83	540 #	4	2.00 in
Short side:	5.497	3	1.83	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)
Check Block shear rupture: 0.K. thinnest part = 0.0713 AISI BSR applies
 $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.463$ in² $A_{nv} = 0.416$ in² $A_{nt} = 0.082$ in²
 $R_n/\Omega = 8.674$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
BSR O.K.




Curb Loads (copied from above)

Transverse: (on long edge)	Comp _{MAX} = 6150 lbs
	Tens _{MAX} = 5779 lbs
	Shear _{MAX} = 10993 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4986 lbs
	Tens _{MAX} = 4615 lbs
	Shear _{MAX} = 10993 lbs

Loads at each Isolator Type: JQA

Transverse loading: (on long edge)**	Comp _{MAX} = 1366.6 lbs
	Tens _{MAX} = 1284.1 lbs
	Shear _{MAX} = 785.2 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1661.9 lbs
	Tens _{MAX} = 1538.2 lbs
	Shear _{MAX} = 785.2 lbs

Max compression force on isolator: 1.662 k ≤ 1.660 k **<1%-O.K.** **assumes capacity of 1/4 holddown from each adjacent edge
Max uplift on isolator: 1.538 k ≤ 1.660 k **O.K.**
Max shear on isolator: 0.785 k ≤ 0.800 k **O.K.**



Forces on top bolt:

$d_b = 0.375$ in
upper rail, $t = 0.1017$ in
Tension = 1.538 k
Shear = 0.785 k

Shear on curb rail: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 7.117$ k $A_n = 0.165$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.975$ k $d/t = 3.69$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ (Table E3.4-1, AISI)
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 13.93$ ksi $f_v = 7.11$ ksi **O.K.**
 $F'_{nt} = 23.86$ ksi $F_{nv}/\Omega = 10.00$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 1.171$ k **No Good - Use Welds**

Longitudinal weld loading: If $L/t < 25$: $L/t = 21.04$

$L = 1.5$ $P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2} \right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$
 $t = 0.0713$ (12 Gauge) $P_n/\Omega = 2.153$ k

Transverse weld loading:

$L = 1$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $t = 0.0713$ $P_n/\Omega = 1.972$ k
 $F_u = 65$ ksi




Client:	ProVent PV2101	Previous:	PV1805
Project:	CBISC-08 Iso Curb	CBISCSLM1830	Base curb
Unit:	ZJ,ZR 180-300; XP 180-240, ZF 210-300		

Curb Information

Hcurb =	25	in	(Height of curb)
Lcurb =	128.25	in	(Length of curb)
wcurb =	86	in	(Width of curb)
WGTCurb =	656	lbs	(Weight of curb)
# Springs long side =	4		# Springs short side = 3

Unit Information

WGTunit =	3061.3	lbs	(Weight of Unit)
WTmax =	908	lbs	(Maximum corner weight)
Wtmin =	306	lbs	(Minimum corner weight)
Hunit =	52.625	in	(Height of unit above curb)
Hcm =	26.3125	in	(Height to center of mass)
Lunit =	136.25	in	(Length of unit)
Wunit =	92	in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	10993	lbs
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	13349	lbs
	(unit and curb)	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf = 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _h ASD trans =	2491	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _h ASD long =	1682	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert} ASD =	2331	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	6049	lbs	= [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	5678	lbs	= Comp _{SEISMIC} - [0.6-0.14*SDS]*WGTunit
Compression _{WIND} =	686	lbs	= [F _h transASD*Hcm+2*0.6*Wtmax*wcurb-F _{vert} ASD*wcurb/2]/wcurb
Tension _{WIND} =	1180	lbs	= Comp _{WIND} +F _{vert} -0.6*WGTunit

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	4941	lbs	= [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	4570	lbs	= Comp _{SEISMIC} - [0.6-0.14*SDS]*WGTunit
Compression _{WIND} =	269	lbs	= [F _h transASD*Hcm+2*0.6*Wtmax*Lcurb-F _{vert} ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	763	lbs	= Comp _{WIND} +F _{vert} -0.6*WGTunit

----> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	6049	lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} =	5678	lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	4941	lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} =	4570	lbs	----> Along short edge of curb.

----> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi Fu = 65 ksi t = 0.1017 12 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.492 in = A' - (2r+t)
B' = 1.750 in	a' = 24.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r+t/2+a(r+t/2)]
α = 1.000 (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - [t/2+αt/2]
R = 0.1525 (Inside bend radius)	c = 0.746 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.949 in = α[C' - t/2]
r' = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.187 in (Distance between centroid and web centerline)	
I _x = 205.037 in (Moment of Inertia about X-Axis)	
I _y = 0.672 in (Moment of Inertia about Y-Axis)	
A = 3.02 in ²	
r _x = 8.23 in	
r _y = 0.471 in	
r _{min} = 0.471 in	



Axial Compression

P_u = 5.497 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 9.973 k
F_e = 6.77 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 2.72 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 5.93 ksi Lateral unbraced length
L_y = 122.25 in (assume k=0.8)
k_yL_y/r_y = 207

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 245.82 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _h = 0.02	
P _n = 4.106 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 2.346 k			
Long side: P _{uTrans} = 2.016 k	O.K. # clips = 3	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{uLong} = 1.647 k	O.K. # clips = 3		

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28√(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.106 k
P_n = 16.181 k
P_n/Ω_c = 9.518 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2748 lbs Max(F_{pmaxASD}/4 -OR- F_{HASDtrans}/4 corner connections)
V_{crnmax} = 2839 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs

of Bolts required for Tension = 1.1

of Bolts required for Shear = 2.6

of Bolts Used = 3.0

***If combined fails:

USE --> 4.0

Check Combined Stress in Bolts & Inserts: 1.233 **N.G.**

StressComb = 0.925 **O.K.**



Check 1/8" welded connection

<--- USE WELD $\Omega = 2.35$

Assume $L/t > 25$: $25 * t = 2.543$ in $P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} d = \frac{V_{req} \Omega}{0.75 t F_u}$

$L_{req} d = 1.346$ in

Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 6150 lbs
	Tens _{MAX} = 5779 lbs
	Shear _{MAX} = 10993 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4986 lbs
	Tens _{MAX} = 4615 lbs
	Shear _{MAX} = 10993 lbs


Loads at each Isolator Type: **JQA**

Transverse loading: (on long edge)**	Comp _{MAX} = 1366.6 lbs
	Tens _{MAX} = 1284.1 lbs
	Shear _{MAX} = 785.2 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1661.9 lbs
	Tens _{MAX} = 1538.2 lbs
	Shear _{MAX} = 785.2 lbs

Max compression force on isolator: 1.662 k ≤ 1.660 k **<1%-O.K.**

Max uplift on isolator: 1.538 k ≤ 1.660 k **O.K.**

Max shear on isolator: 0.785 k ≤ 0.800 k **O.K.**



Forces on bottom bolts:

$d_b = 0.5$ in

base curb, $t = 0.1017$ in

Tension = 0.769 k / bolt

Shear = 0.393 k / bolt

Shear on base curb: $P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

$P_n / \Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n / \Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n / \Omega = 3.966$ k $d/t = 4.92$

Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²

$P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$


$P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.83$ ksi $f_v = 2.00$ ksi

$F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi

$P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**



Connection of Curb to Supporting Structure

Roof Loading	SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$	WIND: $0.6D + W$
Transverse:	Uplift _{MAX} = 10263 lbs	Shear _{MAX} = 6674 lbs

Compression_{SEISMIC} = 10713 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 10263 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression_{WIND} = 1436 lbs = $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * w_{curb} - F_{vertASD} * w_{curb} / 2] / w_{curb}$

Tension_{WIND} = 1537 lbs = $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * w_{curb} + F_{vertASD} * w_{curb} / 2] / w_{curb}$

Longitudinal:	Uplift _{MAX} = 7639 lbs	Shear _{MAX} = 6674 lbs
---------------	----------------------------------	---------------------------------

Compression_{SEISMIC} = 8089 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 7639 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression_{WIND} = 623 lbs = $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * L_{curb} - F_{vertASD} * L_{curb} / 2] / L_{curb}$

Tension_{WIND} = 723 lbs = $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * L_{curb} + F_{vertASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment: **1/4" φ x 3.5" Simpson SDS screw w/ 2.25" threaded emt** (SGmin = 0.43)

Tall _{metal} = 946.67 lbs	Vall _{metal} = 1043.33 lbs
Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift = 16.66	COMBINED LOADING: 0.973 O.K.
# of Screws Req'd for Shear = 9.93	Req'd Min Spacing = 5.5 in o.c.
Total # of screws required = 23	

Use 23 - 1/4" φ x 3.5" Simpson SDS screws @ 5.5 in o.c. along long side of curb w/ 2.25" threaded embed



Longitudinal:

of Screws Req'd for Uplift = 12.40
of Screws Req'd for Shear = 9.93
Total # of screws required = 17

COMBINED LOADING: 0.978 O.K.
Screw Spacing = 4.9 in o.c.

Use 17 - 1/4" φ x 3.5" Simpson SDS screws @ 4.9 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = 4418 lbs
Transverse: 4418 lbs

Vall_{bolt} = 2356 lbs
2356 lbs

of Bolts Req'd for Uplift = 2.32
of Bolts Req'd for Shear = 2.83
Total # of bolts required = 4

COMBINED LOADING: 0.985 O.K.
Bolt Spacing = 38.8 in o.c.

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 38.8 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.73
of Bolts Req'd for Shear = 2.83
Total # of bolts required = 3

COMBINED LOADING: 0.981 O.K.
Bolt Spacing = 37.0 in o.c.

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 37 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87
Tall_{ASD} = Tall_{LRFD}/α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/α = 1704.8 lbs (D = 0.465, E = 0.535)

Transverse: Uplift_{MAX} = 22210 lbs Shear_{MAX} = 16686 lbs

Compression_{SEISMIC} = 22660 lbs = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}

Tension_{SEISMIC} = 22210 lbs = Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})

Shear_{SEISMIC} = 16686 lbs = 2.5 * F_{pmaxASD} / 2

Min Bolts Req'd Uplift = 21.64 spacing = 5.536 in o.c. T_{applied} = 965.6 lbs

Min Bolts Req'd Shear = 9.79 spacing = 12.917 in o.c. V_{applied} = 427.8 lbs

Try using 23 bolts spaced at 5.28 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.19$

Use 23 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.3 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 15650 lbs Shear_{MAX} = 16686 lbs

Compression_{SEISMIC} = 16101 lbs = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}

Tension_{SEISMIC} = 15650 lbs = Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})

Shear_{SEISMIC} = 16686 lbs = 2.5 * F_{pmaxASD} / 2

Min Bolts Req'd Uplift = 15.25 spacing = 4.933 in o.c. T_{applied} = 978.1 lbs

Min Bolts Req'd Shear = 9.79 spacing = 8.222 in o.c. V_{applied} = 427.8 lbs

Try using 16 bolts spaced at 4.93 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.20$

Use 16 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 4.9 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-08	CBISCSLM1830	Unit:	ZJ, ZR 180-300; XP 180-240, ZF 210-300
UPPER CURB RAIL THICKNESS:		0.1017 in	12 Gauge		
UNIT CLIP THICKNESS:		0.0713 in	14 Gauge		
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
# OF CLIPS (SHORT SIDE) - 3 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
VIBRATION ISOLATOR TYPE: JQA		Top stud diameter: 3/8	(4) - JQA Isolators long side		
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(3) - JQA Isolators short side		
BASE CURB THICKNESS: 0.1017 in		12 Gauge	***Must weld top of JQA***		
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
CORNER CONNECTION: Use minimum 4 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
CURB ANCHORAGE	WOOD	STEEL	CONCRETE		
	1/4" φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed		
LONG DIRECTION	23 @ 5.47 in o.c.	4 @ 38.75 in o.c.	23 @ 5.28 in o.c.		
SHORT DIRECTION	17 @ 4.88 in o.c.	3 @ 37 in o.c.	16 @ 4.93 in o.c.		