



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations

for

CBISC-02 Series

CBISCLXL SERIES**



Prepared for:

PROVENT / RRS

**3847 Wabash Drive
Mira Loma, CA 91725**

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR YORK UNITS

P***B CABINET

PROVENT P/N	A	B	EST. WEIGHT
CBISCLXL18**	8"	18"	205 Lbs.
CBISCLXL21**	11"	21"	224 Lbs.
CBISCLXL24**	14"	24"	239 Lbs.

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-02

DATE:
5/19/2022


PART NUMBER:
-

REV:
4

DRAWN BY:
JG

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-02 Iso Curb CBISCLXL	
Unit:	ALL YORK P***B CABINETS	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	46.5 in	(Length of upper curb)
wcurb =	41 in	(Width of upper curb)
WGTupper =	38 lbs	(Weight of upper curb)
# Clips long side =	1	# Clips short side = 1

Unit Information

WGTunit =	656 lbs	(Weight of Unit)
Wtmax =	197 lbs	(Maximum corner weight)
Wtmin =	139 lbs	(Minimum corner weight)
Hunit =	55 in	(Height of unit above curb)
Hcm =	27.5 in	(Height to center of mass)
Lunit =	51.25 in	(Length of unit)
Wunit =	45.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category IV Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2356 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 2492 lbs
		(unit + upper rail)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _h ASD trans =	730 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _h ASD long =	652 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert} ASD =	436 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	2099 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1502 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	508 lbs	= [F _h ASD trans *Hcm + 2*0.6*Wtmax*wcurb - F _{vert} ASD*wcurb/2]/wcurb
Tension _{WIND} =	541 lbs	= [F _h ASD trans *Hcm - 2*0.6*Wtmin*wcurb + F _{vert} ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	1912 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1315 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	404 lbs	= [F _h ASD long *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert} ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	436 lbs	= [F _h ASD long *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert} ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 2099 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1502 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1912 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1315 lbs	---> Along short edge of curb.


---> Negative values indicate opposite load.

Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.000 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 0.822 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 0.964 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.129 in (Distance between centroid and web centerline)	
I _x = 1.899 in ⁴	r _x = 1.92 in
I _y = 0.034 in ⁴	r _y = 0.257 in
A = 0.52 in ²	r _{min} = 0.257 in



Axial Compression

P _a = 1.178 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 4.964 k		
F _e = 19.75 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
λ _c = 1.59	If λ _c ≤ 1.5; F _n = (0.658λ _c ²) F _y	F _e = $\frac{\pi^2 E}{(kl/r)^2}$
F _n = 17.32 ksi	If λ _c > 1.5; F _n = $\frac{0.877}{\lambda_c^2} F_y$	
L _y = 39.00 in	Lateral unbraced length	
k _y L _y /r _y = 121	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	C _R = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.12	
Ω _w = 1.75	N/h = 1.273 ≤ 2.0	C _h = 0.048	
P _n = 1.947 k	R/t = 1.50 ≤ 12.0		
P _n /Ω _w = 1.112 k			
Long side: P _u Trans = 2.099 k	web stiffener REQ'D # clips = 1	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _u Long = 1.912 k	web stiffener REQ'D # clips = 1		

Check Web Stiffener

16Ga x 1-3/16in x 7in (C-channel)	P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}
width of stiffener = 7.000 in	t _s = 0.0566 16 Gauge
web of stiff. w = 6.717 in	R _s = 0.0849 in
***Check w/ts ≤ 1.28VE/F _y	Ω _c = 1.70
w/ts = 118.675	
1.28v(E/F _y) = 31.091	--> w/ts over limit Use C3.7.2
	P _n /Ω _c = 8.629 k
	O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crn} max = 623 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
V _{crn} max = 1050 lbs	Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1096 lbs
# of Bolts required for Tension = 0.3	
# of Bolts required for Shear = 1.0	
# of Bolts Used = 2.0	
Check Combined Stress in Bolts & Inserts: 0.604	O.K.

Check 1/8" welded connection

<--- USE WELD	Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in	$\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tL F_u \geq V_{req}$
L _{req'd} = 0.710 in	$L_{req'd} = \frac{V_{req} \Omega}{0.75t F_u}$



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	


For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755 \#$
 $P_{ss}/\Omega = 540 \#$ <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249 \#$ <- Controls
 $P_{ts}/\Omega = 820 \#$ (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377 \#$
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.178	1	1.18	540 #	4	2.00 in
Short side:	1.178	1	1.18	540 #	4	2.00 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 2464 lbs Tens _{MAX} = 1908 lbs Shear _{MAX} = 2492 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2226 lbs Tens _{MAX} = 1671 lbs Shear _{MAX} = 2492 lbs


Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 2463.6 lbs Tens _{MAX} = 1908.4 lbs Shear _{MAX} = 623.0 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 2226.4 lbs Tens _{MAX} = 1671.2 lbs Shear _{MAX} = 623.0 lbs

Max compression force on isolator: 2.464 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.908 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.623 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.908 k $d_b = 0.375$
 Shear = 0.623 k $d_w = 0.375$
 per rail, $t = 0.0713$ in



Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 17.28$ ksi $f_v = 5.64$ ksi **O.K.**
 $F'_{nt} = 29.80$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.463$ k **No Good - Use Welds**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ in $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ in $P_n/\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



Client:	ProVent PV2203	Base curb
Project:	CBISC-02 Iso Curb CBISCLXL	
Unit:	ALL YORK P***B CABINETS	

Base Curb Information

Hbase curb =	25 in	(Height of base curb)
Lcurb =	50.5 in	(Length of base curb)
wcurb =	45 in	(Width of base curb)
WGtbase =	201 lbs	(Weight of base curb)
# Springs long side =	1	# Springs short side = 1

Unit Information

WGtunit =	656 lbs	(Weight of Unit)
Wt'max =	206 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	149 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	55 in	(Height of unit above curb)
H'cm =	37.5 in	(Hcm+10"*(upper+spring))
Lunit =	51.25 in	(Length of unit)
Wunit =	45.75 in	(Width of unit)
WGtunit+upper+base =	895 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category IV Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	2492 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 3214 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1086 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	970 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	436 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	2621 lbs	= [FpmaxASD*H'cm + 2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	1993 lbs	= [FpmaxASD*H'cm - 2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	935 lbs	= [Fh ASD trans *H'cm + 2*0.6*Wt'max*wcurb - Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	945 lbs	= [Fh ASD trans *H'cm - 2*0.6*Wt'min*wcurb + Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	2395 lbs	= [FpmaxASD*H'cm + 2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	1767 lbs	= [FpmaxASD*H'cm - 2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	750 lbs	= [Fh ASD long *H'cm + 2*0.6*Wt'max*Lcurb - Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	759 lbs	= [Fh ASD long *H'cm - 2*0.6*Wt'min*Lcurb + Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:


Transverse:	Comp _{MAX} = 2621 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1993 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2395 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1767 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.



Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge



Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + a(r + t/2)]
a = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I _x = 128.737 in ⁴	r _x = 8.00 in
I _y = 0.218 in ⁴	r _y = 0.329 in
A = 2.01 in ²	r _{min} = 0.329 in

Axial Compression

P_u = 1.246 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 18.917 k
F_e = 19.29 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.61 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 16.91 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 50.50 in Lateral unbraced length
k_yL_y/r_y = 123 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _n = 0.02	
P _n = 2.105 k	R/t = 1.50 ≤ 9.0		

P_n = C t² F_y sin(90) (1 - C_R √(R/t)) (1 + C_N √(N/t)) (1 - C_n √(h/t))

Long side: P_{uTrans} = 2.621 k **web stiffener REQ'D** # clips = 1
Short side: P_{uLong} = 2.395 k **web stiffener REQ'D** # clips = 1
*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k A_e = 0.380 in²
P_n = 14.780 k
P_n/Ω_c = 8.694 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crnmax} = 803 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1311 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 1.1
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.470 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.886 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 2464 lbs Tens _{MAX} = 1908 lbs Shear _{MAX} = 2492 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2226 lbs Tens _{MAX} = 1671 lbs Shear _{MAX} = 2492 lbs

Max compression force on isolator: 2.464 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.908 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.623 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.0713$ in
 Tension = 0.954 k / bolt
 Shear = 0.312 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.781$ k

$d/t = 7.01$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²

$P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.**

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega_t = 2.25$

$P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** $\Omega_v = 2.40$

[Table E3.4-1, AISI]

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 9.72$ ksi $f_v = 1.59$ ksi

$F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi

$P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 4338 lbs	Shear _{MAX} = 1607 lbs
Compression _{SEISMIC} =	5054 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Tension _{SEISMIC} =	4338 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Compression _{WIND} =	1559 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1458 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb
Longitudinal:	Uplift _{MAX} = 3852 lbs	Shear _{MAX} = 1607 lbs
Compression _{SEISMIC} =	4568 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Tension _{SEISMIC} =	3852 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Compression _{WIND} =	1251 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	1150 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb



Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	5.71	COMBINED LOADING: 0.986 O.K.
# of Screws Req'd for Shear =	2.39	Req'd Min Spacing = 7.08 in o.c.
Total # of screws required =	7	

Use 7 - 1/4" φ x 4.5" Simpson SDS screws @ 7.1 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge)	Comp _{MAX} = 2463.6 lbs Tens _{MAX} = 1908.4 lbs Shear _{MAX} = 623.0 lbs
# isolators: 1	
Longitudinal loading: (on short edge)	Comp _{MAX} = 2226.4 lbs Tens _{MAX} = 1671.2 lbs Shear _{MAX} = 623.0 lbs
# isolators: 1	





Longitudinal:

of Screws Req'd for Uplift = 5.07 COMBINED LOADING: 0.895 O.K.
of Screws Req'd for Shear = 2.39 Screw Spacing = in o.c.
Total # of screws required =

Use 7 - 1/4" φ x 4.5" Simpson SDS screws @ 6.2 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = lbs Vall_{bolt} = lbs
Transverse: Tall_{metal} = lbs Vall_{metal} = lbs
of Bolts Req'd for Uplift = 2.08 COMBINED LOADING: 0.840 O.K.
of Bolts Req'd for Shear = 0.73 Bolt Spacing = in o.c.
Total # of bolts required =

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 19.3 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.85 COMBINED LOADING: 0.762 O.K.
of Bolts Req'd for Shear = 0.73 Bolt Spacing = in o.c.
Total # of bolts required =

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 33 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_e = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = 8802 lbs Shear_{MAX} = 3214 lbs
Compression_{SEISMIC} = 9518 lbs = [Ω_e*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 8802 lbs = [Ω_e*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 3214 lbs = Ω_e*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 7.68 spacing = 5.50 in o.c. T_{applied} = 1257.4 lbs
Min Bolts Req'd Shear = 1.21 spacing = 38.50 in o.c. V_{applied} = 267.8 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.20$

Use 7 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 7830 lbs Shear_{MAX} = 3214 lbs

Compression_{SEISMIC} = 8546 lbs = [Ω_e*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 7830 lbs = [Ω_e*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 3214 lbs = Ω_e*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 6.83 spacing = 5.50 in o.c. T_{applied} = 1118.5 lbs
Min Bolts Req'd Shear = 1.21 spacing = 33.00 in o.c. V_{applied} = 267.8 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.08$

Use 5 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 8.3 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		Unit:	ALL YORK P***B CABINETS
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA Top stud diameter: 3/8 (1) - CQA Isolators long side			
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16 (1) - CQA Isolators short side			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			***Must weld top of CQA***
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	7 @ 7.08 in o.c.	3 @ 19.25 in o.c.	7 @ 6.42 in o.c.
SHORT DIRECTION	7 @ 6.17 in o.c.	2 @ 33 in o.c.	5 @ 8.25 in o.c.