



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

## **Structural Calculations**

**for**

**CBISC-01 Series**

**CBISCLXS\*\* SERIES**



**Prepared for:**

**PROVENT / RRS**

**3847 Wabash Drive  
Mira Loma, CA 91725**

**Date: July 13, 2022**

**Project Number: PV2203**

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

## STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR YORK UNITS

PROVENT P/N	A	B	EST. WEIGHT
CBISCLXS18*	8"	18"	180 Lbs.
CBISCLXS21**	11"	21"	195 Lbs.
CBISCLXS24**	14"	24"	210 Lbs.

\*\*Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:  
CBC 2019  
IBC 2018




### FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.

P\*\*\*A CABINET



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:  
CBISC-01

DATE:  
6/30/2022


PART NUMBER:  
-

REV:  
4

DRAWN BY:  
FMM

**WELDMENT AND BOLTING DETAIL**

OPTIONAL  
WELD I.L.O.  
BOLTED STUD




**BASE CURB SUPPORT**

(3) 5/16" BOLTS  
GRADE 5 EA SIDE  
OF THE STIFFENER  
  
(2) EA SIDE FOR  
UPPER RAIL SUPPORT

OPTIONAL BOTTOM  
BUMPER FOR:  
ISCALSLU180  
ISCALSLM1830

FOR JQA:  
3/16" Ø HOLE USE 1/2" Ø A307 BOLT  
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:  
1/16" Ø HOLE USE 5/8" Ø A307 BOLT  
WITH FLAT WASHER AND NUT



**FOR BOLT ON ISOLATORS**

HOLE FOR ISOLATOR STUD,  
W/ FLAT WASHER REQUIRED  
UNDER NUT  
7/16" FOR JQA  
9/16" FOR JQB/JQBX  
11/16" FOR JQE/JQF

NEOPRENE CUP  
UNDER SPRING

1/4" THICK NEOPRENE PAD  
REQUIRED



3847 WABASH DRIVE  
MIRA LOMA, CA 91725

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_


FORM NO:  
CB-61

DATE:  
02/08/18

REV:  
1

DRAWN BY:  
ALL

**STEEL ATTACHMENT**




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

**ASSUMES:**

CONC SLAB  
 $f_c = 4000\text{PSI}$  MINIMUM  
 6" MIN THICKNESS  
 NORMAL WEIGHT CONCRETE  
 OR SAND LIGHT WEIGHT

**CONCRETE ATTACHMENT**




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
 \*\* CENTERED.

ROOF ANCHORAGE DETAIL
<b>CBISC Series</b>
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

**WOOD ATTACHMENT**



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE  
 MIRA LOMA, CA 91752  
 PHONE (951) 685-1101  
 FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_  
 JOB NAME: \_\_\_\_\_  
 EQUIPMENT: \_\_\_\_\_  
 NOTES: \_\_\_\_\_

FORM NO:  
 CB-62

DATE:  
 6/30/2022

REV:  
 2

DRAWN BY:  
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-01 Iso Curb CBISCLXS	
Unit:	ALL YORK P***A CABINETS	

**Upper Curb Information**

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	46.5 in	(Length of upper curb)
wcurb =	31 in	(Width of upper curb)
WGTupper =	33 lbs	(Weight of upper curb)
# Clips long side =	1	# Clips short side = 1

**Unit Information**

WGTunit =	521 lbs	(Weight of Unit)
Wtmax =	156 lbs	(Maximum corner weight)
Wtmin =	111 lbs	(Minimum corner weight)
Hunit =	49 in	(Height of unit above curb)
Hcm =	24.5 in	(Height to center of mass)
Lunit =	51.25 in	(Length of unit)
Wunit =	35.75 in	(Width of unit)



**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	1871 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 1989 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

**Wind Loading - 2018 IBC/2019 CBC**

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr <sub>(horiz)</sub> =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr <sub>(vert)</sub> =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
F <sub>h ASD trans</sub> =	658 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F <sub>h ASD long</sub> =	459 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F <sub>vert ASD</sub> =	341 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Upper Curb Loading**

Transverse:

Compression <sub>SEISMIC</sub> =	1891 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	1416 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S <sub>DS</sub> )*Wtmin*wcurb]/wcurb
Compression <sub>WIND</sub> =	537 lbs	= [F <sub>h ASD trans</sub> *Hcm + 2*0.6*Wtmax*wcurb - F <sub>vert ASD</sub> *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	557 lbs	= [F <sub>h ASD trans</sub> *Hcm - 2*0.6*Wtmin*wcurb + F <sub>vert ASD</sub> *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression <sub>SEISMIC</sub> =	1398 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	924 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S <sub>DS</sub> )*Wtmin*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	259 lbs	= [F <sub>h ASD long</sub> *Hcm + 2*0.6*Wtmax*Lcurb - F <sub>vert ASD</sub> *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	279 lbs	= [F <sub>h ASD long</sub> *Hcm - 2*0.6*Wtmin*Lcurb + F <sub>vert ASD</sub> *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

**Governing Reactions:**

<u>Transverse:</u>	Comp <sub>MAX</sub> =	1891 lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	1416 lbs	---> Along long edge of curb.
<u>Longitudinal:</u>	Comp <sub>MAX</sub> =	1398 lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	924 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




**Curb Design**

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

**Calculate Section Properties of Curb**

A' = <span style="border: 1px solid black; padding: 2px;">5.500</span> in	a = 5.144 in = A' - (2r+t)
B' = <span style="border: 1px solid black; padding: 2px;">1.000</span> in	a' = 5.429 in = A' - t
C' = <span style="border: 1px solid black; padding: 2px;">0.000</span> in (0 if no lips)	b = 0.822 in = B' - [r+t/2+α(r+t/2)]
α = <span style="border: 1px solid black; padding: 2px;">0.000</span> (0 - no Lip; 1 w/ lip)	b' = 0.964 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.129 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 1.899 in <sup>4</sup>	r <sub>x</sub> = 1.92 in
I <sub>y</sub> = 0.034 in <sup>4</sup>	r <sub>y</sub> = 0.257 in
A = 0.52 in <sup>2</sup>	r <sub>min</sub> = 0.257 in



**Axial Compression**

Pa = 0.935 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 7.976 k  
F<sub>e</sub> = 35.72 ksi       $\lambda_c = \frac{F_y}{\sqrt{F_e}}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$   
λ<sub>c</sub> = 1.18      If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>  
F<sub>n</sub> = 27.83 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$   
L<sub>y</sub> = 29.00 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 90      (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 5.5 in      -- Check limits:      C = 7.50  
t = 0.0713 in      h/t = 77.14 ≤ 200      C<sub>R</sub> = 0.08  
N = 7.00      N/t = 98.18 ≤ 210      C<sub>N</sub> = 0.12  
Ω<sub>w</sub> = 1.75      N/h = 1.273 ≤ 2.0      C<sub>h</sub> = 0.048  
P<sub>n</sub> = 1.947 k      R/t = 1.50 ≤ 12.0  
P<sub>n</sub>/Ω<sub>w</sub> = 1.112 k       $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$   
Long side: P<sub>u</sub>Trans = 1.891 k **web stiffener REQ'D** # clips = 1  
Short side: P<sub>u</sub>Long = 1.398 k **web stiffener REQ'D** # clips = 1

(See table C3.4.1-2, fastened to support, two flange, end loading)

**Check Web Stiffener**

16Ga x 1-3/16in x 7in (C-channel)      P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>  
width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 16 Gauge      P<sub>wc</sub> = 1.947 k  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in      P<sub>n</sub> = 14.669 k  
\*\*\*Check w/ts ≤ 1.28VE/F<sub>y</sub>      Ω<sub>c</sub> = 1.70      A<sub>e</sub> = 0.380 in<sup>2</sup>  
w/ts = 118.675  
1.28v(E/F<sub>y</sub>) = 31.091      --> w/ts over limit      Use C3.7.2      P<sub>n</sub>/Ω<sub>c</sub> = 8.629 k      **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

T<sub>crn</sub>max = 497 lbs      Max(F<sub>p</sub>maxASD/4 -OR- F<sub>h</sub>ASDtrans/4 corner connections)  
V<sub>crn</sub>max = 946 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1208 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1536 lbs  
# of Bolts required for Tension = 0.2  
# of Bolts required for Shear = 0.8  
# of Bolts Used = 2.0  
Check Combined Stress in Bolts & Inserts: 0.492      **O.K.**

**Check 1/8" welded connection**

<--- USE WELD      Ω = 2.35  
Assume L/t > 25: 25\*t = 1.783 in      P<sub>n</sub>/Ω =  $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$       L<sub>req'd</sub> =  $\frac{V_{req}\Omega}{0.75tF_u}$   
L<sub>req'd</sub> = 0.639 in



<b>Connection Unit to Curb Clip</b>	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	


For  $t_2/t_1 \leq 1.0$ :  
**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$  2.27 k  
**Tension:**  $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  
 $P_{ns} = 2.7t_2dF_{u2}$  2.38 k  
 $P_{ns}/\Omega = 755 \#$   
 $P_{ss}/\Omega = 540 \#$  <- Controls  
 $P_{not} = 0.748$  k (screw pull-out strength)  
 $P_{nov} = 2.607$  k (screw pull-over strength)  
 $P_{ts}/\Omega = 249 \#$  <- Controls  
 $P_{ts}/\Omega = 820 \#$  (full tensile screw capacity)

For  $t_2/t_1 \geq 2.5$ :  
 $P_{ns} = 2377 \#$   
 $P_{ns} = 2.7t_1dF_{u1}$  2.38 k  
 $P_{ns} = 2.7t_2dF_{u2}$  2.38 k  
 $P_{not} = 0.85t_c d F_{u2}$   
 $t_c = \min(t_1, t_2)$   
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	0.935	1	0.94	540 #	4	2.00 in
Short side:	0.935	1	0.94	540 #	4	2.00 in

clip width (in) = 7.00  
 min spacing = 0.57 in  
 clip height = 2.5 in  
 edge distance = 0.5 in (min. 1.5d)

**Check Block shear rupture:** O.K.  
 $F_y = 50$  ksi  
 $A_{gv} = 0.463$  in<sup>2</sup>  
 $R_n/\Omega = 8.674$  k  
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$  (AISI Sect. E5.3)  
 $\Omega = 2.22$  bolt/screw connection  
 $A_{nv} = 0.416$  in<sup>2</sup>  
 $A_{nt} = 0.082$  in<sup>2</sup>



**Curb Loads** [copied from above]

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> = 2291 lbs Tens <sub>MAX</sub> = 1847 lbs Shear <sub>MAX</sub> = 1989 lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> = 1649 lbs Tens <sub>MAX</sub> = 1206 lbs Shear <sub>MAX</sub> = 1989 lbs

**Loads at each Isolator** Type: CQA

<b>Transverse loading:</b> (on long edge)	Comp <sub>MAX</sub> = 2290.7 lbs Tens <sub>MAX</sub> = 1847.5 lbs Shear <sub>MAX</sub> = 497.4 lbs
<b>Longitudinal loading:</b> (on short edge)	Comp <sub>MAX</sub> = 1648.9 lbs Tens <sub>MAX</sub> = 1205.7 lbs Shear <sub>MAX</sub> = 497.4 lbs

Max compression force on isolator: 2.291 k  $\leq 3.176$  k **O.K.**  
 Max uplift on isolator: 1.847 k  $\leq 3.176$  k **O.K.**  
 Max shear on isolator: 0.497 k  $\leq 1.163$  k **O.K.**

**Forces on top bolt:**

Tension = 1.847 k  $d_b = 0.375$   
 Shear = 0.497 k  $d_w = 0.375$   
 per rail,  $t = 0.0713$  in

**Shear on curb rail:**

$P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
**Shear O.K.**  $P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**

$P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**

$P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**

$C = 3.00$   $m_f = 1.00$   
 (Appendix A, Section E3.4 AISI)

**Shear and tension in bolt:**

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>  
 $P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)  
 $P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 16.73$  ksi  $f_v = 4.50$  ksi **O.K.**  
 $F'_{nt} = 34.41$  ksi  $F_{nv}/\Omega = 10.00$  ksi


**No Good - Use Welds**

**Longitudinal weld loading:**

$L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$   
 If  $L/t < 25$ :  $L/t = 21.04$   $t = 0.0713$  in  $P_n/\Omega = 2.153$  k

**Transverse weld loading:**

$L = 1$   $F_u = 65$  ksi  $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$   
 $P_n/\Omega = 1.972$  k





Client:	ProVent PV2203	Base curb
Project:	CBISC-01 Iso Curb CBISCLXS	
Unit:	ALL YORK P***A CABINETS	

**Base Curb Information**

Hbase curb =	25 in	(Height of base curb)
Lcurb =	50.5 in	(Length of base curb)
wcurb =	35 in	(Width of base curb)
WGtbase =	177 lbs	(Weight of base curb)
# Springs long side =	1	# Springs short side = 1

**Unit Information**

WGtunit =	521 lbs	(Weight of Unit)
Wt'max =	165 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	119 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	49 in	(Height of unit above curb)
H'cm =	34.5 in	(Hcm+10"*(upper+spring))
Lunit =	51.25 in	(Length of unit)
Wunit =	35.75 in	(Width of unit)
WGtunit+upper+base =	731 lbs	(Total weight)

**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	1989 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 2625 lbs
		(unit + upper rail + base curb)

**Wind Loading - 2018 IBC/2019 CBC**

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1014 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	707 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	341 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Base Curb Loading**

Transverse:

Compression <sub>SEISMIC</sub> =	2395 lbs	= [FpmaxASD*H'cm+2*(1+0.14S <sub>DS</sub> )*Wt'max*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	1894 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*wcurb]/wcurb
Compression <sub>WIND</sub> =	1027 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	1027 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression <sub>SEISMIC</sub> =	1793 lbs	= [FpmaxASD*H'cm+2*(1+0.14S <sub>DS</sub> )*Wt'max*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	1292 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	510 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	511 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

**Governing Reactions:**

<u>Transverse:</u>	Comp <sub>MAX</sub> =	2395 lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	1894 lbs	---> Along long edge of curb.
<u>Longitudinal:</u>	Comp <sub>MAX</sub> =	1793 lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	1292 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.








**Curb Design**

F<sub>y</sub> = 50 ksi      Fu = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge



**Calculate Section Properties of Curb**

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + a(r + t/2)]
a = 0.000 in (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 128.737 in <sup>4</sup>	r <sub>x</sub> = 8.00 in
I <sub>y</sub> = 0.218 in <sup>4</sup>	r <sub>y</sub> = 0.329 in
A = 2.01 in <sup>2</sup>	r <sub>min</sub> = 0.329 in

**Axial Compression**

P<sub>u</sub> = 0.995 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 18.917 k  
F<sub>e</sub> = 19.29 ksi      λ<sub>c</sub> = 1.61      λ<sub>c</sub> = √(F<sub>y</sub>/F<sub>e</sub>)      F<sub>e</sub> = π<sup>2</sup>E / (kl/r)<sup>2</sup>  
λ<sub>c</sub> = 1.61      If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>)F<sub>y</sub>  
F<sub>n</sub> = 16.91 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> = 0.877 / λ<sub>c</sub><sup>2</sup> F<sub>y</sub>  
L<sub>y</sub> = 50.50 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 123      (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	C <sub>R</sub> = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C <sub>N</sub> = 0.35	
Ω <sub>w</sub> = 1.75	N/h = 0.28 ≤ 2.0	C <sub>n</sub> = 0.02	
P <sub>n</sub> = 2.105 k	R/t = 1.50 ≤ 9.0		

P<sub>n</sub> = C t<sup>2</sup> F<sub>y</sub> sin(90) (1 - C<sub>R</sub> √(R/t)) (1 + C<sub>N</sub> √(N/t)) (1 - C<sub>n</sub> √(h/t))

Long side: P<sub>uTrans</sub> = 2.395 k **web stiffener REQ'D** # clips = 1  
Short side: P<sub>uLong</sub> = 1.793 k **web stiffener REQ'D** # clips = 1  
**\*\*\*h/t > 200; use web stiffeners**

**Check Web Stiffener**

16Ga x 1.5in x 7in [C-channel]  
width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 16 Gauge  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/t<sub>s</sub> ≤ 1.28VE/F<sub>y</sub>      Ω<sub>c</sub> = 1.70  
w/t<sub>s</sub> = 118.675  
1.28v(E/F<sub>y</sub>) = 31.091 --> w/t<sub>s</sub> over limit Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>  
P<sub>wc</sub> = 2.105 k      A<sub>e</sub> = 0.380 in<sup>2</sup>  
P<sub>n</sub> = 14.780 k  
P<sub>n</sub>/Ω<sub>c</sub> = 8.694 k      **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**  
T<sub>crnmax</sub> = 656 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 1198 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1208 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1536 lbs  
# of Bolts required for Tension = 0.3  
# of Bolts required for Shear = 1.0  
# of Bolts Used = 2.0  
Check Combined Stress in Bolts & Inserts: 0.628 **O.K.**

**Check 1/8" welded connection**

---- USE WELD      Ω = 2.35  
Assume L/t > 25: 25\*t = 1.783 in      P<sub>n</sub>/Ω = 1/Ω \* 0.75tL F<sub>u</sub> ≥ V<sub>req</sub>      L<sub>req'd</sub> = V<sub>req</sub>Ω / (0.75tF<sub>u</sub>)  
L<sub>req'd</sub> = 0.810 in



**Curb Loads** [copied from upper rail calcs]

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> = 2291 lbs Tens <sub>MAX</sub> = 1847 lbs Shear <sub>MAX</sub> = 1989 lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> = 1649 lbs Tens <sub>MAX</sub> = 1206 lbs Shear <sub>MAX</sub> = 1989 lbs

Max compression force on isolator: 2.291 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 1.847 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 0.497 k ≤ 1.163 k **O.K.**

**Forces on bottom bolts:**

$d_b = 0.5$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 0.924 k / bolt  
 Shear = 0.249 k / bolt

**Shear on base curb:**  $P_n = teF_u$        $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n/\Omega = 4.635$  k       $e = 1.0$  in

**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$        $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n/\Omega = 5.909$  k       $A_n = 0.107$  in

**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$        $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n/\Omega = 2.781$  k       $d/t = 7.01$

**Bearing O.K.**

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$        $F_{nt} = 45.0$  ksi       $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt}/\Omega = 3.927$  k      **Bolt tension O.K.**       $\Omega t = 2.25$

Shear  $P_{nv} = A_b F_{nv}$        $F_{nv} = 27.0$  ksi       $\Omega v = 2.40$   
 $P_{nv}/\Omega = 2.209$  k      **Bolt shear O.K.**      **\*\*\*[Table E3.4-1, AISI]\*\***

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$        $f_t = 9.41$  ksi       $f_v = 1.27$  ksi  
 $F'_{nt} = 45.00$  ksi       $F_{nv}/\Omega = 11.25$  ksi  
 $P'_{nt} = A_b F'_{nt}$        $P'_{nt}/\Omega = 3.927$  k      **Combined Not Applicable -> F'nt = Fnt**

**Connection of Curb to Supporting Structure**

**Roof Loading**      SEISMIC: (0.6-0.14S<sub>DS</sub>)D + 0.7E      WIND: 0.6D + W

<b>Transverse:</b>	Uplift <sub>MAX</sub> = 4360 lbs	Shear <sub>MAX</sub> = 1313 lbs
Compression <sub>SEISMIC</sub> =	4945 lbs	= [F <sub>pmaxASD</sub> *(H'cm+Hbase curb)+(1+0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb
Tension <sub>SEISMIC</sub> =	4360 lbs	= [F <sub>pmaxASD</sub> *(H'cm+Hbase curb)-(0.6-0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb
Compression <sub>WIND</sub> =	1773 lbs	= [F <sub>h ASD trans</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *wcurb/2-F <sub>vert ASD</sub> *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	1675 lbs	= [F <sub>h ASD trans</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *wcurb/2+F <sub>vert ASD</sub> *wcurb/2]/wcurb
<b>Longitudinal:</b>	Uplift <sub>MAX</sub> = 2990 lbs	Shear <sub>MAX</sub> = 1313 lbs
Compression <sub>SEISMIC</sub> =	3575 lbs	= [F <sub>pmaxASD</sub> *(H'cm+Hbase curb)+(1+0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb
Tension <sub>SEISMIC</sub> =	2990 lbs	= [F <sub>pmaxASD</sub> *(H'cm+Hbase curb)-(0.6-0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb
Compression <sub>WIND</sub> =	882 lbs	= [F <sub>h ASD long</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	784 lbs	= [F <sub>h ASD long</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2+F <sub>vert ASD</sub> *Lcurb/2]/Lcurb



**Wood Attachment:** 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:  $T_{all\_metal} = 997$  lbs       $V_{all\_metal} = 1097$  lbs  
 $T_{all\_wood} = 760$  lbs       $V_{all\_wood} = 672$  lbs  
 # of Screws Req'd for Uplift = 5.74      COMBINED LOADING: 0.982 O.K.  
 # of Screws Req'd for Shear = 1.95      Req'd Min Spacing = 7.08 in o.c.  
 Total # of screws required = 7

Use 7 - 1/4" φ x 4.5" Simpson SDS screws @ 7.1 in o.c. along long side of curb w/ 2.75" threaded embed

**Loads at each Isolator**      Type: **CQA**

<b>Transverse loading:</b> (on long edge)	Comp <sub>MAX</sub> = 2290.7 lbs Tens <sub>MAX</sub> = 1847.5 lbs Shear <sub>MAX</sub> = 497.4 lbs
# isolators: 1	
<b>Longitudinal loading:</b> (on short edge)	Comp <sub>MAX</sub> = 1648.9 lbs Tens <sub>MAX</sub> = 1205.7 lbs Shear <sub>MAX</sub> = 497.4 lbs
# isolators: 1	





Longitudinal:

# of Screws Req'd for Uplift = 3.93      COMBINED LOADING: 0.950 O.K.  
 # of Screws Req'd for Shear = 1.95      Screw Spacing =  in o.c.  
 Total # of screws required =

Use 5 - 1/4" φ x 4.5" Simpson SDS screws @ 6.8 in o.c. along short side of curb w/ 2.75" threaded embed

**Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck**

Tall<sub>bolt</sub> =  lbs      Vall<sub>bolt</sub> =  lbs  
Transverse: Tall<sub>metal</sub> =  lbs      Vall<sub>metal</sub> =  lbs  
 # of Bolts Req'd for Uplift = 2.09      COMBINED LOADING: 0.816 O.K.  
 # of Bolts Req'd for Shear = 0.60      Bolt Spacing =  in o.c.  
 Total # of bolts required =

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 19.3 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 1.43      COMBINED LOADING: 0.598 O.K.  
 # of Bolts Req'd for Shear = 0.60      Bolt Spacing =  in o.c.  
 Total # of bolts required =

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 23 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7Ω<sub>e</sub>E      Ω<sub>e</sub> = 2.0

**Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed**

Tall<sub>LRFD</sub> = 1957 lbs      Vall<sub>LRFD</sub> = 4540 lbs      α = (1 + 0.2SDS)D + 2.5E = 1.708  
 Tall<sub>ASD</sub> = Tall<sub>LRFD</sub>/α = 1146 lbs      Vall<sub>ASD</sub> = Vall<sub>LRFD</sub>/α = 2658 lbs      (D = 0.758, E = 0.242)  
Transverse: Uplift<sub>MAX</sub> =  lbs      Shear<sub>MAX</sub> =  lbs  
 Compression<sub>SEISMIC</sub> = 9407 lbs      = [Ω<sub>e</sub>\*F<sub>pmaxASD</sub>\*(H'cm+Hbase curb)+(1+0.14S<sub>DS</sub>)\*WGT<sub>unit+curb+base</sub>\*wcurb/2]/wcurb  
 Tension<sub>SEISMIC</sub> = 8822 lbs      = [Ω<sub>e</sub>\*F<sub>pmaxASD</sub>\*(H'cm+Hbase curb)-(0.6-0.14S<sub>DS</sub>)\*WGT<sub>unit+curb+base</sub>\*wcurb/2]/wcurb  
 Shear<sub>SEISMIC</sub> = 2625 lbs      = Ω<sub>e</sub>\*F<sub>pmaxASD</sub>/2  
 Min Bolts Req'd Uplift = 7.70 spacing = 5.50 in o.c.      T<sub>applied</sub> = 1260.3 lbs  
 Min Bolts Req'd Shear = 0.99 spacing = 25.25 in o.c.      V<sub>applied</sub> = 238.6 lbs

Try using  bolts spaced at  in o.c.      COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.19$

Use 7 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift<sub>MAX</sub> =  lbs      Shear<sub>MAX</sub> =  lbs

Compression<sub>SEISMIC</sub> = 6668 lbs      = [Ω<sub>e</sub>\*F<sub>pmaxASD</sub>\*(H'cm+Hbase curb)+(1+0.14S<sub>DS</sub>)\*WGT<sub>unit+curb+base</sub>\*Lcurb/2]/Lcurb  
 Tension<sub>SEISMIC</sub> = 6083 lbs      = [Ω<sub>e</sub>\*F<sub>pmaxASD</sub>\*(H'cm+Hbase curb)-(0.6-0.14S<sub>DS</sub>)\*WGT<sub>unit+curb+base</sub>\*Lcurb/2]/Lcurb  
 Shear<sub>SEISMIC</sub> = 2625 lbs      = Ω<sub>e</sub>\*F<sub>pmaxASD</sub>/2  
 Min Bolts Req'd Uplift = 5.31 spacing = 4.60 in o.c.      T<sub>applied</sub> = 1013.8 lbs  
 Min Bolts Req'd Shear = 0.99 spacing = 17.50 in o.c.      V<sub>applied</sub> = 238.6 lbs

Try using  bolts spaced at  in o.c.      COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.97$

Use 4 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.7 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		Unit:
CBISC-01    CBISCLXS		ALL YORK P***A CABINETS
UPPER CURB RAIL THICKNESS: 0.0713 in    14 Gauge		
UNIT CLIP THICKNESS: 0.0713 in    14 Gauge		
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip		
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip		
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip		
VIBRATION ISOLATOR TYPE: CQA    Top stud diameter: 3/8    (1) - CQA Isolators long side		
Anchor bolt diameter: 1/2    Anchor hole diamter: 9/16    (1) - CQA Isolators short side		
BASE CURB THICKNESS: 0.0713 in    14 Gauge		***Must weld top of CQA***
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb		
CORNER CONNECTION: Use minimum 2 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts		
CURB ANCHORAGE	WOOD	STEEL
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck
		CONCRETE
	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed	
LONG DIRECTION	7 @ 7.08 in o.c.	3 @ 19.25 in o.c.
SHORT DIRECTION	5 @ 6.75 in o.c.	2 @ 23 in o.c.
		4 @ 7.67 in o.c.