



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-06 Series
CBISCPRL SERIES**




Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 23, 2023
Project Number: PV2312

WELDMENT AND BOLTING DETAIL

* OPTIONAL
WELD I.L.O.
BOLTED STUD



(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

BASE CURB SUPPORT


Note: * - INDICATES WELD REQUIRED I.L.O.
BOLTED STUD FOR THE FOLLOWING CURBS:

- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA/CQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA/CQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED

FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
08/14/23

REV:
2

DRAWN BY:
FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.

WELDED CURB

SHEATHING WHERE OCCURS

METAL DECK

STEEL ANGLE SUPPORT BY OTHERS

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	5 @ 17.44" O.C.	2 @ 41.5" O.C.
SAV1518	6 @ 22.43" O.C.	3 @ 35.56" O.C.
SAV2025	7 @ 21.02" O.C.	3 @ 35.56" O.C.
SAV28	7 @ 23.75" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
MIN. 9-1/8" EDGE DISTANCE.

CONCRETE ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE.
SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø THREADED ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4" EMBED

NO. OF ANCHORAGE BOLTS REQUIRED


CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	2 @ 23.0" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.50" O.C.
SUN3672	4 @ 21.0" O.C.	2 @ 27.25" O.C.
PRD3715	9 @ 8.92" O.C.	6 @ 8.30" O.C.
PRS	5 @ 15.34" O.C.	3 @ 15.56" O.C.
PRL	7 @ 11.63" O.C.	4 @ 13.83" O.C.
SAV1518	8 @ 16.02" O.C.	6 @ 14.23" O.C.
SAV2025	9 @ 15.77" O.C.	6 @ 14.23" O.C.
SAV28	10 @ 15.83" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

WOOD ATTACHMENT

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	8 @ 6.07" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.70" O.C.	8 @ 6.50" O.C.
SAV1518	15 @ 8.29" O.C.	10 @ 8.35" O.C.
SAV2025	18 @ 7.65" O.C.	10 @ 8.35" O.C.
SAV28	20 @ 7.71" O.C.	10 @ 8.35" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-62

DATE:
6/28/2023

REV:
4

DRAWN BY:
FMM

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR DIRECT FIT (SUN CORE) LARGE CABINET UNITS



ZX08-14; XX08-12; XYA7, ZYA7
ZY07-12; XY07-09; ZL08-14

FEATURES


- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROFILE DETAIL




PROVENT P/N	A	B	EST. WEIGHT
CBISCPRL18**	8"	18"	380 Lbs.
CBISCPRL21**	11"	21"	405 Lbs.
CBISCPRL24**	14"	24"	425 Lbs.

**Note: Spring configuration must be added to part number at time of order

Weight of upper portion supported by spring isolators= 221 Lbs.

Meets seismic requirements for the following codes:
CBC 2022
IBC 2021



3847 WABASH DRIVE
MIRA LOMA, CA 91752
PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-06
DATE:
7/28/2023

PART NUMBER:
-
REV:
5
DRAWN BY:
JG




Client:	ProVent	PV2312	Upper curb rail
Project:	CBISC-06	Iso Curb	CBISCPRL
Unit:	ZX/ZL 08-14; XX 08-12; XYA7, ZYA7; ZY 07-12; XY 07-09		

Upper Curb Information

Hcurb upper =	5.5	in	(Height of upper curb rail)
Lcurb =	81.75	in	(Length of upper curb)
wcurb =	53.5	in	(Width of upper curb)
WGTupper =	221	lbs	(Weight of upper curb)
# Clips long side =	2		
# Clips short side =	2		

Unit Information

WGTunit =	1318	lbs	(Weight of Unit)
Wtmax =	395	lbs	(Maximum corner weight)
Wtmin =	264	lbs	(Minimum corner weight)
Hunit =	48.56	in	(Height of unit above curb)
Hcm =	24.28	in	(Height to center of mass)
Lunit =	87.18	in	(Length of unit)
Wunit =	61.69	in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	4733	lbs
	(unit only)	
ap =	2.5	
Rp =	2	
FpmaxASD =	5527	lbs
	(unit + upper rail)	

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf
Fh ASD trans =	1110	lbs
Fh ASD long =	786	lbs
Fvert ASD =	1000	lbs
	= 0.00256*Kz*Kzt*Kd*Ke*V ²	(Eq. 26.10-1 ASCE 7-16)
	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb)	(Eq. 29.4-2)
	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)	
	= 0.6*qz*GCr*Lunit*Wunit	(Eq. 29.4-3)

Upper Curb Loading

Transverse:			
Compression _{SEISMIC} =	3191	lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	2000	lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	478	lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	688	lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:			
Compression _{SEISMIC} =	2449	lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1258	lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	208	lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	417	lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:		Comp _{MAX} =	3191	lbs	---> Along long edge of curb.
(on long edge)		Tens _{MAX} =	2000	lbs	---> Along long edge of curb.
Longitudinal:		Comp _{MAX} =	2449	lbs	---> Along short edge of curb.
(on short edge)		Tens _{MAX} =	1258	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r + t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	r _x = 2.08 in
I _y = 0.169 in ⁴	r _y = 0.521 in
A = 0.62 in ²	r _{min} = 0.521 in



Axial Compression

P_a = 2.366 k (Max Axial Comp) Ω_c = 1.80

P_n/Ω_c = 11.320 k

Fe = 49.34 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

λ_c = 1.01 If λ_c ≤ 1.5; F_n = (0.658^{λ_c²) F_y If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$}

F_n = 32.72 ksi

Ly = 50.00 in Lateral unbraced length

k_yL_y/r_y = 77 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50

t = 0.0713 in h/t = 77.14 ≤ 260 C_R = 0.08

N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12

Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048

P_n = 1.947 k R/t = 1.50 ≤ 12.0

P_n/Ω_w = 1.112 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Long side: P_{Utrans} = 1.596 k **web stiffener REQ'D** # clips = 2

Short side: P_{ULong} = 1.224 k **web stiffener REQ'D** # clips = 2

Check Web Stiffener

16Ga x 3/4in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}

width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k

web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k

***Check w/t_s ≤ 1.28vE/F_y Ω_c = 1.70 A_e = 0.380 in²

w/t_s = 118.675

1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 1382 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)

V_{crnmax} = 1596 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1208 lbs

Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs

of Bolts required for Tension = 0.6

of Bolts required for Shear = 1.5

of Bolts Used = 3.0

Check Combined Stress in Bolts & Inserts: 0.671 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

L_{req'd} = 1.079 in



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	

For $t_2/t_1 \leq 1.0$:	$P_{ns} = 2266$ #	For $t_2/t_1 \geq 2.5$:	$P_{ns} = 2377$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$	2.27 k	$P_{ns} = 2.7t_1dF_{u1}$	2.38 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$	2.38 k	$P_{ns} = 2.7t_2dF_{u2}$	2.38 k
$P_{ns}/\Omega = 755$ #			
$P_{ss}/\Omega = 540$ # <- Controls		$P_{not} = 0.85t_c dF_{u2}$	
$P_{not} = 0.748$ k (screw pull-out strength)		$t_c = \min(t_1, t_2)$	
$P_{nov} = 2.607$ k (screw pull-over strength)		$P_{nov} = 1.5t_1d_wF_{u1}$	
$P_{ts}/\Omega = 249$ # <- Controls			
$P_{ts}/\Omega = 820$ #	(full tensile screw capacity)		

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.366	2	1.18	540 #	4	2.00 in
Short side:	2.366	2	1.18	540 #	4	2.00 in

clip width (in) = 7.00
min spacing = 0.57 in

clip height = 2.5 in
edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

$F_y = 50$ ksi

$A_{gv} = 0.463$ in²

$R_n/\Omega = 8.674$ k

$\Omega = 2.22$ bolt/screw connection

$A_{nv} = 0.416$ in²

$R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$

(AISI Sect. E5.3)

$A_{nt} = 0.082$ in²

BSR O.K.

Curb Loads (copied from above)

Transverse:	$Comp_{MAX} = 4091$ lbs
(on long edge)	$Tens_{MAX} = 2860$ lbs
	$Shear_{MAX} = 5527$ lbs
Longitudinal:	$Comp_{MAX} = 3028$ lbs
(on short edge)	$Tens_{MAX} = 1797$ lbs
	$Shear_{MAX} = 5527$ lbs

Loads at each Isolator

Type: CQA

Transverse loading:	$Comp_{MAX} = 2045.7$ lbs
(on long edge)	$Tens_{MAX} = 1430.1$ lbs
# isolators: 2	$Shear_{MAX} = 690.8$ lbs
Longitudinal loading:	$Comp_{MAX} = 1514.2$ lbs
(on short edge)	$Tens_{MAX} = 898.6$ lbs
# isolators: 2	$Shear_{MAX} = 690.8$ lbs

Max compression force on isolator: 2.046 k ≤ 3.176 k **O.K.**

Max uplift on isolator: 1.430 k ≤ 3.176 k **O.K.**

Max shear on isolator: 0.691 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.430 k $d_b = 0.375$

Shear = 0.691 k upper rail, $t = 0.0713$ in

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_nF_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k

$d/t = 5.26$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 12.95$ ksi $f_v = 6.25$ ksi **O.K.**

$P'_{nt}/\Omega = 1.341$ k $F'_{nt} = 27.32$ ksi $F_{nv}/\Omega = 10.00$ ksi



No Good - Use Welds

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2} \right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k





Client:	ProVent	PV2312	Base curb
Project:	CBISC-06	Iso Curb	CBISCPRL
Unit:	ZX/ZL 08-14; XX 08-12; XYA7, ZYA7; ZY 07-12; XY 07-09		

Base Curb Information

Hbase curb =	25	in	(Height of base curb)
Lcurb =	81.75	in	(Length of base curb)
wcurb =	53.5	in	(Width of base curb)
WGTbase =	204	lbs	(Weight of base curb)
# Springs long side =	2		# Springs short side = 2

Unit Information

WGUnit =	1318	lbs	(Weight of Unit)
Wt'max =	451	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	319	lbs	(Wtmin+1/4*WGUpper)
Hunit =	48.56	in	(Height of unit above curb)
H'cm =	34.28	in	(Hcm+10"(upper+spring))
Lunit =	87.18	in	(Length of unit)
Wunit =	61.69	in	(Width of unit)
WGUnit+upper+base =	1743	lbs	(Total weight)

Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130	Wp
FpmaxASD =	5527	lbs
	(unit + upper rail)	
ap =	2.5	
Rp =	2	
FpmaxASD =	6259	lbs
	(unit + upper rail + base curb)	

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8	psf
Fh ASD trans =	1716	lbs
Fh ASD long =	1214	lbs
Fvert ASD =	1000	lbs

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	4730	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S _{DS}) * Wt'max * wcurb] / wcurb
Tension _{SEISMIC} =	3362	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S _{DS}) * Wt'min * wcurb] / wcurb
Compression _{WIND} =	1140	lbs	= [Fh ASD trans * H'cm + 2 * 0.6 * Wt'max * wcurb - Fvert ASD * wcurb / 2] / wcurb
Tension _{WIND} =	1217	lbs	= [Fh ASD trans * H'cm - 2 * 0.6 * Wt'min * wcurb + Fvert ASD * wcurb / 2] / wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	3506	lbs	= [FpmaxASD * H'cm + 2 * (1 + 0.14 * S _{DS}) * Wt'max * Lcurb] / Lcurb
Tension _{SEISMIC} =	2138	lbs	= [FpmaxASD * H'cm - 2 * (0.6 - 0.14 * S _{DS}) * Wt'min * Lcurb] / Lcurb
Compression _{WIND} =	550	lbs	= [Fh ASD long * H'cm + 2 * 0.6 * Wt'max * Lcurb - Fvert ASD * Lcurb / 2] / Lcurb
Tension _{WIND} =	627	lbs	= [Fh ASD long * H'cm - 2 * 0.6 * Wt'min * Lcurb + Fvert ASD * Lcurb / 2] / Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	4730	lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} =	3362	lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	3506	lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} =	2138	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.






Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + α(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in	rx = 8.00 in
Iy = 0.218 in	ry = 0.329 in
A = 2.01 in ²	rmin = 0.329 in



Axial Compression

Pu = 2.763 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 7.219 k
Fe = 7.36 ksi
λc = 2.61
Fn = 6.45 ksi
Ly = 81.75 in
kyLy/r_y = 199

If λ_c ≤ 1.5; F_n = (0.658^{λ_c²}) F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 350.63 ≤ 260 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.28 ≤ 2.0 C_h = 0.02
P_n = 2.105 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.203 k
Long side: P_UTrans = 2.365 k web stiffener REQ'D # clips = 2
Short side: P_ULong = 1.753 k web stiffener REQ'D # clips = 2

***h/t > 260; use web stiffeners

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
w/ts = 118.675
1.28V(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k Ae = 0.380 in²
P_n = 14.780 k
P_n/Ωc = 8.694 k O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1565 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
Vcrnmax = 2365 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.6
of Bolts required for Shear = 2.2
of Bolts Used = 4.0
Check Combined Stress in Bolts & Inserts: 0.697 O.K.

Check 1/8" welded connection

USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 1.599 in



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} = 4091 lbs Tens _{MAX} = 2860 lbs Shear _{MAX} = 5527 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 3028 lbs Tens _{MAX} = 1797 lbs Shear _{MAX} = 5527 lbs

Max compression force on isolator: 2.046 k ≤ 3.176 k **O.K.**
Max uplift on isolator: 1.430 k ≤ 3.176 k **O.K.**
Max shear on isolator: 0.691 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, $t = 0.0713$ in
Tension = 0.715 k / bolt
Shear = 0.345 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C_m d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 2.781$ k $d / t = 7.01$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** ***** (Table E3.4-1, AISI) *****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.28$ ksi $f_v = 1.76$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> $F'_{nt} = F_{nt}$**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14 S_{DS}) D + 0.7 E$ WIND: $0.6 D + W$



Transverse:	Uplift _{MAX} = 6691 lbs	Shear _{MAX} = 3130 lbs
Compression _{SEISMIC} =	8085 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Tension _{SEISMIC} =	6691 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Compression _{WIND} =	1924 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1878 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 4294 lbs	Shear _{MAX} = 3130 lbs
Compression _{SEISMIC} =	5688 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Tension _{SEISMIC} =	4294 lbs	$= [F_{pmax} ASD * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Compression _{WIND} =	903 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	858 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
Transverse: Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift = 8.80	COMBINED LOADING: 0.966 O.K.
# of Screws Req'd for Shear = 4.66	Req'd Min Spacing = 6.70 in o.c.
Total # of screws required = 12	

Use 12 - 1/4" φ x 4.5" Simpson SDS screws @ 6.7 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator	Type: CQA
Transverse loading: (on long edge) # isolators: 2	Comp _{MAX} = 2045.7 lbs Tens _{MAX} = 1430.1 lbs Shear _{MAX} = 690.8 lbs
Longitudinal loading: (on short edge) # isolators: 2	Comp _{MAX} = 1514.2 lbs Tens _{MAX} = 898.6 lbs Shear _{MAX} = 690.8 lbs





Longitudinal:

# of Screws Req'd for Uplift =	5.65	COMBINED LOADING:	0.939 O.K.
# of Screws Req'd for Shear =	4.66	Screw Spacing =	6.50 in o.c.
Total # of screws required =	8		

Use 8 - 1/4" ϕ x 4.5" Simpson SDS screws @ 6.5 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Tall _{bolt} =	3927 lbs	Vall _{bolt} =	2209 lbs
Transverse: Tall _{metal} =	2086 lbs	Vall _{metal} =	2192 lbs
# of Bolts Req'd for Uplift =	3.21	COMBINED LOADING:	0.845 O.K.
# of Bolts Req'd for Shear =	1.43	Bolt Spacing =	17.44 in o.c.
Total # of bolts required =	5		

Use 5 - 1/2" ϕ A307 Bolts to steel angle below deck @ 17.4 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	2.06	COMBINED LOADING:	0.616 O.K.
# of Bolts Req'd for Shear =	1.43	Bolt Spacing =	41.50 in o.c.
Total # of bolts required =	2		

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 41.5 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Q_o E $\Omega_o = 2.5$

Concrete Attachment: 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'c =	4000 psi		
h =	6 in (concrete thickness, t _{min} = h _{ef} + 2do)	O.K.	
h _{ef} =	4 in (effective embedment)		
da =	0.625 in (anchor diameter)	do =	0.75 in (hole diameter)
n =	5 (number of dummy anchors to check capacity with spacing effect)		
s =	10 in (initial spacing estimate)		
tk _{cr} / uncr =	1170 2220 psi (from ESR 4868, Table 14, Temp range B)		
tk _{cr} / uncr =	1226 2327 psi If f'c > 2500, multiply by (f'c/2500) ^{0.1}		
c _{Na} =	9.0625 in (min. edge distance for full capacity);	c _{Na} =	10da $\sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength
***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 1053.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 9535 \text{ lbs}$$

$$N_{ag} = 30578 \text{ lbs (group)}$$

$$\phi N_{ag} = 14907 \text{ lbs (group)}$$

$$N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$\lambda_a = 1.0$$

$$\lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightw}$$

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 624 \text{ in}^2$$

$$N_b = 8601 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 144 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 37273 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 20966 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 2981 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 1745 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 0.242 \quad \alpha = 1.709$$

Transverse:	Uplift _{MAX} =	8600 lbs	Shear _{MAX} =	7824 lbs
-------------	-------------------------	----------	------------------------	----------

$$\text{Compression}_{SEISMIC} = 10042 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 8600 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 7824 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 4.93 \text{ spacing} = 17.44 \text{ in o.c.}$$

$$T_{applied} = 1228.5 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 4.36 \text{ spacing} = 17.44 \text{ in o.c.}$$


$$V_{applied} = 711.3 \text{ lbs}$$

Try using 7 bolts
spaced at 11.63 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.10 \text{ O.K.}$$

Use 7 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 11.6 in o.c. max. along long side of curb w/ 4in embed

Longitudinal:	Uplift _{MAX} =	5540 lbs	Shear _{MAX} =	7824 lbs
---------------	-------------------------	----------	------------------------	----------





MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page 8 of 8

$$\begin{aligned}
 \text{Compression}_{\text{SEISMIC}} &= 6983 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) + (1 + 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Tension}_{\text{SEISMIC}} &= 5540 \text{ lbs} &= [\Omega_o * F_{\text{pmaxASD}} * (H_{\text{cm}} + H_{\text{curb}}) - (0.6 - 0.14 S_{\text{DS}}) * WGT_{\text{unit+curb}} * L_{\text{curb}} / 2] / L_{\text{curb}} \\
 \text{Shear}_{\text{SEISMIC}} &= 7824 \text{ lbs} &= \Omega_o * F_{\text{pmaxASD}} / 2 \\
 \text{Min Bolts Req'd Uplift} &= 3.18 \text{ spacing} = 13.83 \text{ in o.c.} & \text{Applied} = 1385.1 \text{ lbs} \\
 \text{Min Bolts Req'd Shear} &= 4.36 \text{ spacing} = 10.38 \text{ in o.c.} & \text{Applied} = 711.3 \text{ lbs} \\
 \text{Try using } 4 \text{ bolts spaced at } 13.83 \text{ in o.c.} & \text{COMBINED LOADING} = \frac{T_{\text{applied}}}{T_{\text{allow, ASD}}} + \frac{V_{\text{applied}}}{V_{\text{allow, ASD}}} \leq 1.2 = 1.19 \text{ O.K.}
 \end{aligned}$$

Use 4 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 13.8 in o.c. max. along short side of curb w/ 4in embed

CURB DESIGN SUMMARY:		CBISC-06	CBISC PRL	Unit:	ZX/ZL 08-14; XX 08-12; XYA7, ZYA7; ZY 07-12; XY 07-09
UPPER CURB RAIL THICKNESS:		0.0713 in	14 Gauge		
UNIT CLIP THICKNESS:		0.0713 in	14 Gauge		
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip					
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip					
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8		(2) - CQA Isolators long side	
Anchor bolt diameter: 1/2		Anchor hole diamter: 9/16		(2) - CQA Isolators short side	
BASE CURB THICKNESS: 0.0713 in 14 Gauge				***Must weld top of CQA***	
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb					
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts					
CURB ANCHORAGE	<u>WOOD</u>		<u>STEEL</u>		<u>CONCRETE</u>
	1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =		1/2" ϕ A307 Bolts to steel angle below deck		0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4in embed
<u>LONG DIRECTION</u>	12 @ 6.7 in o.c.		5 @ 17.44 in o.c.		7 @ 11.63 in o.c.
<u>SHORT DIRECTION</u>	8 @ 6.5 in o.c.		2 @ 41.5 in o.c.		4 @ 13.83 in o.c.