



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations

for

CBISC-05 Series

CBISCPRS SERIES**



Prepared for:

PROVENT / RRS

**3847 Wabash Drive
Mira Loma, CA 91725**

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURB FOR YORK UNITS

ZX 04-07; XX A7, ZX A7, ZY, ZQ, XY, XQ, ZL 04-06

PROVENT P/N	A	B	EST. WEIGHT
CBISCPRS18**	8"	18"	305 Lbs.
CBISCPRS21**	11"	21"	320 Lbs.
CBISCPRS24**	14"	24"	335 Lbs.

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-05

DATE:
4/25/2022

PART NUMBER:


-

REV:
3

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER


(2) EA SIDE FOR
UPPER RAIL SUPPORT

BASE CURB SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
1 1/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED

FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-05 Iso Curb CBISCPRS	
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	70.375 in	(Length of upper curb)
wcurb =	40.1875 in	(Width of upper curb)
WGTupper =	56 lbs	(Weight of upper curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGTunit =	916 lbs	(Weight of Unit)
Wtmax =	275 lbs	(Maximum corner weight)
Wtmin =	195 lbs	(Minimum corner weight)
Hunit =	40.56 in	(Height of unit above curb)
Hcm =	20.28 in	(Height to center of mass)
Lunit =	74.05 in	(Length of unit)
Wunit =	48.88 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3289 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 3490 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	803 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	530 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	673 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	2385 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1551 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	399 lbs	= [F _{h ASD trans} *Hcm + 2*0.6*Wtmax*wcurb - F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	508 lbs	= [F _{h ASD trans} *Hcm - 2*0.6*Wtmin*wcurb + F _{vert ASD} *wcurb/2]/wcurb

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	1673 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	839 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	146 lbs	= [F _{h ASD long} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	256 lbs	= [F _{h ASD long} *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert ASD} *Lcurb/2]/Lcurb

----> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 2385 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1551 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1673 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 839 lbs	----> Along short edge of curb.


----> Negative values indicate opposite load.

Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	r _x = 2.08 in
I _y = 0.169 in ⁴	r _y = 0.521 in
A = 0.62 in ²	r _{min} = 0.521 in



Axial Compression

P_a = 1.645 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 13.768 k
F_e = 91.64 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 0.74 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 39.79 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 36.69 in Lateral unbraced length (assume k=0.8)
k_yL_y/r_y = 56

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12 (See table C3.4.1-2, fastened to support, two flange, end loading)
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Long side: P_{uTrans} = 0.795 k **O.K.** # clips = 3
Short side: P_{uLong} = 0.836 k **O.K.** # clips = 2

Check Web Stiffener

N/A P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **Not Req'd**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 873 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1192 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.1
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.480 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.806 in



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)		$d_w = 0.375$ in (nom. washer diameter)


For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755$ #
 $P_{ss}/\Omega = 540$ # <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249$ # <- Controls
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377$ #
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.645	3	0.55	540 #	4	2.00 in
Short side:	1.645	2	0.82	540 #	4	2.00 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 2880 lbs Tens _{MAX} = 2103 lbs Shear _{MAX} = 3490 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1920 lbs Tens _{MAX} = 1142 lbs Shear _{MAX} = 3490 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 1440.1 lbs Tens _{MAX} = 1051.3 lbs Shear _{MAX} = 436.3 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 959.9 lbs Tens _{MAX} = 571.1 lbs Shear _{MAX} = 436.3 lbs

Max compression force on isolator: 1.440 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.051 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.436 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.051 k $d_b = 0.375$
 Shear = 0.436 k $t = 0.0713$ in

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:


$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 9.52$ ksi $f_v = 3.95$ ksi **O.K.**
 $F'_{nt} = 36.65$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.799$ k **Combined O.K.**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ in $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ in $P_n/\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k





Client:	ProVent PV2203	Base curb
Project:	CBISC-05 Iso Curb CBISCPRS	
Unit:	YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06	

Base Curb Information

Hbase curb =	25 in	(Height of base curb)
Lcurb =	73.375 in	(Length of base curb)
wcurb =	43.125 in	(Width of base curb)
WGtbase =	279 lbs	(Weight of base curb)
# Springs long side =	2	# Springs short side = 2

Unit Information

WGtunit =	916 lbs	(Weight of Unit)
Wt'max =	289 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	209 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	40.56 in	(Height of unit above curb)
H'cm =	30.28 in	(Hcm+10"*(upper+spring))
Lunit =	74.05 in	(Length of unit)
Wunit =	48.88 in	(Width of unit)
WGtunit+upper+base =	1251 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3490 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 4492 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1318 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	870 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	673 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	3213 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	2334 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	935 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1012 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	2202 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	1323 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	369 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	445 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	3213 lbs	---> Along long edge of curb.
	Tens _{MAX} =	2334 lbs	---> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	2202 lbs	---> Along short edge of curb.
	Tens _{MAX} =	1323 lbs	---> Along short edge of curb.


---> Negative values indicate opposite load.





Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge



Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r+t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
a = 0.000 in (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in	rx = 8.00 in
Iy = 0.218 in	ry = 0.329 in
A = 2.01 in ²	rmin = 0.329 in

Axial Compression

Pu = 1.745 k (Max Axial Comp) Ωc = 1.80
 Pn/Ωc = 8.960 k
 Fe = 9.14 ksi If λc ≤ 1.5; Fn = (0.658λc²)Fy
 λc = 2.34 Ωc = Fn/A If λc > 1.5; Fn = 0.877/λc²Fy λc = √(Fy/Fe) Fe = π²E / (kl/r)²
 Fn = 8.01 ksi
 Ly = 73.38 in Lateral unbraced length
 kyLy/ry = 179 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
 t = 0.0713 in h/t = 350.63 ≤ 200 CR = 0.14
 N = 7.00 N/t = 98.18 ≤ 210 CN = 0.35
 Ωw = 1.75 N/h = 0.28 ≤ 2.0 Cn = 0.02
 Pn = 2.105 k R/t = 1.50 ≤ 9.0
 Pn/Ωw = 1.203 k
 Long side: PuTrans = 1.606 k **web stiffener REQ'D** # clips = 2
 Short side: PuLong = 1.101 k **O.K.** # clips = 2
 ***h/t > 200; use web stiffeners

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]
 width of stiffener = 7.000 in ts = 0.0566 16 Gauge
 web of stiff. w = 6.717 in Rs = 0.0849 in
 ***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
 w/ts = 118.675
 1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
 Pn = 0.7(Pwc + AeFy) ≥ Pwc
 Pwc = 2.105 k Ae = 0.380 in²
 Pn = 14.780 k
 Pn/Ωc = 8.694 k **O.K.**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1123 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
 Vcrnmax = 1606 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
 Bolt: Tall = 2480 lbs Vall = 1208 lbs
 Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
 # of Bolts required for Tension = 0.5
 # of Bolts required for Shear = 1.5
 # of Bolts Used = 3.0
 Check Combined Stress in Bolts & Inserts: 0.640 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
 Assume L/t > 25: 25*t = 1.783 in Pn/Ω = 1/Ω * 0.75tFu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu
 Lreq'd = 1.086 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 2880 lbs Tens _{MAX} = 2103 lbs Shear _{MAX} = 3490 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1920 lbs Tens _{MAX} = 1142 lbs Shear _{MAX} = 3490 lbs

Max compression force on isolator: 1.440 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.051 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.436 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.0713$ in
 Tension = 0.526 k / bolt
 Shear = 0.218 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.781$ k $d/t = 7.01$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 5.35$ ksi $f_v = 1.11$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 5583 lbs	Shear _{MAX} = 2246 lbs
Compression _{SEISMIC} =	6584 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Tension _{SEISMIC} =	5583 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Compression _{WIND} =	1728 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1651 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb
Longitudinal:	Uplift _{MAX} = 3209 lbs	Shear _{MAX} = 2246 lbs
Compression _{SEISMIC} =	4210 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Tension _{SEISMIC} =	3209 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Compression _{WIND} =	694 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	617 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb



Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

Transverse: $T_{all_metal} = 997$ lbs $V_{all_metal} = 1097$ lbs
 $T_{all_wood} = 760$ lbs $V_{all_wood} = 672$ lbs
 # of Screws Req'd for Uplift = 7.35 COMBINED LOADING: 0.943 O.K.
 # of Screws Req'd for Shear = 3.34 Req'd Min Spacing = 7.26 in o.c.
 Total # of screws required = 10

Use 10 - 1/4" φ x 4.5" Simpson SDS screws @ 7.3 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge)	Comp _{MAX} = 1440.1 lbs Tens _{MAX} = 1051.3 lbs Shear _{MAX} = 436.3 lbs
# isolators: 2	
Longitudinal loading: (on short edge)	Comp _{MAX} = 959.9 lbs Tens _{MAX} = 571.1 lbs Shear _{MAX} = 436.3 lbs
# isolators: 2	





Longitudinal:

of Screws Req'd for Uplift = 4.22 COMBINED LOADING: 0.913 O.K.
of Screws Req'd for Shear = 3.34 Screw Spacing = 7.03 in o.c.
Total # of screws required = 6

Use 6 - 1/4" φ x 4.5" Simpson SDS screws @ 7 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Transverse: Tall_{metal} = 2086 lbs Vall_{metal} = 2192 lbs
of Bolts Req'd for Uplift = 2.68 COMBINED LOADING: 0.840 O.K.
of Bolts Req'd for Shear = 1.02 Bolt Spacing = 20.46 in o.c.
Total # of bolts required = 4

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 20.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.54 COMBINED LOADING: 0.555 O.K.
of Bolts Req'd for Shear = 1.02 Bolt Spacing = 31.13 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 31.1 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = 11341 lbs Shear_{MAX} = 4492 lbs
Compression_{SEISMIC} = 12342 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 11341 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 4492 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 9.90 spacing = 6.82 in o.c. T_{applied} = 1134.1 lbs
Min Bolts Req'd Shear = 1.69 spacing = 61.38 in o.c. V_{applied} = 299.5 lbs

Try using 10 bolts spaced at 6.82 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.10$

Use 10 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.8 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 6593 lbs Shear_{MAX} = 4492 lbs
Compression_{SEISMIC} = 7594 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 6593 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 4492 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 5.76 spacing = 6.23 in o.c. T_{applied} = 941.9 lbs
Min Bolts Req'd Shear = 1.69 spacing = 31.13 in o.c. V_{applied} = 299.5 lbs

Try using 5 bolts spaced at 7.78 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.93$

Use 5 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-05 CBISCPRS	Unit: YORK ZX 04-07; XX A7; ZY, ZQ, XY, XQ 04-06
UPPER CURB RAIL THICKNESS: 0.0713 in		14 Gauge	
UNIT CLIP THICKNESS: 0.0713 in		14 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(2) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(2) - CQA Isolators short side
BASE CURB THICKNESS: 0.0713 in		14 Gauge	---Bolt or Weld O.K.---
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	10 @ 7.26 in o.c.	4 @ 20.46 in o.c.	10 @ 6.82 in o.c.
SHORT DIRECTION	6 @ 7.03 in o.c.	2 @ 31.13 in o.c.	5 @ 7.78 in o.c.