



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-12 Series
CBISCSAV1518 SERIES**



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS SUNCHOICE UNITS

AV 15-18

PROVENT P/N	A	B	EST. WEIGHT
CBISCSAV151818**	8"	18"	556 Lbs
CBISCSAV151821**	11"	21"	606 Lbs
CBISCSAV151824**	14"	24"	656 Lbs

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-12

DATE:
4/20/2022


PART NUMBER:
-

REV:
2

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-12 Iso Curb	CBISCSAV1518
Unit:	Sunchoice 15-18	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	121.125 in	(Length of upper curb)
wcurb =	80.125 in	(Width of upper curb)
WGTupper =	103 lbs	(Weight of upper curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGTunit =	2380 lbs	(Oper. Weight of Unit)
Wtmax =	666 lbs	(Maximum corner weight)
Wtmin =	506 lbs	(Minimum corner weight)
Hunit =	49.25 in	(Height of unit above curb)
Hcm =	24.625 in	(Height to center of mass)
Lunit =	129.75 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	8547 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 8916 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	1673 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	1145 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2141 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	4385 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	2343 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	243 lbs	= [F _{h ASD trans} *Hcm + 2*0.6*Wtmax*wcurb - F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	978 lbs	= [F _{h ASD trans} *Hcm - 2*0.6*Wtmin*wcurb + F _{vert ASD} *wcurb/2]/wcurb

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	3496 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1454 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	-38 lbs	= [F _{h ASD long} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	696 lbs	= [F _{h ASD long} *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert ASD} *Lcurb/2]/Lcurb

----> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 4385 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2343 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 3496 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1454 lbs	----> Along short edge of curb.

----> Negative values indicate opposite load.




Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
Ix = 2.687 in ⁴	rx = 2.08 in
Iy = 0.169 in ⁴	ry = 0.521 in
A = 0.62 in ²	rmin = 0.521 in



Axial Compression

Pa = 4.273 k	(Max Axial Comp)	Ω _c = 1.80
Pn/Ω _c = 5.794 k		
Fe = 19.09 ksi		
λ _c = 1.62	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
F _n = 16.74 ksi	If λ _c ≤ 1.5; F _n = (0.658λ _c ²) F _y	F _e = $\frac{\pi^2 E}{(kl/r)^2}$
Ly = 80.38 in	If λ _c > 1.5; F _n = $\frac{0.877}{\lambda_c^2} F_y$	
k _y L _y /r _y = 123	Lateral unbraced length	
	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	C _R = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.12	
Ω _w = 1.75	N/h = 1.273 ≤ 2.0	C _h = 0.048	
P _n = 1.947 k	R/t = 1.50 ≤ 12.0		
P _n /Ω _w = 1.112 k			
Long side: P _{U_{Trans}} = 1.462 k	web stiffener REQ'D # clips = 3	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{U_{Long}} = 1.748 k	web stiffener REQ'D # clips = 2		

Check Web Stiffener

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge	P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}
web of stiff. w = 6.717 in	R _s = 0.0849 in	P _{wc} = 1.947 k
***Check w/ts ≤ 1.28√E/F _y	Ω _c = 1.70	P _n = 14.669 k
w/ts = 118.675		A _e = 0.380 in ²
1.28√(E/F _y) = 31.091	--> w/ts over limit Use C3.7.2	P _n /Ω _c = 8.629 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 2229 lbs	Max[F _{pmaxASD} /4 -OR- F _{HASDtrans} /4 corner connections]
V _{crnmax} = 2192 lbs	Max[Tens/2 -OR- Comp/2 corner connections per side]
Bolt: Tall = 2480 lbs	Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1536 lbs
# of Bolts required for Tension = 0.9	
# of Bolts required for Shear = 1.8	
# of Bolts Used = 3.0	
Check Combined Stress in Bolts & Inserts: 0.905	O.K.



Check 1/8" welded connection <--- USE WELD $\Omega = 2.35$

Assume $L/t > 25$: $25 \cdot t = 1.783$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} \cdot d = \frac{V_{req} \Omega}{0.75 t F_u}$

$L_{req} \cdot d = 1.482$ in

Connection Unit to Curb Clip		#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.1017$ in (clip thickness)	$t_2/t_1 = 0.7$	$F_{u1} = 65$ ksi	
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi	
$d = 0.190$ in (screw diameter)	$dw = 0.375$ in (nom. washer diameter)		

For $t_2/t_1 \leq 1.0$: $P_{ns} = 2266$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2377$ #

Shear: $P_{ns} = 4.2 F_{u2} \sqrt{t_2^3 d} = 2.27$ k $P_{ns} = 2.7 t_1 d F_{u1} = 3.39$ k

Tension: $P_{ns} = 2.7 t_1 d F_{u1} = 3.39$ k $P_{ns} = 2.7 t_2 d F_{u2} = 2.38$ k

$P_{ns}/\Omega = 755$ # $P_{not} = 0.85 t_c d F_{u2}$

$P_{ss}/\Omega = 540$ # <- Controls $t_c = \min(t_1, t_2)$

$P_{not} = 0.748$ k (screw pull-out strength) $P_{nov} = 1.5 t_1 d_w F_{u1}$

$P_{nov} = 3.718$ k (screw pull-over strength) $P_{ts}/\Omega = 249$ # <- Controls

$P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.273	3	1.42	540 #	4	2.00 in
Short side:	4.273	2	2.14	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in


min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K. $\Omega = 2.22$ bolt/screw connection

$F_y = 50$ ksi $A_{nv} = 0.593$ in² $A_{nt} = 0.117$ in²

$A_{gv} = 0.661$ in² $R_n = 0.6 F_y A_{gv} + F_u A_{nt} \leq 0.6 F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]

$R_n/\Omega = 12.372$ k



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 4990 lbs
	Tens _{MAX} = 3004 lbs
	Shear _{MAX} = 8916 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 3855 lbs
	Tens _{MAX} = 1869 lbs
	Shear _{MAX} = 8916 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 1663.4 lbs
	Tens _{MAX} = 1001.3 lbs
	Shear _{MAX} = 891.6 lbs
# isolators: 3	
Longitudinal loading: (on short edge)	Comp _{MAX} = 1927.7 lbs
	Tens _{MAX} = 934.5 lbs
	Shear _{MAX} = 891.6 lbs
# isolators: 2	

Max compression force on isolator: 1.928 k ≤ 3.176 k **O.K.**

Max uplift on isolator: 1.001 k ≤ 3.176 k **O.K.**

Max shear on isolator: 0.892 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.001 k $d_b = 0.375$

Shear = 0.892 k $d_b = 0.375$

Shear on curb rail: $P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s) F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$

Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ (Table E3.4-1, AISI)


Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 9.07$ ksi $f_v = 8.07$ ksi **O.K.**

$P'_{nt}/\Omega = 0.979$ k **No Good - Use Welds** $F'_{nt} = 19.95$ ksi $F_{nv}/\Omega = 10.00$ ksi





Client:	ProVent PV2203	Base curb
Project:	CBISC-12 Iso Curb CBISCSAV1518	
Unit:	Sunchoice 15-18	

Base Curb Information

Hbase curb =	14 in	(Height of base curb)
Lcurb =	124.125 in	(Length of base curb)
wcurb =	83.125 in	(Width of base curb)
WGtbase =	553 lbs	(Weight of base curb)
# Springs long side =	3	# Springs short side = 2

Unit Information

WGtunit =	2380 lbs	(Oper. Weight of Unit + 5%)
Wt'max =	692 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	532 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	49.25 in	(Height of unit above curb)
H'cm =	34.625 in	(Hcm+10"*(upper+spring))
Lunit =	129.75 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)
WGtunit+upper+base =	3036 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	8916 lbs	(0.7*Fpmax)
	(unit + upper rail)	
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2239 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	1531 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	2141 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	5540 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	3416 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	692 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1365 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	4313 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	2189 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	187 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	860 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:


Transverse:	Comp _{MAX} = 5540 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3416 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 4313 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2189 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.



Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**



Calculate Section Properties of Curb

A' = 14.000 in	a = 13.492 in = A' - (2r + t)
B' = 1.750 in	a' = 13.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r + t/2 + a(r + t/2)]
a = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2 + at/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = a[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = a[C' - t/2]
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.297 in (Distance between centroid and web centerline)	
I _x = 45.336 in ⁴	r _x = 4.88 in
I _y = 0.610 in ⁴	r _y = 0.566 in
A = 1.91 in ²	r _{min} = 0.566 in

Axial Compression

P_u = 4.458 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 9.779 k
F_e = 10.53 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 2.18
F_n = 9.23 ksi If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
Ly = 117.63 in If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
k_yL_y/r_y = 166 Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 137.66 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.5 ≤ 2.0	C _n = 0.02	
P _n = 4.578 k	R/t = 1.50 ≤ 9.0		

Long side: P_{uTrans} = 1.847 k **O.K.** # clips = 3
Short side: P_{uLong} = 2.157 k **O.K.** # clips = 2

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_n \sqrt{\frac{h}{t}}\right)$$

Check Web Stiffener N/A

width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.578 k
P_n = 16.511 k
P_n/Ω_c = 9.712 k **Not Req'd**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2726 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 2770 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 1.1
of Bolts required for Shear = 2.3
of Bolts Used = 4.0
Check Combined Stress in Bolts & Inserts: 0.848 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in P_n/Ω = $\frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 1.313 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 4990 lbs Tens _{MAX} = 3004 lbs Shear _{MAX} = 8916 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 3855 lbs Tens _{MAX} = 1869 lbs Shear _{MAX} = 8916 lbs

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge) # isolators: 3	Comp _{MAX} = 1663.4 lbs Tens _{MAX} = 1001.3 lbs Shear _{MAX} = 891.6 lbs
Longitudinal loading: (on short edge) # isolators: 2	Comp _{MAX} = 1927.7 lbs Tens _{MAX} = 934.5 lbs Shear _{MAX} = 891.6 lbs

Max compression force on isolator: 1.928 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.001 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.892 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.501 k / bolt
 Shear = 0.446 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.966$ k $d/t = 4.92$
 $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 5.10$ ksi $f_v = 2.27$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure



Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 5951 lbs	Shear _{MAX} = 5451 lbs
Compression _{SEISMIC} =	8380 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Tension _{SEISMIC} =	5951 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Compression _{WIND} =	1150 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1469 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb
Longitudinal:	Uplift _{MAX} = 3845 lbs	Shear _{MAX} = 5451 lbs
Compression _{SEISMIC} =	6273 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Tension _{SEISMIC} =	3845 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Compression _{WIND} =	440 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	760 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 1397 lbs	Vall _{metal} = 1230 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	7.83	COMBINED LOADING: 0.971 O.K.
# of Screws Req'd for Shear =	8.11	Req'd Min Spacing = 9.68 in o.c.
Total # of screws required =	13	

Use 13 - 1/4" φ x 4.5" Simpson SDS screws @ 9.7 in o.c. along long side of curb w/ 2.75" threaded embed





Longitudinal:

of Screws Req'd for Uplift = 5.06 COMBINED LOADING: 0.931 O.K.
of Screws Req'd for Shear = 8.11 Screw Spacing = in o.c.
Total # of screws required =

Use 9 - 1/4" φ x 4.5" Simpson SDS screws @ 9.4 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = lbs Vall_{bolt} = lbs
Transverse: Tall_{metal} = lbs Vall_{metal} = lbs
of Bolts Req'd for Uplift = 2.00 COMBINED LOADING: 0.853 O.K.
of Bolts Req'd for Shear = 2.47 Bolt Spacing = in o.c.
Total # of bolts required =

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 37.4 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.29 COMBINED LOADING: 0.676 O.K.
of Bolts Req'd for Shear = 2.47 Bolt Spacing = in o.c.
Total # of bolts required =

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 35.6 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = 12329 lbs Shear_{MAX} = 10902 lbs
Compression_{SEISMIC} = 14757 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 12329 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 10902 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 10.76 spacing = 11.21 in o.c. T_{applied} = 1027.4 lbs
Min Bolts Req'd Shear = 4.10 spacing = 28.03 in o.c. V_{applied} = 605.7 lbs

Try using 12 bolts spaced at 10.19 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12$

Use 12 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 10.2 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 8116 lbs Shear_{MAX} = 10902 lbs
Compression_{SEISMIC} = 10544 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 8116 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 10902 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 7.08 spacing = 10.16 in o.c. T_{applied} = 1014.4 lbs
Min Bolts Req'd Shear = 4.10 spacing = 17.78 in o.c. V_{applied} = 605.7 lbs

Try using 6 bolts spaced at 14.23 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.11$

Use 6 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 14.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-12 CBISCAV1518	Unit: Sunchoice 15-18
UPPER CURB RAIL THICKNESS: 0.1017 in		12 Gauge	
UNIT CLIP THICKNESS: 0.1017 in		12 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(3) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(2) - CQA Isolators short side
BASE CURB THICKNESS: 0.1017 in		12 Gauge	***Must weld top of CQA***
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use minimum 4 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	13 @ 9.68 in o.c.	4 @ 37.38 in o.c.	12 @ 10.19 in o.c.
SHORT DIRECTION	9 @ 9.39 in o.c.	3 @ 35.56 in o.c.	6 @ 14.23 in o.c.