



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-13 Series
CBISCSAV2025 SERIES**



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS SUNCHOICE UNITS

AV 20-25

PROVENT P/N	A	B	EST. WEIGHT
CBISCSAV202518**	8"	18"	615 Lbs
CBISCSAV202521**	11"	21"	660 Lbs
CBISCSAV202524**	14"	24"	710 Lbs

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
CBISC-13

DATE:
4/20/2022


PART NUMBER:
CBISCSAV2025 SERIES

REV:
1

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
1 1/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-13 Iso Curb	CBISCSAV2025
Unit:	Sunchoice 20-25	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	135.125 in	(Length of upper curb)
wcurb =	80.125 in	(Width of upper curb)
WGTupper =	105 lbs	(Weight of upper curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGTunit =	2640 lbs	(Oper. Weight of Unit)
Wtmax =	739 lbs	(Maximum corner weight)
Wtmin =	561 lbs	(Minimum corner weight)
Hunit =	57.25 in	(Height of unit above curb)
Hcm =	28.625 in	(Height to center of mass)
Lunit =	143.8125 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	9480 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 9857 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	2126 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	1312 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2373 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	5337 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3072 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	460 lbs	= [F _{h ASD trans} *Hcm + 2*0.6*Wtmax*wcurb - F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1273 lbs	= [F _{h ASD trans} *Hcm - 2*0.6*Wtmin*wcurb + F _{vert ASD} *wcurb/2]/wcurb

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	3959 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1693 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	-22 lbs	= [F _{h ASD long} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	791 lbs	= [F _{h ASD long} *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert ASD} *Lcurb/2]/Lcurb

----> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 5337 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3072 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 3959 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1693 lbs	----> Along short edge of curb.


----> Negative values indicate opposite load.

Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.500 in (0 if no lips)	b = 1.233 in = B' - [r+t/2+α(r+t/2)]
α = 0.500 (0 - no Lip; 1 w/ lip)	b' = 1.447 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.161 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.232 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.292 in (Distance between centroid and web centerline)	
Ix = 2.515 in ⁴	rx = 2.04 in
Iy = 0.133 in ⁴	ry = 0.470 in
A = 0.60 in ²	rmin = 0.470 in



Axial Compression

Pa = 4.740 k (Max Axial Comp) Ω_c = 1.80
Pn/Ω_c = 4.957 k
Fe = 16.90 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 1.72 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
Fn = 14.82 ksi
Ly = 77.13 in Lateral unbraced length
k_yL_y/r_y = 131 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$ (See table C3.4.1-2, fastened to support, two flange, end loading)
Long side: P_{U_{Trans}} = 1.779 k **web stiffener REQ'D** # clips = 3
Short side: P_{U_{Long}} = 1.979 k **web stiffener REQ'D** # clips = 2

Check Web Stiffener

16Ga x 1-3/16in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in ts = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2464 lbs Max[F_{pmaxASD}/4 -OR- F_{HASDtrans}/4 corner connections]
V_{crnmax} = 2669 lbs Max[Tens/2 -OR- Comp/2 corner connections per side]
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 1.0
of Bolts required for Shear = 2.2
of Bolts Used = 4.0
Check Combined Stress in Bolts & Inserts: 0.801 **O.K.**



Check 1/8" welded connection

<--- USE WELD $\Omega = 2.35$
 Assume $L/t > 25$: $25 \cdot t = 1.783$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} \cdot d = \frac{V_{req} \Omega}{0.75 t F_u}$
 $L_{req} \cdot d = 1.804$ in

Connection Unit to Curb Clip

#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.1017$ in (clip thickness)	$t_2/t_1 = 0.7$
$t_2 = 0.0713$ in (unit base rail thickness)	$F_{u1} = 65$ ksi
$d = 0.190$ in (screw diameter)	$F_{u2} = 65$ ksi
	$d_w = 0.375$ in (nom. washer diameter)


For $t_2/t_1 \leq 1.0$: $P_{ns} = 2266$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2377$ #
Shear: $P_{ns} = 4.2 F_{u2} \sqrt{t_2^3 d}$ 2.27 k $P_{ns} = 2.7 t_1 d F_{u1}$ 3.39 k
Tension: $P_{ns} = 2.7 t_1 d F_{u1}$ 3.39 k $P_{ns} = 2.7 t_2 d F_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755$ # $P_{not} = 0.85 t_c d F_{u2}$
 $P_{ss}/\Omega = 540$ # <- Controls $t_c = \min(t_1, t_2)$
 $P_{not} = 0.748$ k (screw pull-out strength) $P_{nov} = 1.5 t_1 d_w F_{u1}$
 $P_{nov} = 3.718$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249$ # <- Controls $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.740	3	1.58	540 #	4	2.00 in
Short side:	4.740	2	2.37	540 #	5	1.50 in

clip width (in) = 7.00 clip height = 2.5 in
 min spacing = 0.57 in edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

$F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.661$ in² $A_{nv} = 0.574$ in² $A_{nt} = 0.117$ in²
 $R_n/\Omega = 12.372$ k $R_n = 0.6 F_y A_{gv} + F_u A_{nt} \leq 0.6 F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 6009 lbs
	Tens _{MAX} = 3813 lbs
	Shear _{MAX} = 9857 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4300 lbs
	Tens _{MAX} = 2104 lbs
	Shear _{MAX} = 9857 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 2002.9 lbs
	Tens _{MAX} = 1270.9 lbs
	Shear _{MAX} = 985.7 lbs
# isolators: 3	
Longitudinal loading: (on short edge)	Comp _{MAX} = 2150.0 lbs
	Tens _{MAX} = 1052.0 lbs
	Shear _{MAX} = 985.7 lbs
# isolators: 2	

Max compression force on isolator: 2.150 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.271 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.986 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.271 k $d_b = 0.375$
 Shear = 0.986 k $d_b = 0.375$ in

Shear on curb rail:

$P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in
Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s) F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:


$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

$P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 Tension $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ (Table E3.4-1, AISI)
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 11.51$ ksi $f_v = 8.92$ ksi **O.K.**
 $F'_{nt} = 16.50$ ksi $F_{nv}/\Omega = 10.00$ ksi
 $P'_{nt}/\Omega = 0.810$ k **No Good - Use Welds**





Client:	ProVent PV2203	Base curb
Project:	CBISC-13 Iso Curb CBISCSAV2025	
Unit:	Sunchoice 20-25	

Base Curb Information

Hbase curb =	14 in	(Height of base curb)
Lcurb =	138.125 in	(Length of base curb)
wcurb =	83.125 in	(Width of base curb)
WGtbase =	605 lbs	(Weight of base curb)
# Springs long side =	3	# Springs short side = 2

Unit Information

WGtunit =	2640 lbs	(Oper. Weight of Unit + 5%)
Wt'max =	765 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	587 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	57.25 in	(Height of unit above curb)
H'cm =	38.625 in	(Hcm+10"*(upper+spring))
Lunit =	143.8125 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)
WGtunit+upper+base =	3350 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	9857 lbs	(0.7*Fpmax)
	(unit + upper rail)	
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2752 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	1698 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	2373 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	6600 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	4251 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	1011 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1761 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	4776 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	2427 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	207 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	957 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 6600 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 4251 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 4776 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2427 lbs	---> Along short edge of curb.


---> Negative values indicate opposite load.





Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**



Calculate Section Properties of Curb

A' = 14.000 in	a = 13.492 in = A' - (2r + t)
B' = 1.750 in	a' = 13.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r + t/2 + a(r + t/2)]
a = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2 + at/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = a[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = a[C' - t/2]
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.297 in (Distance between centroid and web centerline)	
Ix = 45.336 in ⁴	rx = 4.88 in
Iy = 0.610 in ⁴	ry = 0.566 in
A = 1.91 in ²	rmin = 0.566 in

Axial Compression

Pu = 4.929 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 7.751 k
Fe = 8.34 ksi
λc = 2.45
Fn = 7.32 ksi
Ly = 132.13 in
kyLy/ry = 187

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658 \lambda_c^2) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 137.66 ≤ 200	CR = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.5 ≤ 2.0	Cn = 0.02	
Pn = 4.578 k	R/t = 1.50 ≤ 9.0		

Long side: Pu_{Trans} = 2.200 k **O.K.** # clips = 3

Short side: Pu_{Long} = 2.388 k **O.K.** # clips = 2

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_n \sqrt{\frac{h}{t}}\right)$$

Check Web Stiffener N/A

width of stiffener = 7.000 in ts = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
w/ts = 118.675
1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc Ae = 0.380 in²
Pwc = 4.578 k
Pn = 16.511 k
Pn/Ωc = 9.712 k **Not Req'd**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 3007 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 3300 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs

of Bolts required for Tension = 1.2
of Bolts required for Shear = 2.7
of Bolts Used = 4.0

Check Combined Stress in Bolts & Inserts: 0.986 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in Pn/Ω = 1/Ω * 0.75tFu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu
Lreq'd = 1.564 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 6009 lbs Tens _{MAX} = 3813 lbs Shear _{MAX} = 9857 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4300 lbs Tens _{MAX} = 2104 lbs Shear _{MAX} = 9857 lbs

Max compression force on isolator: 2.150 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.271 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.986 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.635 k / bolt
 Shear = 0.493 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 3.966$ k $d / t = 4.92$
 $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 6.47$ ksi $f_v = 2.51$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 7146 lbs	Shear _{MAX} = 6015 lbs
Compression _{SEISMIC} =	9826 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) + (1 + 0.14S _{DS}) * WGT _{unit+upper+base} * wcurb / 2] / wcurb
Tension _{SEISMIC} =	7146 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) - (0.6 - 0.14S _{DS}) * WGT _{unit+upper+base} * wcurb / 2] / wcurb
Compression _{WIND} =	1561 lbs	= [F _{h ASD trans} * (H'cm + Hbase curb) + 0.6 * WGT _{unit+upper+base} * wcurb / 2 - F _{vert ASD} * wcurb / 2] / wcurb
Tension _{WIND} =	1924 lbs	= [F _{h ASD trans} * (H'cm + Hbase curb) - 0.6 * WGT _{unit+upper+base} * wcurb / 2 + F _{vert ASD} * wcurb / 2] / wcurb
Longitudinal:	Uplift _{MAX} = 4113 lbs	Shear _{MAX} = 6015 lbs
Compression _{SEISMIC} =	6793 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) + (1 + 0.14S _{DS}) * WGT _{unit+upper+base} * Lcurb / 2] / Lcurb
Tension _{SEISMIC} =	4113 lbs	= [F _{pmax} ASD * (H'cm + Hbase curb) - (0.6 - 0.14S _{DS}) * WGT _{unit+upper+base} * Lcurb / 2] / Lcurb
Compression _{WIND} =	465 lbs	= [F _{h ASD long} * (H'cm + Hbase curb) + 0.6 * WGT _{unit+upper+base} * Lcurb / 2 - F _{vert ASD} * Lcurb / 2] / Lcurb
Tension _{WIND} =	829 lbs	= [F _{h ASD long} * (H'cm + Hbase curb) - 0.6 * WGT _{unit+upper+base} * Lcurb / 2 + F _{vert ASD} * Lcurb / 2] / Lcurb



Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 1397 lbs	Vall _{metal} = 1230 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	9.40	COMBINED LOADING: 1.000 O.K.
# of Screws Req'd for Shear =	8.95	Req'd Min Spacing = 9.29 in o.c.
Total # of screws required =	15	

Use 15 - 1/4" φ x 4.5" Simpson SDS screws @ 9.3 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge)	Comp _{MAX} = 2002.9 lbs Tens _{MAX} = 1270.9 lbs Shear _{MAX} = 985.7 lbs
# isolators: 3	
Longitudinal loading: (on short edge)	Comp _{MAX} = 2150.0 lbs Tens _{MAX} = 1052.0 lbs Shear _{MAX} = 985.7 lbs
# isolators: 2	





Longitudinal:

of Screws Req'd for Uplift = 5.41 COMBINED LOADING: 0.974 O.K.
of Screws Req'd for Shear = 8.95 Screw Spacing = 9.39 in o.c.
Total # of screws required = 9

Use 9 - 1/4" φ x 4.5" Simpson SDS screws @ 9.4 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Transverse: Tall_{metal} = 2975 lbs Vall_{metal} = 3072 lbs
of Bolts Req'd for Uplift = 2.40 COMBINED LOADING: 0.989 O.K.
of Bolts Req'd for Shear = 2.72 Bolt Spacing = 42.04 in o.c.
Total # of bolts required = 4

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 42 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.38 COMBINED LOADING: 0.735 O.K.
of Bolts Req'd for Shear = 2.72 Bolt Spacing = 35.56 in o.c.
Total # of bolts required = 3

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 35.6 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = 14761 lbs Shear_{MAX} = 12030 lbs
Compression_{SEISMIC} = 17441 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 14761 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 12030 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 12.88 spacing = 10.51 in o.c. T_{applied} = 1054.4 lbs
Min Bolts Req'd Shear = 4.53 spacing = 31.53 in o.c. V_{applied} = 601.5 lbs

Try using 14 bolts spaced at 9.70 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$

Use 14 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 9.7 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 8696 lbs Shear_{MAX} = 12030 lbs

Compression_{SEISMIC} = 11376 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 8696 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 12030 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 7.59 spacing = 10.16 in o.c. T_{applied} = 1087.0 lbs
Min Bolts Req'd Shear = 4.53 spacing = 17.78 in o.c. V_{applied} = 601.5 lbs

Try using 6 bolts spaced at 14.23 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18$

Use 6 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 14.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-13 CBISCAV2025	Unit: Sunchoice 20-25
UPPER CURB RAIL THICKNESS: 0.1017 in		12 Gauge	
UNIT CLIP THICKNESS: 0.1017 in		12 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 5 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(3) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(2) - CQA Isolators short side
BASE CURB THICKNESS: 0.1017 in		12 Gauge	***Must weld top of CQA***
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use minimum 4 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	15 @ 9.29 in o.c.	4 @ 42.04 in o.c.	14 @ 9.7 in o.c.
SHORT DIRECTION	9 @ 9.39 in o.c.	3 @ 35.56 in o.c.	6 @ 14.23 in o.c.