



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-14 Series
CBISCSAV28 SERIES**



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.
 Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS SUNCHOICE UNITS

AV 28

PROVENT P/N	A	B	EST. WEIGHT
CBISCSAV2818**	8"	18"	653 Lbs
CBISCSAV2821**	11"	21"	698 Lbs
CBISCSAV2824**	14"	24"	748 Lbs

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
 CBC 2019
 IBC 2018

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799


SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CBISC-14
 DATE:
 4/20/2022

PART NUMBER:
 CBISCSAV28 SERIES
 REV:
 1
 DRAWN BY:
 FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-14 Iso Curb	CBISCSAV28
Unit:	Sunchoice 28	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	151.5 in	(Length of upper curb)
wcurb =	80.125 in	(Width of upper curb)
WGTupper =	112 lbs	(Weight of upper curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGTunit =	2720 lbs	(Oper. Weight of Unit)
Wtmax =	762 lbs	(Maximum corner weight)
Wtmin =	578 lbs	(Minimum corner weight)
Hunit =	57.22 in	(Height of unit above curb)
Hcm =	28.61 in	(Height to center of mass)
Lunit =	160.0625 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	9768 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 10170 lbs (unit + upper rail)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _h ASD trans =	2365 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _h ASD long =	1311 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert} ASD =	2642 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	5497 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3163 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	437 lbs	= [F _h ASD trans *Hcm + 2*0.6*Wtmax*wcurb - F _{vert} ASD *wcurb/2]/wcurb
Tension _{WIND} =	1472 lbs	= [F _h ASD trans *Hcm - 2*0.6*Wtmin*wcurb + F _{vert} ASD *wcurb/2]/wcurb

----> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	3854 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1520 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	-159 lbs	= [F _h ASD long *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert} ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	875 lbs	= [F _h ASD long *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert} ASD *Lcurb/2]/Lcurb

----> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} =	5497 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} =	3163 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} =	3854 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1520 lbs	----> Along short edge of curb.

----> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.500 in (0 if no lips)	b = 1.233 in = B' - [r+t/2+α(r+t/2)]
α = 0.500 (0 - no Lip; 1 w/ lip)	b' = 1.447 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.161 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.232 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.292 in (Distance between centroid and web centerline)	
I _x = 2.515 in ⁴	r _x = 2.04 in
I _y = 0.133 in ⁴	r _y = 0.470 in
A = 0.60 in ²	r _{min} = 0.470 in



Axial Compression

Pa = 4.884 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 4.957 k
F_e = 16.90 ksi $\lambda_c = \frac{F_y}{\sqrt{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.72 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 14.82 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 77.13 in Lateral unbraced length
k_yL_y/r_y = 131 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Long side: P_{uTrans} = 1.832 k **web stiffener REQ'D** # clips = 3
Short side: P_{uLong} = 1.927 k **web stiffener REQ'D** # clips = 2

Check Web Stiffener

16Ga x 1-3/16in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2542 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 2749 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 1.0
of Bolts required for Shear = 2.3
of Bolts Used = 4.0

Check Combined Stress in Bolts & Inserts: 0.825 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 1.858 in



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.1017$ in (clip thickness)	$t_2/t_1 = 0.7$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	

For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755 \#$
 $P_{ss}/\Omega = 540 \#$ <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 3.718$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249 \#$ <- Controls
 $P_{ts}/\Omega = 820 \#$ (full tensile screw capacity)


For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377 \#$
 $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.884	3	1.63	540 #	4	2.00 in
Short side:	4.884	2	2.44	540 #	5	1.50 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

$F_y = 50$ ksi
 $A_{gv} = 0.661$ in²
 $R_n/\Omega = 12.372$ k
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.574$ in²
 $A_{nt} = 0.117$ in²
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 6197 lbs
	Tens _{MAX} = 3932 lbs
	Shear _{MAX} = 10170 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4158 lbs
	Tens _{MAX} = 1892 lbs
	Shear _{MAX} = 10170 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 2065.8 lbs
	Tens _{MAX} = 1310.6 lbs
	Shear _{MAX} = 1017.0 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 2078.8 lbs
	Tens _{MAX} = 946.0 lbs
	Shear _{MAX} = 1017.0 lbs

Max compression force on isolator: 2.079 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.311 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 1.017 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.311 k $d_b = 0.375$
 Shear = 1.017 k $t = 0.0713$ in

Shear on curb rail:

$P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$

Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt:

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 11.87$ ksi $f_v = 9.21$ ksi **O.K.**

$P'_{nt}/\Omega = 0.754$ k **No Good - Use Welds** $F'_{nt} = 15.36$ ksi $F_{nv}/\Omega = 10.00$ ksi

Longitudinal weld loading:


$L = 1.5 P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 14.75$ $t = 0.1017$ in $P_n/\Omega = 3.315$ k

Transverse weld loading:

$L = 1$ $F_u = 65$ ksi $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$

$P_n/\Omega = 2.813$ k






Client:	ProVent PV2203	Base curb
Project:	CBISC-14 Iso Curb CBISCSAV28	
Unit:	Sunchoice 28	

Base Curb Information

Hbase curb =	14 in	(Height of base curb)
Lcurb =	154.5 in	(Length of base curb)
wcurb =	83.125 in	(Width of base curb)
WGtbase =	636 lbs	(Weight of base curb)
# Springs long side =	3	# Springs short side = 2

Unit Information

WGtunit =	2720 lbs	(Oper. Weight of Unit + 5%)
Wt'max =	790 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	606 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	57.22 in	(Height of unit above curb)
H'cm =	38.61 in	(Hcm+10" (upper+spring))
Lunit =	160.0625 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)
WGtunit+upper+base =	3468 lbs	(Total weight)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	10170 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 12454 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	3062 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	1698 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	2642 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	6807 lbs	= [FpmaxASD*H'cm + 2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	4383 lbs	= [FpmaxASD*H'cm - 2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	1049 lbs	= [Fh ASD trans *H'cm + 2*0.6*Wt'max*wcurb - Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	2016 lbs	= [Fh ASD trans *H'cm - 2*0.6*Wt'min*wcurb + Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	4625 lbs	= [FpmaxASD*H'cm + 2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	2201 lbs	= [FpmaxASD*H'cm - 2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	51 lbs	= [Fh ASD long *H'cm + 2*0.6*Wt'max*Lcurb - Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	1018 lbs	= [Fh ASD long *H'cm - 2*0.6*Wt'min*Lcurb + Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 6807 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 4383 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 4625 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2201 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**

Calculate Section Properties of Curb

A' = 14.000 in	a = 13.492 in = A' - (2r + t)
B' = 1.750 in	a' = 13.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r + t/2 + a(r + t/2)]
a = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2 + at/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = a[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = a[C' - t/2]
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.297 in (Distance between centroid and web centerline)	
I _x = 45.336 in ⁴	r _x = 4.88 in
I _y = 0.610 in ⁴	r _y = 0.566 in
A = 1.91 in ²	r _{min} = 0.566 in



Axial Compression

P_u = 5.085 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 6.135 k
F_e = 6.61 ksi λ_c = 2.75 λ_c = √(F_y/F_e) F_e = π²E / (kl/r)²
λ_c = 2.75 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 5.79 ksi If λ_c > 1.5; F_n = 0.877 / λ_c² F_y
L_y = 148.50 in Lateral unbraced length
k_yL_y/r_y = 210 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 137.66 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.5 ≤ 2.0	C _n = 0.02	
P _n = 4.578 k	R/t = 1.50 ≤ 9.0		

P_n/Ω_w = 2.616 k
Long side: P_{uTrans} = 2.269 k **O.K.** # clips = 3
Short side: P_{uLong} = 2.312 k **O.K.** # clips = 2

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_n \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

N/A
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.578 k
P_n = 16.511 k
P_n/Ω_c = 9.712 k **Not Req'd**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 3113 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 3403 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 1.3
of Bolts required for Shear = 2.8
of Bolts Used = 5.0
Check Combined Stress in Bolts & Inserts: 0.815 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in P_n/Ω = 1/Ω * 0.75tL F_u ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u
L_{req'd} = 1.613 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 6197 lbs Tens _{MAX} = 3932 lbs Shear _{MAX} = 10170 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 4158 lbs Tens _{MAX} = 1892 lbs Shear _{MAX} = 10170 lbs

Max compression force on isolator: 2.079 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.311 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 1.017 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.655 k / bolt
 Shear = 0.508 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 3.966$ k

$d/t = 4.92$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 6.67$ ksi $f_v = 2.59$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 7395 lbs	Shear _{MAX} = 6227 lbs
Compression _{SEISMIC} =	10169 lbs	= [F _{pmax} ASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Tension _{SEISMIC} =	7395 lbs	= [F _{pmax} ASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Compression _{WIND} =	1658 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	2218 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb
Longitudinal:	Uplift _{MAX} = 3754 lbs	Shear _{MAX} = 6227 lbs
Compression _{SEISMIC} =	6528 lbs	= [F _{pmax} ASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Tension _{SEISMIC} =	3754 lbs	= [F _{pmax} ASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Compression _{WIND} =	298 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	859 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb



Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 1397 lbs	Vall _{metal} = 1230 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	9.73	COMBINED LOADING: 0.979 O.K.
# of Screws Req'd for Shear =	9.27	Req'd Min Spacing = 9.77 in o.c.
Total # of screws required =	16	

Use 16 - 1/4" φ x 4.5" Simpson SDS screws @ 9.8 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge)	Comp _{MAX} = 2065.8 lbs Tens _{MAX} = 1310.6 lbs Shear _{MAX} = 1017.0 lbs
# isolators: 3	
Longitudinal loading: (on short edge)	Comp _{MAX} = 2078.8 lbs Tens _{MAX} = 946.0 lbs Shear _{MAX} = 1017.0 lbs
# isolators: 2	





Longitudinal:

of Screws Req'd for Uplift = 4.94 COMBINED LOADING: 0.919 O.K.
of Screws Req'd for Shear = 9.27 Screw Spacing = in o.c.
Total # of screws required =

Use 9 - 1/4" φ x 4.5" Simpson SDS screws @ 9.4 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = lbs Vall_{bolt} = lbs
Transverse: Tall_{metal} = lbs Vall_{metal} = lbs
of Bolts Req'd for Uplift = 2.49 COMBINED LOADING: 0.850 O.K.
of Bolts Req'd for Shear = 2.82 Bolt Spacing = in o.c.
Total # of bolts required =

Use 5 - 1/2" φ A307 Bolts to steel angle below deck @ 35.6 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.26 COMBINED LOADING: 0.605 O.K.
of Bolts Req'd for Shear = 2.82 Bolt Spacing = in o.c.
Total # of bolts required =

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 35.6 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = lbs Shear_{MAX} = lbs
Compression_{SEISMIC} = 18051 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 15277 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 12454 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 13.33 spacing = 10.96 in o.c. T_{applied} = 1091.2 lbs
Min Bolts Req'd Shear = 4.69 spacing = 35.63 in o.c. V_{applied} = 622.7 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.19$

Use 14 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 11 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = lbs Shear_{MAX} = lbs

Compression_{SEISMIC} = 10769 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 7994 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 12454 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 6.98 spacing = 11.85 in o.c. T_{applied} = 999.3 lbs
Min Bolts Req'd Shear = 4.69 spacing = 17.78 in o.c. V_{applied} = 622.7 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.11$

Use 6 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 14.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-14 CBISCAV28	Unit: Sunchoice 28
UPPER CURB RAIL THICKNESS: 0.0713 in		14 Gauge	
UNIT CLIP THICKNESS: 0.1017 in		12 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 5 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(3) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(2) - CQA Isolators short side
BASE CURB THICKNESS: 0.1017 in		12 Gauge	***Must weld top of CQA***
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use minimum 5 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	16 @ 9.77 in o.c.	5 @ 35.63 in o.c.	14 @ 10.96 in o.c.
SHORT DIRECTION	9 @ 9.39 in o.c.	3 @ 35.56 in o.c.	6 @ 14.23 in o.c.