




**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
619-727-4800

**Structural Calculations**  
**for**  
**CBISC-15 Series**  
CBISCSEL2835\*\* SERIES




**Prepared for:**  
**PROVENT / RRS**  
**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: March 2, 2023**  
**Project Number: PV2304**

**STEEL ATTACHMENT**

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



**NO. OF ANCHORAGE BOLTS REQUIRED**

CURB	LONG SIDE	SHORT SIDE
SEL2835	7 @ 27.57" O.C.	4 @ 24.23" O.C.

**ASSUMES:**

CONC SLAB  
 $f'_c = 4000\text{PSI}$  MINIMUM  
 6" MIN THICKNESS  
 NORMAL WEIGHT CONCRETE


Meets seismic requirements for the following codes:  
 CBC 2022  
 IBC 2021

ROOF ANCHORAGE DETAIL

CBISC Series

SEL2835

**CONCRETE ATTACHMENT**




SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø HAS THREADED ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4-1/2" EMBED (MIN. 9-1/16" EDGE DISTANCE)

**NO. OF ANCHORAGE BOLTS REQUIRED**

CURB	LONG SIDE	SHORT SIDE
SEL2835	16 @ 11.03" O.C.	8 @ 10.38" O.C.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
 \*\* CENTERED.

**WOOD ATTACHMENT**



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø x 4.5" SIMPSON SDS SCREWS W/ 2.75" THREADED EMBED (SGMIN=0.50)

**NO. OF ANCHORAGE SCREWS REQUIRED**

CURB	LONG SIDE	SHORT SIDE
SEL2835	26 @ 6.78" O.C.	13 @ 6.39" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
 MIRA LOMA, CA 91752

PHONE (951) 685-1101  
 FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_  
 JOB NAME: \_\_\_\_\_  
 EQUIPMENT: \_\_\_\_\_  
 NOTES: \_\_\_\_\_

FORM NO:

CB-63

DATE:  
 1/31/2023

REV:  
 2

DRAWN BY:  
 JG

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-63.  
 Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

## VIBRATION ISOLATION ROOF CURBS YORK UNITS

SUN SELECT 28-35 TON


PROVENT P/N	A	B	EST. WEIGHT
CBISCSEL283518**	8"	18"	587 Lbs
CBISCSEL283521**	11"	21"	632 Lbs
CBISCSEL283524**	14"	24"	682 Lbs
CBISCSEL283528**	18"	28"	807 Lbs

### FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

### NOTES


- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.





\*\*Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:  
 CBC 2022  
 IBC 2021

ATTACH TO CURB WITH (4) #10 TEK SCREWS EACH SIDE



**PROFILE DETAIL**



3847 WABASH DRIVE  
MIRA LOMA, CA 91752

PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_  
 JOB NAME: \_\_\_\_\_  
 EQUIPMENT: \_\_\_\_\_  
 NOTES: \_\_\_\_\_

FORM NO:  
CBISC-15

DATE:  
1/31/2023

PART NUMBER:  
CBISCSEL2835 SERIES

REV: -  
DRAWN BY: JG




Client:	ProVent PV	Upper curb rail
Project:	CBISC-15 Iso Curb CBISCSEL2835	
Unit:	Sun Select 28-35 Ton	

**Upper Curb Information**

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	177.4375 in	(Length of upper curb)
wcurb =	84.6875 in	(Width of upper curb)
WGtUpper =	140 lbs	(Weight of upper curb)
# Clips long side =	3	
# Clips short side =	2	

**Unit Information**

WGtUnit =	4191 lbs	(Oper. Weight of Unit)
Wtmax =	1207 lbs	(Maximum corner weight)
Wtmin =	897 lbs	(Minimum corner weight)
Hunit =	70 in	(Height of unit above curb)
Hcm =	35 in	(Height to center of mass)
Lunit =	180 in	(Length of unit)
Wunit =	90 in	(Width of unit)



**Seismic Loading - 2021 IBC/2022 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	15050 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 15553 lbs
		(unit + upper rail)

**Wind Loading - 2021 IBC/2022 CBC**

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr (horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr (vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	3201 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1600 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	3632 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Upper Curb Loading**

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	9404 lbs	= [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	5716 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*wcurb]/wcurb
Compression <sub>WIND</sub> =	955 lbs	= [Fh ASD trans *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	2062 lbs	= [Fh ASD trans *Hcm-2*0.6*Wtmin*wcurb+Fvert ASD *wcurb/2]/wcurb

---> Negative values indicate opposite load.

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	6153 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	2465 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S <sub>DS</sub> )*Wtmin*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	-52 lbs	= [Fh ASD long *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	1055 lbs	= [Fh ASD long *Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

**Governing Reactions:**

<b>Transverse:</b>		
(on long edge)	Comp <sub>MAX</sub> = 9404 lbs	---> Along long edge of curb.
	Tens <sub>MAX</sub> = 5716 lbs	---> Along long edge of curb.
<b>Longitudinal:</b>		
(on short edge)	Comp <sub>MAX</sub> = 6153 lbs	---> Along short edge of curb.
	Tens <sub>MAX</sub> = 2465 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




**Curb Design**

Fy = 50 ksi      Fu = 65 ksi  
E = 29500 ksi      t = 0.0713 14 Gauge

**Calculate Section Properties of Curb**

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 2.000 in	a' = 5.429 in = A' - t
C' = 0.500 in (0 if no lips)	b = 1.733 in = B' - [r+t/2+α(r+t/2)]
α = 0.500 (0 - no Lip; 1 w/ lip)	b' = 1.947 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.161 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.232 in = α(C' - t/2)
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.454 in (Distance between centroid and web centerline)	
Ix = 3.041 in <sup>4</sup>	rx = 2.13 in
Iy = 0.283 in <sup>4</sup>	ry = 0.649 in
A = 0.67 in <sup>2</sup>	rmin = 0.649 in



**Axial Compression**

Pa = 7.525 k (Max Axial Comp)      Ωc = 1.80  
Pn/Ωc = 9.178 k  
Fe = 29.41 ksi       $\lambda_c = \sqrt{\frac{F_y}{F_e}}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$   
λc = 1.30       $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$       If λc ≤ 1.5;  $F_n = (0.658\lambda_c^2) F_y$   
Fn = 24.54 ksi      If λc > 1.5;  $F_n = \frac{0.877}{\lambda_c^2} F_y$   
Ly = 80.69 in      Lateral unbraced length  
kyLy/ry = 100      (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 5.5 in      -- Check limits:      C = 7.50  
t = 0.0713 in      h/t = 77.14 ≤ 200      CR = 0.08  
N = 7.00      N/t = 98.18 ≤ 210      CN = 0.12  
Ωw = 1.75      N/h = 1.273 ≤ 2.0      Ch = 0.048  
Pn = 1.947 k      R/t = 1.50 ≤ 12.0  
Pn/Ωw = 1.112 k       $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$   
Long side: P<sub>Utrans</sub> = 3.135 k      **web stiffener REQ'D**      # clips = 3  
Short side: P<sub>Ulong</sub> = 3.077 k      **web stiffener REQ'D**      # clips = 2

**Check Web Stiffener**

16Ga x 1-3/16in x 6in (C-channel)      Pn = 0.7(P<sub>wc</sub> + AeFy) ≥ Pwc  
width of stiffener = 6.000 in      ts = 0.0566 16 Gauge      Pwc = 1.947 k  
web of stiff. w = 5.717 in      Rs = 0.0849 in      Pn = 12.688 k  
\*\*\*Check w/ts ≤ 1.28√E/Fys      Ωc = 1.70      Ae = 0.324 in<sup>2</sup>  
w/ts = 101.007  
1.28√(E/Fys) = 31.091      --> w/ts over limit      Use C3.7.2      Pn/Ωc = 7.464 k      **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

Tcrnmax = 3888 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
Vcrnmax = 4702 lbs      Max(Tens/2 -OR- Comp/2 corner connections per side)  
Bolt: Tall = 2480 lbs      Vall = 1208 lbs  
Threaded Insert: Tall = 2860 lbs      Vall = 1536 lbs  
# of Bolts required for Tension = 1.6  
# of Bolts required for Shear = 3.9  
# of Bolts Used = 5.0  
Check Combined Stress in Bolts & Inserts: 1.092      **N.G. --> USE WELDED CORNER CONNECTION**

**Check welded connection**

<--- USE WELD      Ω = 2.35  
Assume L/t > 25: 25\*t = 1.783 in      Pn/Ω =  $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$       L<sub>req'd</sub> =  $\frac{V_{req} \Omega}{0.75 t F_u}$   
L<sub>req'd</sub> = 3.179 in



<b>Connection Unit to Curb Clip</b>	#12 SMS screw	$\Omega = 3.0$
$t_1 = 0.1017$ in (clip thickness)	$t_2/t_1 = 0.7$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.216$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	

For $t_2/t_1 \leq 1.0$ :	$P_{ns} = 2416$ #	For $t_2/t_1 \geq 2.5$ :	$P_{ns} = 2703$ #
<b>Shear:</b> $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$	2.42 k		
<b>Tension:</b> $P_{ns} = 2.7t_1dF_{u1}$	3.86 k	$P_{ns} = 2.7t_1dF_{u1}$	3.86 k
$P_{ns} = 2.7t_2dF_{u2}$	2.70 k	$P_{ns} = 2.7t_2dF_{u2}$	2.70 k
$P_{ns}/\Omega = 805$ # <- Controls			
$P_{ss}/\Omega = 840$ #		$P_{not} = 0.85t_c d F_{u2}$	
$P_{not} = 0.851$ k (screw pull-out strength)		$t_c = \min(t_1, t_2)$	
$P_{nov} = 3.718$ k (screw pull-over strength)		$P_{nov} = 1.5t_1 d_w F_{u1}$	
$P_{ts}/\Omega = 284$ # <- Controls			
$P_{ts}/\Omega = 845$ #	(full tensile screw capacity)		

	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
Long side:	7.525	3	2.51	805 #	4	2.00 in
Short side:	7.525	2	3.76	805 #	5	1.50 in

clip width (in) = 7.00  
min spacing = 0.65 in


clip height = 2.5 in  
edge distance = 0.5 in (min. 1.5d)  
thinnest part = 0.0713 AISI BSR applies

Check Block shear rupture: O.K.

$F_y = 50$  ksi  
 $A_{gv} = 0.661$  in<sup>2</sup>  
 $R_n/\Omega = 12.334$  k

$\Omega = 2.22$  bolt/screw connection  
 $A_{nv} = 0.562$  in<sup>2</sup>  
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$   
(AISI Sect. E5.3)

Ant = 0.116 in<sup>2</sup>



**BSR O.K.**

**Curb Loads** (copied from above)

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> = 10294 lbs
	Tens <sub>MAX</sub> = 6830 lbs
	Shear <sub>MAX</sub> = 15553 lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> = 6407 lbs
	Tens <sub>MAX</sub> = 2942 lbs
	Shear <sub>MAX</sub> = 15553 lbs

**Loads at each Isolator**

Type: CQA

<b>Transverse loading:</b> (on long edge)	Comp <sub>MAX</sub> = 1715.7 lbs
	Tens <sub>MAX</sub> = 1138.3 lbs
# isolators: 6	Shear <sub>MAX</sub> = 777.6 lbs
<b>Longitudinal loading:</b> (on short edge)	Comp <sub>MAX</sub> = 1601.7 lbs
	Tens <sub>MAX</sub> = 735.5 lbs
# isolators: 4	Shear <sub>MAX</sub> = 777.6 lbs

Max compression force on isolator: 1.716 k ≤ 3.176 k **O.K.**  
Max uplift on isolator: 1.138 k ≤ 3.176 k **O.K.**  
Max shear on isolator: 0.778 k ≤ 1.163 k **O.K.**

**Forces on top bolt:**

Tension = 1.138 k  $d_b = 0.375$  in  
Shear = 0.778 k upper rail,  $t = 0.0713$  in

**Shear on curb rail:**  $P_n = teF_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)

**Shear O.K.**  $P_n/\Omega = 4.635$  k  $e = 1.0$  in

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$  k  $A_n = 0.116$  in

**N.S.R. O.K.**  $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$  ksi

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$  k  $d/t = 5.26$

**Bearing O.K.**  $C = 3.00$   $mf = 1.00$

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 40.5$  ksi  $A_b = 0.1104$  in<sup>2</sup>  
 $P_{nt}/\Omega = 1.988$  k **Bolt tension O.K.**  $\Omega t = 2.25$  (Table E3.4-1, AISI)

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 24.0$  ksi  $\Omega v = 2.40$  (Table E3.4-1, AISI)  
 $P_{nv}/\Omega = 1.104$  k **Bolt shear O.K.**


**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 10.31$  ksi  $f_v = 7.04$  ksi **O.K.**  
 $F'_{nt} = 24.13$  ksi  $F_{nv}/\Omega = 10.00$  ksi

$P'_{nt}/\Omega = 1.185$  k **Combined O.K.**

Longitudinal weld loading:  $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$   $\Omega = 2.55$   
If  $L/t < 25$ :  $L/t = 14.75$   $t = 0.1017$   $P_n/\Omega = 3.315$  k

Transverse weld loading:  $t = 0.1017$   $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$   $\Omega = 2.35$   
 $L = 1$   $F_u = 65$  ksi  $P_n/\Omega = 2.813$  k






Client:	ProVent PV	Base curb
Project:	CBISC-15 Iso Curb	CBISCSEL2835
Unit:	Sun Select 28-35 Ton	

**Base Curb Information**

Hbase curb =	18	in	(Height of base curb)
Lcurb =	177.4375	in	(Length of base curb)
wcurb =	84.6875	in	(Width of base curb)
WGTbase =	667	lbs	(Weight of base curb)
# Springs long side =	6		
# Springs short side =	4		

**Unit Information**

WGUnit =	4191	lbs	(Oper. Weight of Unit + 5%)
Wt'max =	1242	lbs	(Wtmax+1/4*WGUpper)
Wt'min =	932	lbs	(Wtmin+1/4*WGUpper)
Hunit =	70	in	(Height of unit above curb)
H'cm =	45	in	(Hcm+10"(upper+spring))
Lunit =	180	in	(Length of unit)
Wunit =	90	in	(Width of unit)
WGUnit+upper+base =	4998	lbs	(Total weight)



**Seismic Loading - 2021 IBC/2022 CBC**

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss) ap = 2.5
Sds =	2.280	(2/3*Sms) Rp = 2
Fpmax =	5.130	Wp
FpmaxASD =	15553	lbs
		(unit + upper rail)
		FpmaxASD = 17948 lbs
		(unit + upper rail + base curb)

**Wind Loading - 2021 IBC/2022 CBC**

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr <sub>(horiz)</sub> =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr <sub>(vert)</sub> =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8	psf = 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-16)
F <sub>h ASD trans</sub> =	4155	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
F <sub>h ASD long</sub> =	2077	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
F <sub>vert ASD</sub> =	3632	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Base Curb Loading**

<b>Transverse:</b>	
Compression <sub>SEISMIC</sub> =	11541 lbs = [FpmaxASD*H'cm+2*(1+0.14S <sub>DS</sub> )*Wt'max*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	7741 lbs = [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*wcurb]/wcurb
Compression <sub>WIND</sub> =	1882 lbs = [F <sub>h ASD trans</sub> *H'cm+2*0.6*Wt'max*wcurb-F <sub>vert ASD</sub> *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	2905 lbs = [F <sub>h ASD trans</sub> *H'cm-2*0.6*Wt'min*wcurb+F <sub>vert ASD</sub> *wcurb/2]/wcurb

---> Negative values indicate opposite load.

<b>Longitudinal:</b>	
Compression <sub>SEISMIC</sub> =	7221 lbs = [FpmaxASD*H'cm+2*(1+0.14*S <sub>DS</sub> )*Wt'max*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	3421 lbs = [FpmaxASD*H'cm-2*(0.6-0.14S <sub>DS</sub> )*Wt'min*Lcurb]/Lcurb
Compression <sub>WIND</sub> =	201 lbs = [F <sub>h ASD long</sub> *H'cm+2*0.6*Wt'max*Lcurb-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	1224 lbs = [F <sub>h ASD long</sub> *H'cm-2*0.6*Wt'min*Lcurb+F <sub>vert ASD</sub> *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

**Governing Reactions:**

Transverse:	Comp <sub>MAX</sub> =	11541	lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> =	7741	lbs	---> Along long edge of curb.
Longitudinal:	Comp <sub>MAX</sub> =	7221	lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> =	3421	lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




**Curb Design**

Fy = 50 ksi Fu = 65 ksi  
E = 29500 ksi t = 0.1017 **12 Gauge**

**Calculate Section Properties of Curb**

A' = 18.000 in	a = 17.492 in = A' - (2r+t)
B' = 1.750 in	a' = 17.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r+t/2+α(r+t/2)]
α = 1.000 (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2+αt/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.949 in = α(C' - t/2)
r' = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.244 in (Distance between centroid and web centerline)	
Ix = 86.495 in	rx = 6.12 in
Iy = 0.640 in	ry = 0.526 in
A = 2.31 in <sup>2</sup>	rmin = 0.526 in



**Axial Compression**

Pu = 7.776 k (Max Axial Comp) Ωc = 1.80  
 Pn/Ωc = 6.432 k  
 Fe = 5.71 ksi  
 λc = 2.96  
 Fn = 5.01 ksi  
 Ly = 148.50 in  
 kvLp/rp = 226

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$   $F_e = \frac{\pi^2 E}{(kl/r)^2}$

If λc ≤ 1.5; Fn = (0.658λc<sup>2</sup>)Fy  
 If λc > 1.5; Fn =  $\frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length (assume k=0.8)

**Compression Check = N.G.**

**Check Web Crippling**

h = 18 in -- Check limits: C = 4.00  
 t = 0.1017 in h/t = 176.99 ≤ 200 CR = 0.14  
 N = 7.00 N/t = 68.83 ≤ 210 CN = 0.35  
 Ωw = 1.75 N/h = 0.388889 ≤ 2.0 CH = 0.02  
 Pn = 4.390 k R/t = 1.50 ≤ 9.0  
 Pn/Ωw = 2.509 k  
 Long side: PuTrans = 3.847 k **web stiffener REQ'D** # clips = 3  
 Short side: PuLong = 3.611 k **web stiffener REQ'D** # clips = 2

$P_n = C t^2 F_y \sin(90) \left( 1 - C_R \sqrt{\frac{R}{t}} \right) \left( 1 + C_N \sqrt{\frac{N}{t}} \right) \left( 1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, one flange, end loading)

**Check Web Stiffener**

16Ga x 1.5in x 6in (C-channel) Pn = 0.7(Pwc + AeFy) ≥ Pwc  
 width of stiffener = 6.000 in ts = 0.0566 **16 Gauge** Pwc = 4.390 k  
 web of stiff. w = 5.717 in Rs = 0.0849 in Pn = 14.398 k  
 \*\*\*Check w/ts ≤ 1.28vE/Fys Ωc = 1.70 Ae = 0.324 in<sup>2</sup>  
 w/ts = 101.007  
 1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2 Pn/Ωc = 8.470 k **O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

Tcrnmax = 4487 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)  
 Vcrnmax = 5771 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)  
 Bolt: Tall = 2480 lbs Vall = 1208 lbs  
 Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs  
 # of Bolts required for Tension = 1.8  
 # of Bolts required for Shear = 4.8  
 # of Bolts Used = 7.0  
 Check Combined Stress in Bolts & Inserts: 0.941 **O.K.**

**Check 1/8" welded connection**

Assume L/t > 25: 25\*t = 2.543 in Ω = 2.35  
 Lreq'd = 2.735 in  $P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$   $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$





**Curb Loads** (copied from upper rail calcs)

<b>Transverse:</b> (on long edge)	Comp <sub>MAX</sub> = 10294 lbs Tens <sub>MAX</sub> = 6830 lbs Shear <sub>MAX</sub> = 15553 lbs
<b>Longitudinal:</b> (on short edge)	Comp <sub>MAX</sub> = 6407 lbs Tens <sub>MAX</sub> = 2942 lbs Shear <sub>MAX</sub> = 15553 lbs

**Loads at each Isolator** Type: **CQA**

<b>Transverse loading:</b> (on long edge)	Comp <sub>MAX</sub> = 1715.7 lbs Tens <sub>MAX</sub> = 1138.3 lbs Shear <sub>MAX</sub> = 777.6 lbs
# isolators: 6	
<b>Longitudinal loading:</b> (on short edge)	Comp <sub>MAX</sub> = 1601.7 lbs Tens <sub>MAX</sub> = 735.5 lbs Shear <sub>MAX</sub> = 777.6 lbs
# isolators: 4	

Max compression force on isolator: 1.716 k ≤ 3.176 k **O.K.**  
 Max uplift on isolator: 1.138 k ≤ 3.176 k **O.K.**  
 Max shear on isolator: 0.778 k ≤ 1.163 k **O.K.**

**Forces on bottom bolts:**

$d_b = 0.5$  in  
 base curb,  $t = 0.1017$  in  
 Tension = 0.569 k / bolt  
 Shear = 0.389 k / bolt

**Shear on base curb:**  $P_n = teF_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n/\Omega = 6.611$  k  $e = 1.0$  in

**Shear O.K.**

**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n/\Omega = 8.428$  k  $A_n = 0.153$  in

**N.S.R. O.K.**

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n/\Omega = 3.966$  k  $d/t = 4.92$

**Bearing O.K.**



**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt}/\Omega = 3.927$  k **Bolt tension O.K.**  $\Omega t = 2.25$

Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$   
 $P_{nv}/\Omega = 2.209$  k **Bolt shear O.K.** **\*\*\* (Table E3.4-1, AISI) \*\*\***

**Combined Shear and tension in bolt:**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_t = 5.80$  ksi  $f_v = 1.98$  ksi  
 $F'_{nt} = 45.00$  ksi  $F_{nv}/\Omega = 11.25$  ksi  
 $P'_{nt}/\Omega = 3.927$  k **Combined Not Applicable -> F'nt = Fnt**



**Connection of Curb to Supporting Structure**

**Roof Loading** SEISMIC: (0.6-0.14S<sub>DS</sub>)D + 0.7E WIND: 0.6D + W

<b>Transverse:</b>	Uplift <sub>MAX</sub> = 12650 lbs	Shear <sub>MAX</sub> = 8974 lbs
Compression <sub>SEISMIC</sub> = 16648 lbs	=[FpmaxASD*(H'cm+Hbase curb)+(1+0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb	
Tension <sub>SEISMIC</sub> = 12650 lbs	=[FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *wcurb/2]/wcurb	
Compression <sub>WIND</sub> = 2774 lbs	=[F <sub>h ASD trans</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *wcurb/2-F <sub>vert ASD</sub> *wcurb/2]/wcurb	
Tension <sub>WIND</sub> = 3407 lbs	=[F <sub>h ASD trans</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *wcurb/2+F <sub>vert ASD</sub> *wcurb/2]/wcurb	
<b>Longitudinal:</b>	Uplift <sub>MAX</sub> = 5671 lbs	Shear <sub>MAX</sub> = 8974 lbs
Compression <sub>SEISMIC</sub> = 9669 lbs	=[FpmaxASD*(H'cm+Hbase curb)+(1+0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb	
Tension <sub>SEISMIC</sub> = 5671 lbs	=[FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S <sub>DS</sub> )*WGT <sub>unit+upper+base</sub> *Lcurb/2]/Lcurb	
Compression <sub>WIND</sub> = 421 lbs	=[F <sub>h ASD long</sub> *(H'cm+Hbase curb)+0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb	
Tension <sub>WIND</sub> = 1054 lbs	=[F <sub>h ASD long</sub> *(H'cm+Hbase curb)-0.6*WGT <sub>unit+upper+base</sub> *Lcurb/2+F <sub>vert ASD</sub> *Lcurb/2]/Lcurb	

**Wood Attachment:** 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

<b>Transverse:</b>	Tall <sub>metal</sub> = 1397 lbs	Vall <sub>metal</sub> = 1230 lbs
	Tall <sub>wood</sub> = 760 lbs	Vall <sub>wood</sub> = 672 lbs
# of Screws Req'd for Uplift = 16.64	COMBINED LOADING: 0.983 O.K.	
# of Screws Req'd for Shear = 13.35	Req'd Min Spacing = 6.78 in o.c.	
Total # of screws required = 26		

Use 26 - 1/4" φ x 4.5" Simpson SDS screws @ 6.8 in o.c. along long side of curb w/ 2.75" threaded embed



**Longitudinal:**

# of Screws Req'd for Uplift = 7.46  
 # of Screws Req'd for Shear = 13.35  
 Total # of screws required = **13**

COMBINED LOADING: 0.916 O.K.  
 Screw Spacing = **6.39** in o.c.

Use 13 - 1/4"  $\phi$  x 4.5" Simpson SDS screws @ 6.4 in o.c. along short side of curb w/ 2.75" threaded embed

**Steel Deck Attachment: 1/2"  $\phi$  A307 Bolts to steel angle below deck**

Tall<sub>bolt</sub> = **3927** lbs  
 Vall<sub>bolt</sub> = **2209** lbs  
 Tall<sub>metal</sub> = **2975** lbs  
 Vall<sub>metal</sub> = **3072** lbs

Transverse: # of Bolts Req'd for Uplift = 4.25  
 # of Bolts Req'd for Shear = 4.06  
 Total # of bolts required = **7**

COMBINED LOADING: 0.977 O.K.  
 Bolt Spacing = **27.57** in o.c.

Use 7 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 27.6 in o.c. along long side of curb

**Longitudinal:**

# of Bolts Req'd for Uplift = 1.91  
 # of Bolts Req'd for Shear = 4.06  
 Total # of bolts required = **4**

COMBINED LOADING: 0.642 O.K.  
 Bolt Spacing = **24.23** in o.c.

Use 4 - 1/2"  $\phi$  A307 Bolts to steel angle below deck @ 24.2 in o.c. along short side of curb

**For Concrete anchorage:** SEISMIC (0.6-0.14S<sub>DS</sub>)D + 0.7 $\Omega_o$ E  $\Omega_o = 2.0$

**Concrete Attachment: 5/8"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed**

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'c = **4000** psi  
 h = **6** in (concrete thickness, t<sub>min</sub> = h<sub>ef</sub> + 2do) O.K.  
 h<sub>ef</sub> = **4.5** in (effective embedment)  
 da = **0.625** in (anchor diameter) do = **0.75** in (hole diameter)  
 n = **3** (number of dummy anchors to check capacity with spacing effect)  
 s = **10.375** in (initial spacing estimate)  
 tk<sub>cr / uncr</sub> = **1170** / **2220** psi (from ESR 4868, Table 14, Temp range B)  
 tk<sub>cr / uncr</sub> = **1226** / **2327** psi If f'c > 2500, multiply by (f'c/2500)<sup>0.1</sup>  
 c<sub>N $\alpha$</sub>  = 9.0625 in (min. edge distance for full capacity); c<sub>N $\alpha$</sub>  = 10da $\sqrt{\frac{\tau_{uncr}}{1100}}$

**Tension:**  
 Bond strength  
 \*\*\*Bond strength  
 will govern over  
 concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 704.61 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 10727 \text{ lbs} \quad N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$N_{ag} = 23007 \text{ lbs (group)}$$

$$\phi N_{ag} = 11216 \text{ lbs (group)}$$

CONTROLS

$$\lambda_a = 1.0$$

$\lambda_a = 1.0$  for normal weight conc; 0.6 for lightw

**Breakout strength**

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'c} h_{ef}^{1.5}$$

$$A_{Nc} = 462.375 \text{ in}^2$$

$$N_b = 10264 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 182.25 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 26039 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 14647 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

**Shear:**

$$V_{sa,eq} = \mathbf{7865} \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

**Steel strength**

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 3739 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.708$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 2189 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1796 \text{ lbs} \quad (D = 0.758, E = 0.242)$$

Transverse: Uplift<sub>MAX</sub> = **26021** lbs      Shear<sub>MAX</sub> = **17948** lbs

$$\text{Compression}_{SEISMIC} = 29908 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 26021 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$


$$\text{Shear}_{SEISMIC} = 17948 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 11.89 \text{ spacing} = 15.04 \text{ in o.c.} \quad T_{applied} = 1626.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 10.00 \text{ spacing} = 18.38 \text{ in o.c.} \quad V_{applied} = 747.8 \text{ lbs}$$

Try using **16** bolts spaced at **11.03** in o.c.      COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$  O.K.

Use 16 - 5/8"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 11 in o.c. max. along long side of curb w/ 4.5in embed





# MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120  
(619)727-4800  
Page 8 of 8

<b>Longitudinal:</b>	Uplift <sub>MAX</sub> = 12063 lbs		Shear <sub>MAX</sub> = 17948 lbs	
Compression <sub>SEISMIC</sub> =	15949 lbs	=[ $\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+curb} * L_{curb} / 2$ ]/L <sub>curb</sub>		
Tension <sub>SEISMIC</sub> =	12063 lbs	=[ $\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+curb} * L_{curb} / 2$ ]/L <sub>curb</sub>		
Shear <sub>SEISMIC</sub> =	17948 lbs	= $\Omega_o * F_{pmaxASD} / 2$		
Min Bolts Req'd Uplift =	5.51 spacing =	14.54 in o.c.	T Applied = 1507.9 lbs	
Min Bolts Req'd Shear =	10.00 spacing =	8.08 in o.c.	V Applied = 747.8 lbs	
Try using	8 bolts	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.11$ O.K.		
spaced at	10.38 in o.c.			

Use 8 - 5/8"  $\phi$  HAS rods in Hilti HIT-HY 200 V3 epoxy @ 10.4 in o.c. max. along short side of curb w/ 4.5in embed

<b>CURB DESIGN SUMMARY:</b>		CBISC-15	CBISCSEL2835	<b>Unit:</b> Sun Select 28-35 Ton
<b>UPPER CURB RAIL THICKNESS:</b>		0.0713 in	14 Gauge	
<b>UNIT CLIP THICKNESS:</b>		0.1017 in	12 Gauge	
<b># OF CLIPS (LONG SIDE)</b> - 3 clips with 4 - #12 SMS screws each clip				
<b>WEB STIFFENER:</b> 16Ga x 1-3/16in x 6in (C-channel) stiffener at each clip				
<b># OF CLIPS (SHORT SIDE)</b> - 2 clips with 5 - #12 SMS screws each clip				
<b>WEB STIFFENER:</b> 16Ga x 1-3/16in x 6in (C-channel) stiffener at each clip				
<b>VIBRATION ISOLATOR TYPE:</b> CQA		Top stud diameter:	3/8	(6) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter:	9/16	(4) - CQA Isolators short side
<b>BASE CURB THICKNESS:</b> 0.1017 in		12 Gauge	---Bolt or Weld O.K.---	
<b>WEB STIFFENER:</b> 16Ga x 1.5in x 6in (C-channel) stiffener at each clip on base curb				
<b>CORNER CONNECTION:</b> Use minimum 7 - 1/4" $\phi$ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts				
<b>CURB ANCHORAGE</b>	<u>WOOD</u>	<u>STEEL</u>	<u>CONCRETE</u>	
	1/4" $\phi$ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" $\phi$ A307 Bolts to steel angle below deck	5/8" $\phi$ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed	
<b>LONG DIRECTION</b>	26 @ 6.78 in o.c.	7 @ 27.57 in o.c.	16 @ 11.03 in o.c.	
<b>SHORT DIRECTION</b>	13 @ 6.39 in o.c.	4 @ 24.23 in o.c.	8 @ 10.38 in o.c.	