



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISCSEL4050 Curb



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: November 26, 2024
Project Number: PV2403

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-63.
 Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS YORK UNITS

SUN SELECT 40-50 TON


PROVENT P/N	A	B	EST. WEIGHT
CBISCSEL405018**	8"	18"	810 Lbs
CBISCSEL405021**	11"	21"	863 Lbs
CBISCSEL405024**	14"	24"	913 Lbs
CBISCSEL405028**	18"	28"	1,038 Lbs

FEATURES

- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
 CBC 2022
 IBC 2021

ATTACH TO CURB WITH (4) #10 TEK SCREWS EACH SIDE

14 GA UPPER RAIL

UNIT BASE RAIL

ATTACH TO UNIT WITH
 (4) CLIPS EACH LONG SIDE w/
 (4) #12 SCREWS PER CLIP
 (3) CLIPS EACH SHORT SIDE w/
 (5) #12 SCREWS PER CLIP

14 GA UNIT HOLD DOWN
 (4) PER LONG SIDE
 (3) PER SHORT SIDE
 16 GAx1-3/16"x 6" CHAN.
 STIFF. AT EA. HOLD DOWN

CQA SPRING ISOLATOR
 (2) AT EACH HOLD DOWN
 FULL PERIMETER WOOD NAILER
 16GAx 1-1/2"x 6" CHANNEL
 STIFFENER AT EA SET OF SPRINGS
 12 GA. CURB

"B" TOTAL CURB HEIGHT

"A" BASE CURB HEIGHT

PROFILE DETAIL



3847 WABASH DRIVE
 MIRA LOMA, CA 91752

PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CBISC-16


DATE:
 11/20/2024

PART NUMBER:
 CBISCSEL4050 SERIES

REV:
 1

DRAWN BY:
 FMM


WELDMENT AND BOLTING DETAIL



OPTIONAL BOTTOM BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA/CQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT WITH FLAT WASHER AND NUT



Note: * - INDICATES WELD REQUIRED I.L.O. BOLTED STUD FOR THE FOLLOWING CURBS:

- LXL (CBISC-02)
- PRD3715 (CBISC-04)
- SAV1518 (CBISC-12)
- SAV2025 (CBISC-13)
- SAV28 (CBISC-14)
- SEL4050 (CBISC-16)



3847 WABASH DRIVE
MIRA LOMA, CA 91725


PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO: CB-61		
DATE: 11/21/24	REV: 3	DRAWN BY: FMM

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SEL2835	7 @ 27.57" O.C.	4 @ 24.23" O.C.
SEL4050	14 @ 16.23" O.C.	5 @ 17.17" O.C.

ASSUMES:

CONC SLAB
 f_c= 4000PSI MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE

Meets seismic requirements for the following codes:
 CBC 2022
 IBC 2021

ROOF ANCHORAGE DETAIL
CBISC Series
SEL2835
SEL4050

CONCRETE ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SEL2835	16 @ 11.03" O.C.	8 @ 10.38" O.C.
SEL4050	26 @ 8.44" O.C.	9 @ 8.59" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.


WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
SEL2835	26 @ 6.78" O.C.	13 @ 6.39" O.C.
SEL4050	40 @ 5.51" O.C.	15 @ 5.19" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO: CB-63
 DATE: 11/20/2024
 REV: 3
 DRAWN BY: FMM




Client:	ProVent PV2403	Upper curb rail
Project:	CBISC-16 Iso Curb CBISCSEL4050	
Unit:	SUN SELECT 40-50 TON	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	227 in	(Length of upper curb)
wcurb =	84.6875 in	(Width of upper curb)
WGTupper =	558 lbs	(Weight of upper curb)
# Clips long side =	4	# Clips short side = 3

Unit Information

WGTunit =	5984 lbs	(Weight of Unit)
Wtmax =	1646 lbs	(Maximum corner weight)
Wtmin =	1346 lbs	(Minimum corner weight)
Hunit =	77 in	(Height of unit above curb)
Hcm =	38.5 in	(Height to center of mass)
Lunit =	232 in	(Length of unit)
Wunit =	90 in	(Width of unit)



Seismic Loading - 2021 IBC/2022 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	21489 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 23492 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	4508 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1749 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	3883 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:		
Compression _{SEISMIC} =	14111 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	9013 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	2083 lbs	= [Fh ASD trans *Hcm + 2*0.6*Wtmax*wcurb - Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	2375 lbs	= [Fh ASD trans *Hcm - 2*0.6*Wtmin*wcurb + Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:		
Compression _{SEISMIC} =	7986 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	2888 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	330 lbs	= [Fh ASD long *Hcm + 2*0.6*Wtmax*Lcurb - Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	622 lbs	= [Fh ASD long *Hcm - 2*0.6*Wtmin*Lcurb + Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	14111 lbs	---> Along long edge of curb.
	Tens _{MAX} =	9013 lbs	---> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	7986 lbs	---> Along short edge of curb.
	Tens _{MAX} =	2888 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 2.000 in	a' = 5.429 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.644 in = B' - [r+t/2+α(r+t/2)]
α = 1.000 (0 - no Lip; 1 w/ lip)	b' = 1.929 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.822 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.964 in = α(C' - t/2)
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.657 in (Distance between centroid and web centerline)	
I _x = 3.543 in ⁴	r _x = 2.13 in
I _y = 0.482 in ⁴	r _y = 0.785 in
A = 0.782 in ²	r _{min} = 0.785 in



Axial Compression

Pa = 10.744 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 13.366 k
F_e = 43.07 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 1.08 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 30.76 ksi
L_y = 80.68 in Lateral unbraced length
k_yL_y/r_y = 82 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 260	C _R = 0.08	
N = 7.00	N/h = 98.18 ≤ 210	C _N = 0.12	
Ω _w = 1.75	N/h = 1.273 ≤ 2.0	C _h = 0.048	
P _n = 1.947 k	R/t = 1.50 ≤ 12.0		
P _n /Ω _w = 1.112 k			
Long side: P _U Trans = 3.528 k	web stiffener REQ'D # clips = 4		
Short side: P _U Long = 2.662 k	web stiffener REQ'D # clips = 3		

$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

Check Web Stiffener

16Ga x 1 3/16in x 6in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 6.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 5.717 in R_s = 0.0849 in P_n = 12.688 k
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70 A_e = 0.324 in²
w/t_s = 101.007
1.28√(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2 P_n/Ω_c = 7.464 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crn}max = 5873 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 7055 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 2.4
of Bolts required for Shear = 6.4
of Bolts Used = 9.0
Check Combined Stress in Bolts & Inserts: 0.978 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 4.770 in



Connection Unit to Curb Clip	#12 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (mech unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.216$ in (screw diameter)	$dw = 0.375$ in (nom. washer diameter)	

For $t_2/t_1 \leq 1.0$:	$P_{ns} = 2416$ #	For $t_2/t_1 \geq 2.5$:	$P_{ns} = 2703$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$	2.42 k		
Tension: $P_{ns} = 2.7t_1dF_{u1}$	2.70 k	$P_{ns} = 2.7t_1dF_{u1}$	2.70 k
$P_{ns} = 2.7t_2dF_{u2}$	2.70 k	$P_{ns} = 2.7t_2dF_{u2}$	2.70 k
$P_{ns}/\Omega = 805$ # <- Controls			
$P_{ss}/\Omega = 840$ #		$P_{not} = 0.85t_c dF_{u2}$	
$P_{not} = 0.851$ k (screw pull-out strength)		$t_c = \min(t_1, t_2)$	
$P_{nov} = 2.607$ k (screw pull-over strength)		$P_{nov} = 1.5t_1 d_w F_{u1}$	
$P_{ts}/\Omega = 284$ # <- Controls			
$P_{ts}/\Omega = 845$ #	(full tensile screw capacity)		

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	10.744	4	2.69	805 #	4	2.00 in
Short side:	10.744	3	3.58	805 #	5	1.50 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.65 in edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.463$ in² $A_{nv} = 0.394$ in² $A_{nt} = 0.081$ in²
 $R_n/\Omega = 8.647$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)

BSR O.K.

Curb Loads (copied from above)

Transverse:	Comp _{MAX} = 16521 lbs
(on long edge)	Tens _{MAX} = 11287 lbs
	Shear _{MAX} = 23492 lbs
Longitudinal:	Comp _{MAX} = 8869 lbs
(on short edge)	Tens _{MAX} = 3635 lbs
	Shear _{MAX} = 23492 lbs

Max compression force on isolator: 2.065 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.411 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.839 k ≤ 1.163 k **O.K.**

Forces on top bolt:

Tension = 1.411 k $d_b = 0.375$ in
 Shear = 0.839 k upper rail, t = 0.0713 in 7.0 in

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$ $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**



Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 12.77$ ksi $f_v = 7.60$ ksi O.K.
 $F'_{nt} = 21.88$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.074$ k **No Good - Use Welds**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$
 If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k





Client:	ProVent PV2403	Base curb
Project:	CBISC-16 Iso Curb	CBISCSEL4050
Unit:	SUN SELECT 40-50 TON	

Base Curb Information

Hbase curb =	25 in	(Height of base curb)
Lcurb =	223 in	(Length of base curb)
wcurb =	80.6875 in	(Width of base curb)
WGtbase =	480 lbs	(Weight of base curb)
# Springs long side =	4	# Springs short side = 3

Unit Information

WGtunit =	5984 lbs	(Weight of Unit)
Wt'max =	1785 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	1486 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	77 in	(Height of unit above curb)
H'cm =	48.5 in	(Hcm+10"(upper+spring))
Lunit =	232 in	(Length of unit)
Wunit =	90 in	(Width of unit)
WGtunit+upper+base =	7022 lbs	(Total weight)

Seismic Loading - 2021 IBC/2022CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	23492 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 25216 lbs
		(unit + upper rail + base curb)

Wind Loading - 2021 IBC/2022 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	6120 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	2374 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	3883 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	18831 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	13286 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	3880 lbs	= [Fh ASD trans *H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	3837 lbs	= [Fh ASD trans *H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	9819 lbs	= [FpmaxASD*H'cm+2*(1+0.14*S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	4275 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	717 lbs	= [Fh ASD long *H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	675 lbs	= [Fh ASD long *H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

<u>Transverse:</u> (on long edge)	Comp _{MAX} =	18831 lbs	---> Along long edge of curb.
	Tens _{MAX} =	13286 lbs	---> Along long edge of curb.
<u>Longitudinal:</u> (on short edge)	Comp _{MAX} =	9819 lbs	---> Along short edge of curb.
	Tens _{MAX} =	4275 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.






Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 12 Gauge

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.492 in = A' - (2r+t)
B' = 1.750 in	a' = 24.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r+t/2+α(r+t/2)]
α = 1.000 (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2+αt/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.949 in = α(C' - t/2)
r' = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.187 in (Distance between centroid and web centerline)	
I _x = 205.037 in ⁴	r _x = 8.23 in
I _y = 0.672 in ⁴	r _y = 0.471 in
A = 3.025 in ²	r _{min} = 0.471 in



Axial Compression

P_u = 11.746 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 20.428 k
F_e = 13.86 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.90
F_n = 12.16 ksi If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
L_y = 85.42 in If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
k_yL_y/r_y = 145 Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 245.82 ≤ 260	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _h = 0.02	
P _n = 4.106 k	R/t = 1.50 ≤ 9.0		

Long side: P_{uTrans} = 4.708 k **web stiffener REQ'D** # clips = 4
Short side: P_{uLong} = 3.273 k **web stiffener REQ'D** # clips = 3

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 1.5in x 6in (C-channel)
width of stiffener = 6.000 in ts = 0.0566 16 Gauge
web of stiff. w = 5.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28VE/F_{ys} Ω_c = 1.70
w/ts = 101.007
1.28V(E/F_{ys}) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 4.106 k A_e = 0.324 in²
P_n = 14.200 k
P_n/Ω_c = 8.353 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crnmax} = 6304 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 9415 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 2.5
of Bolts required for Shear = 8.6
of Bolts Used = 11.0
Check Combined Stress in Bolts & Inserts: 1.012 **N.G.- USE WELDS**

Check 1/8" welded connection

Assume L/t > 25: 25*t = 2.543 in Ω = 2.35
L_{req'd} = 4.463 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} = 16521 lbs Tens _{MAX} = 11287 lbs Shear _{MAX} = 23492 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 8869 lbs Tens _{MAX} = 3635 lbs Shear _{MAX} = 23492 lbs

Max compression force on isolator: 2.065 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.411 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.839 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.705 k / bolt
 Shear = 0.420 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 6.611$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 8.428$ k $A_n = 0.153$ in

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 3.966$ k $d/t = 4.92$

Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *** (Table E3.4-1, AISI) ***

Combined Shear and tension in bolt:
 $F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.19$ ksi $f_v = 2.14$ ksi
 $P'_{nt} / \Omega = 3.927$ k $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi
Combined Not Applicable -> $F'_{nt} = F_{nt}$

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E

WIND: 0.6D + W



Transverse:	Uplift _{MAX} = 21984 lbs	Shear _{MAX} = 12608 lbs
Compression _{SEISMIC} =	27602 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Tension _{SEISMIC} =	21984 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb
Compression _{WIND} =	5740 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	5410 lbs	= [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb
Longitudinal:	Uplift _{MAX} = 7325 lbs	Shear _{MAX} = 12608 lbs
Compression _{SEISMIC} =	12943 lbs	= [FpmaxASD*(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Tension _{SEISMIC} =	7325 lbs	= [FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb
Compression _{WIND} =	948 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	617 lbs	= [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded emb (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
	# of Screws Req'd for Uplift = 28.93	COMBINED LOADING: 0.999 O.K.
	# of Screws Req'd for Shear = 18.76	Req'd Min Spacing = 5.51 in o.c.
	Total # of screws required = 40	

Use 40 - 1/4" φ x 4.5" Simpson SDS screws @ 5.5 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator	Type:	CQA
Transverse loading: (on long edge)	Comp _{MAX} = 2065.1 lbs Tens _{MAX} = 1410.9 lbs Shear _{MAX} = 839.0 lbs	# isolators: 8
Longitudinal loading: (on short edge)	Comp _{MAX} = 1478.1 lbs Tens _{MAX} = 605.8 lbs Shear _{MAX} = 839.0 lbs	# isolators: 6





Longitudinal:

of Screws Req'd for Uplift = 9.64 COMBINED LOADING: 0.848 O.K.
 # of Screws Req'd for Shear = 18.76 Screw Spacing = 5.19 in o.c.
 Total # of screws required = 15

Use 15 - 1/4" φ x 4.5" Simpson SDS screws @ 5.2 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
 Tall_{metal} = 2086 lbs Vall_{metal} = 2192 lbs
 # of Bolts Req'd for Uplift = 10.54 COMBINED LOADING: 0.961 O.K.
 # of Bolts Req'd for Shear = 5.75 Bolt Spacing = 16.23 in o.c.
 Total # of bolts required = 14

Use 14 - 1/2" φ A307 Bolts to steel angle below deck @ 16.2 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 3.51 COMBINED LOADING: 0.804 O.K.
 # of Bolts Req'd for Shear = 5.75 Bolt Spacing = 17.17 in o.c.
 Total # of bolts required = 5


Use 5 - 1/2" φ A307 Bolts to steel angle below deck @ 17.2 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_o E Ω_o = 2.5

Concrete Attachment: 0.625in φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

f'_c = 4000 psi
 h = 6 in (concrete thickness, t_{min} = h_{ef} + 2c_o) O.K.
 h_{ef} = 4.5 in (effective embedment)
 d_a = 0.625 in (anchor diameter) d_o = 0.75 in (hole diameter)
 n = 5 (number of dummy anchors to check capacity with spacing effect)
 s = 8 in (initial spacing estimate)
 tk_{cr} / uncr = 1170 2220 psi (from ESR 4868, Table 14, Temp range B)
 tk_{cr} / uncr = 1226 2327 psi If f'_c > 2500, multiply by (f'_c/2500)^{0.1}
 c_{Na} = 9.0625 in (min. edge distance for full capacity); c_{Na} = 10d_a√ $\frac{\tau_{uncr}}{1100}$



Tension:

Bond strength
 ***Bond strength will govern over concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 908.52 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 10727 \text{ lbs} \quad N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$N_{ag} = 29666 \text{ lbs (group)}$$

$$\phi N_{ag} = 14462 \text{ lbs (group)}$$

CONTROLS

$$\lambda_a = 1.0$$

λ_a = 1.0 for normal weight conc; 0.6 for lightw

Breakout strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b$$

$$N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 614.25 \text{ in}^2$$

$$N_b = 10264 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 182.25 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 34592 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 19458 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = \text{7865 (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$Tall_{LRFD} = 2892 \text{ lbs (anchor)}$$

$$Vall_{LRFD} = 3067 \text{ lbs}$$

$$\alpha = (1 + 0.2SDS)D + 2.5E = 1.421$$

$$Tall_{ASD} = Tall_{LRFD} / \alpha = 1693 \text{ lbs}$$

$$Vall_{ASD} = Vall_{LRFD} / \alpha = 1795 \text{ lbs}$$

$$D = 0.758 \quad E = 2.42 \quad \alpha = 1.709$$

Transverse: Uplift_{MAX} = 34300 lbs Shear_{MAX} = 31520 lbs

$$\text{Compression}_{SEISMIC} = 40012 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 34300 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb} / 2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 31520 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 20.26 \text{ spacing} = 10.55 \text{ in o.c.} \quad T_{applied} = 1143.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 17.56 \text{ spacing} = 12.41 \text{ in o.c.} \quad V_{applied} = 900.6 \text{ lbs}$$

Try using	26 bolts	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18$ O.K.
spaced at	8.44 in o.c.	

Use 26 - 0.625in φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 8.4 in o.c. max. along long side of curb w/ 4.5in embed

Longitudinal: Uplift_{MAX} = 11771 lbs Shear_{MAX} = 31520 lbs



MOUR GROUP

ENGINEERING + DESIGN

Compression_{SEISMIC} = 17483 lbs = $[\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{Ds}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$
 Tension_{SEISMIC} = 11771 lbs = $[\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14 S_{Ds}) * WGT_{unit+curb} * L_{curb} / 2] / L_{curb}$
 Shear_{SEISMIC} = 31520 lbs = $\Omega_o * F_{pmaxASD} / 2$
 Min Bolts Req'd Uplift = 6.95 spacing = 11.45 in o.c. Applied = 1070.1 lbs
 Min Bolts Req'd Shear = 17.56 spacing = 4.04 in o.c. Applied = 900.6 lbs
 Try using 9 bolts COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2$ = 1.13 O.K.
 spaced at 8.59 in o.c.

Use 9 - 0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 8.6 in o.c. max. along short side of curb w/ 4.5in embed

CURB DESIGN SUMMARY:		CBISC-16 CBISCSEL4050	Unit: SUN SELECT 40-50 TON
UPPER CURB RAIL THICKNESS:		0.1017 in 12 Gauge	
UNIT CLIP THICKNESS:		0.0713 in 14 Gauge	
# OF CLIPS (LONG SIDE) - 4 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 1 3/16in x 6in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 3 clips with 5 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 1 3/16in x 6in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(8) - CQA Isolators long side
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	(6) - CQA Isolators short side
BASE CURB THICKNESS: 0.1017 in 12 Gauge		***Must weld top of CQA***	
WEB STIFFENER: 16Ga x 1.5in x 6in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 11 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	<u>WOOD</u>	<u>STEEL</u>	<u>CONCRETE</u>
	1/4" ϕ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" ϕ A307 Bolts to steel angle below deck	0.625in ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed
<u>LONG DIRECTION</u>	40 @ 5.51 in o.c.	14 @ 16.23 in o.c.	26 @ 8.44 in o.c.
<u>SHORT DIRECTION</u>	15 @ 5.19 in o.c.	5 @ 17.17 in o.c.	9 @ 8.59 in o.c.