



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-08 Series
CBISCSLM1830 SERIES**



Prepared for:

PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS YORK UNITS

ZJ, ZR 180-300; XP 180-240
ZF 210-300; ZT 180-276

PROVENT P/N	A	B	EST. WEIGHT
CBISCSLM183018**	8"	18"	556 Lbs
CBISCSLM183021**	11"	21"	606 Lbs
CBISCSLM183024**	14"	24"	656 Lbs

**Note: Spring configuration must be added to part number at time of order



Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES


- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-08

DATE:
4/20/2022


PART NUMBER:
-

REV:
3

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
1 1/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

Meets seismic requirements for the following codes:
 CBC 2019
 IBC 2018

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-08 Iso Curb	CBISCSLM1830
Unit:	ZJ,ZR 180-300; XP 180-240, ZF 210-300	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	125.75 in	(Length of upper curb)
wcurb =	83.5 in	(Width of upper curb)
WGTupper =	107 lbs	(Weight of upper curb)
# Clips long side =	3	# Clips short side = 3

Unit Information

WGTunit =	3305 lbs	(Weight of Unit)
Wtmax =	950 lbs	(Maximum corner weight)
Wtmin =	702 lbs	(Minimum corner weight)
Hunit =	52.625 in	(Height of unit above curb)
Hcm =	26.3125 in	(Height to center of mass)
Lunit =	136.25 in	(Length of unit)
Wunit =	92 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category IV Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	11868 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 12252 lbs
		(unit + upper rail)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	1865 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	1260 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2331 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	6247 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3346 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	563 lbs	= [F _{h ASD trans} *Hcm + 2*0.6*Wtmax*wcurb - F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	910 lbs	= [F _{h ASD trans} *Hcm - 2*0.6*Wtmin*wcurb + F _{vert ASD} *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	4990 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	2089 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	238 lbs	= [F _{h ASD long} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	586 lbs	= [F _{h ASD long} *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert ASD} *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 6247 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3346 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 4990 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2089 lbs	---> Along short edge of curb.


---> Negative values indicate opposite load.

Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	r _x = 2.08 in
I _y = 0.169 in ⁴	r _y = 0.521 in
A = 0.62 in ²	r _{min} = 0.521 in



Axial Compression

P_a = 5.934 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 5.848 k
F_e = 19.27 ksi $\lambda_c = \frac{F_y}{\sqrt{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.61 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 16.90 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 80.00 in Lateral unbraced length
k_yL_y/r_y = 123 (assume k=0.8)

Compression Check = N.G.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$
Long side: P_uTrans = 2.082 k **web stiffener REQ'D** # clips = 3
Short side: P_uLong = 1.663 k **web stiffener REQ'D** # clips = 3

Check Web Stiffener

16Ga x 1-3/16in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crn}max = 3063 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 3123 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 1.2
of Bolts required for Shear = 2.8
of Bolts Used = 4.0

Check Combined Stress in Bolts & Inserts: 1.021 **N.G.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 2.112 in



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	


For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755 \#$
 $P_{ss}/\Omega = 540 \#$ <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249 \#$ <- Controls
 $P_{ts}/\Omega = 820 \#$ (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377 \#$
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	5.934	3	1.98	540 #	4	2.00 in
Short side:	5.934	3	1.98	540 #	4	2.00 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²




Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 6919 lbs Tens _{MAX} = 4189 lbs Shear _{MAX} = 12252 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 5350 lbs Tens _{MAX} = 2621 lbs Shear _{MAX} = 12252 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 2306.2 lbs Tens _{MAX} = 1396.3 lbs Shear _{MAX} = 1021.0 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1783.4 lbs Tens _{MAX} = 873.5 lbs Shear _{MAX} = 1021.0 lbs

Max compression force on isolator: 2.306 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.396 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 1.021 k ≤ 1.163 k **O.K.**



Forces on top bolt:

Tension = 1.396 k $d_b = 0.375$
 Shear = 1.021 k $t = 0.0713$ in

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 12.64$ ksi $f_v = 9.24$ ksi **O.K.**
 $F'_{nt} = 15.21$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 0.747$ k **No Good - Use Welds**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$
 If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ in $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ in $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



Client:	ProVent PV2203	Base curb
Project:	CBISC-08 Iso Curb CBISCSLM1830	
Unit:	ZJ,ZR 180-300; XP 180-240, ZF 210-300	

Base Curb Information

Hbase curb =	25 in	(Height of base curb)
Lcurb =	128.25 in	(Length of base curb)
wcurb =	86 in	(Width of base curb)
WGtbase =	549 lbs	(Weight of base curb)
# Springs long side =	3	# Springs short side = 3

Unit Information

WGtunit =	3305 lbs	(Weight of Unit)
Wt'max =	977 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	729 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	52.625 in	(Height of unit above curb)
H'cm =	36.3125 in	(Hcm+10"*(upper+spring))
Lunit =	136.25 in	(Length of unit)
Wunit =	92 in	(Width of unit)
WGtunit+upper+base =	3961 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	12252 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 14224 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2812 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	1899 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	2331 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	7751 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	4764 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	1194 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1478 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	6047 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	3060 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	544 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	828 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:


Transverse: (on long edge)	Comp _{MAX} =	7751 lbs	---> Along long edge of curb.
	Tens _{MAX} =	4764 lbs	---> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	6047 lbs	---> Along short edge of curb.
	Tens _{MAX} =	3060 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.



Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**



Calculate Section Properties of Curb

A' = 25.000 in	a = 24.492 in = A' - (2r + t)
B' = 1.750 in	a' = 24.898 in = A' - t
C' = 1.000 in (0 if no lips)	b = 1.242 in = B' - [r + t/2 + a(r + t/2)]
a = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 1.648 in = B' - (t/2 + at/2)
R = 0.1525 (Inside bend radius)	c = 0.746 in = a[C' - (r + t/2)]
t = 0.1017 in	c' = 0.949 in = a[C' - t/2]
r' = 0.203 in = R + t/2	u = 0.319 in = πr/2
x = 0.187 in (Distance between centroid and web centerline)	
I _x = 205.037 in ⁴	r _x = 8.23 in
I _y = 0.672 in ⁴	r _y = 0.471 in
A = 3.02 in ²	r _{min} = 0.471 in

Axial Compression

P_u = 6.126 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 9.973 k
F_e = 6.77 ksi λ_c = 2.72 λ_c = √(F_y/F_e) F_e = π²E / (kl/r)²
λ_c = 2.72 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 5.93 ksi If λ_c > 1.5; F_n = 0.877 / λ_c² F_y
L_y = 122.25 in Lateral unbraced length
k_yL_y/r_y = 207 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 245.82 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _n = 0.02	
P _n = 4.106 k	R/t = 1.50 ≤ 9.0		

P_n/Ω_w = 2.346 k P_n = C t² F_y sin(90) (1 - C_R √(R/t)) (1 + C_N √(N/t)) (1 - C_n √(h/t))
Long side: P_{uTrans} = 2.584 k **web stiffener REQ'D** # clips = 3
Short side: P_{uLong} = 2.016 k **O.K.** # clips = 3

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.106 k
P_n = 16.181 k
P_n/Ω_c = 9.518 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crnmax} = 3556 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 3876 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Threaded Insert: Tall = 2480 lbs Vall = 1208 lbs
Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 1.4
of Bolts required for Shear = 3.2
of Bolts Used = **5.0**
Check Combined Stress in Bolts & Inserts: 0.928 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in P_n/Ω = 1/Ω * 0.75tL F_u ≥ V_{req} L_{req'd} = V_{req}Ω / (0.75tF_u)
L_{req'd} = 1.837 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 6919 lbs Tens _{MAX} = 4189 lbs Shear _{MAX} = 12252 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 5350 lbs Tens _{MAX} = 2621 lbs Shear _{MAX} = 12252 lbs

Max compression force on isolator: 2.306 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 1.396 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 1.021 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.698 k / bolt
 Shear = 0.511 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n / \Omega = 3.966$ k

$d/t = 4.92$

$C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²

$P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$

$P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:



$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.11$ ksi $f_v = 2.60$ ksi

$F'_{nt} = 45.00$ ksi

$F_{nv} / \Omega = 11.25$ ksi

$P'_{nt} = A_b F'_{nt}$ $P'_{nt} / \Omega = 3.927$ k

Combined Not Applicable -> F'nt = Fnt



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$ WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 9585 lbs	Shear _{MAX} = 7112 lbs
Compression _{SEISMIC} =	12753 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) + (1 + 0.14S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Tension _{SEISMIC} =	9585 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Compression _{WIND} =	2028 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1982 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 6244 lbs	Shear _{MAX} = 7112 lbs
Compression _{SEISMIC} =	9413 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) + (1 + 0.14S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Tension _{SEISMIC} =	6244 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Compression _{WIND} =	931 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	885 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.5)

Transverse:	Tall _{metal} = 1397 lbs	Vall _{metal} = 1230 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	12.61	COMBINED LOADING: 0.994 O.K.
# of Screws Req'd for Shear =	10.58	Req'd Min Spacing = 6.68 in o.c.
Total # of screws required =	19	

Use 19 - 1/4" φ x 4.5" Simpson SDS screws @ 6.7 in o.c. along long side of curb w/ 2.75" threaded embed



Longitudinal:

of Screws Req'd for Uplift = 8.22 COMBINED LOADING: 0.963 O.K.
of Screws Req'd for Shear = 10.58 Screw Spacing = 6.50 in o.c.
Total # of screws required = 13

Use 13 - 1/4" φ x 4.5" Simpson SDS screws @ 6.5 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Transverse:
Tall_{bolt} = 3927 lbs Vall_{bolt} = 2209 lbs
Tall_{metal} = 2975 lbs Vall_{metal} = 3072 lbs
of Bolts Req'd for Uplift = 3.22 COMBINED LOADING: 0.997 O.K.
of Bolts Req'd for Shear = 3.22 Bolt Spacing = 29.06 in o.c.
Total # of bolts required = 5

Use 5 - 1/2" φ A307 Bolts to steel angle below deck @ 29.1 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 2.10 COMBINED LOADING: 0.777 O.K.
of Bolts Req'd for Shear = 3.22 Bolt Spacing = 24.67 in o.c.
Total # of bolts required = 4

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 24.7 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = 19725 lbs Shear_{MAX} = 14224 lbs
Compression_{SEISMIC} = 22894 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 19725 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 14224 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 17.22 spacing = 6.84 in o.c. T_{applied} = 1095.9 lbs
Min Bolts Req'd Shear = 5.35 spacing = 23.25 in o.c. V_{applied} = 490.5 lbs

Try using 18 bolts spaced at 6.84 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.14$

Use 18 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.8 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 13044 lbs Shear_{MAX} = 14224 lbs
Compression_{SEISMIC} = 16213 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 13044 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 14224 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 11.39 spacing = 6.73 in o.c. T_{applied} = 1003.4 lbs
Min Bolts Req'd Shear = 5.35 spacing = 14.80 in o.c. V_{applied} = 490.5 lbs

Try using 11 bolts spaced at 7.40 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.06$

Use 11 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.4 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBISC-08 CBISCSLM1830		Unit: ZJ,ZR 180-300; XP 180-240, ZF 210-300	
UPPER CURB RAIL THICKNESS: 0.1017 in 12 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 3 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: CQA Top stud diameter: 3/8 (3) - CQA Isolators long side			
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16 (3) - CQA Isolators short side			
BASE CURB THICKNESS: 0.1017 in 12 Gauge ***Must weld top of CQA***			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 5 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin = 0.5)	1/2" φ A307 Bolts to steel angle below deck	CONCRETE
LONG DIRECTION	19 @ 6.68 in o.c.	5 @ 29.06 in o.c.	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
SHORT DIRECTION	13 @ 6.5 in o.c.	4 @ 24.67 in o.c.	18 @ 6.84 in o.c.