



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-07 Series
CBISCSLU180 SERIES**



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS YORK UNITS

| PROVENT P/N | A | B | EST. WEIGHT |
|-----------------|-----|-----|-------------|
| CBISCSLU18018** | 8" | 18" | 475 Lbs |
| CBISCSLU18021** | 11" | 21" | 525 Lbs |
| CBISCSLU18024** | 14" | 24" | 575 Lbs |

**Note: Spring configuration must be added to part number at time of order



Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES


- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.



(4) #10 TEK SCREWS



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-07

DATE:
01/29/18


PART NUMBER:
-

REV:
1

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS

HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




| CURB | NO. OF ANCHORAGE BOLTS REQUIRED | |
|---------|---------------------------------|-----------------|
| | LONG SIDE | SHORT SIDE |
| LXS | 3 @ 19.25" O.C. | 2 @ 23" O.C. |
| LXL | 3 @ 19.25" O.C. | 2 @ 33" O.C. |
| SUN3672 | 4 @ 21" O.C. | 2 @ 27.25" O.C. |
| PRD3715 | 6 @ 14.28" O.C. | 3 @ 20.75" O.C. |
| PRS | 4 @ 20.46" O.C. | 2 @ 31.13" O.C. |
| PRL | 3 @ 36.13" O.C. | 2 @ 44" O.C. |
| SLU180 | 4 @ 35.08" O.C. | 3 @ 37" O.C. |
| SLM1830 | 5 @ 29.06" O.C. | 4 @ 24.67" O.C. |
| SAV1518 | 4 @ 37.38" O.C. | 3 @ 35.56" O.C. |
| SAV2025 | 4 @ 42.04" O.C. | 3 @ 35.56" O.C. |
| SAV28 | 5 @ 35.63" O.C. | 3 @ 35.56" O.C. |

ASSUMES:

CONC SLAB
 $f'_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




| CURB | NO. OF ANCHORAGE BOLTS REQUIRED | |
|---------|---------------------------------|-----------------|
| | LONG SIDE | SHORT SIDE |
| LXS | 7 @ 6.42" O.C. | 4 @ 7.67" O.C. |
| LXL | 7 @ 6.42" O.C. | 5 @ 8.25" O.C. |
| SUN3672 | 9 @ 7.88" O.C. | 4 @ 9.08" O.C. |
| PRD3715 | 14 @ 5.49" O.C. | 9 @ 5.19" O.C. |
| PRS | 10 @ 6.82" O.C. | 5 @ 7.78" O.C. |
| PRL | 11 @ 7.23" O.C. | 6 @ 8.8" O.C. |
| SLU180 | 12 @ 9.57" O.C. | 8 @ 10.57" O.C. |
| SLM1830 | 18 @ 6.84" O.C. | 11 @ 7.4" O.C. |
| SAV1518 | 12 @ 10.19" O.C. | 6 @ 14.23" O.C. |
| SAV2025 | 14 @ 14.97" O.C. | 6 @ 14.23" O.C. |
| SAV28 | 14 @ 10.96" O.C. | 6 @ 14.23" O.C. |

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

| ROOF ANCHORAGE DETAIL |
|-----------------------|
| CBISC Series |
| LXS |
| LXL |
| SUN3672 |
| PRD3715 |
| PRS |
| PRL |
| SLU180 |
| SLM1830 |
| SAV1518 |
| SAV2025 |
| SAV28 |

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

| CURB | NO. OF ANCHORAGE SCREWS REQUIRED | |
|---------|----------------------------------|-----------------|
| | LONG SIDE | SHORT SIDE |
| LXS | 7 @ 7.08" O.C. | 5 @ 6.75" O.C. |
| LXL | 7 @ 7.08" O.C. | 7 @ 6.17" O.C. |
| SUN3672 | 9 @ 8.38" O.C. | 5 @ 7.81" O.C. |
| PRD3715 | 15 @ 5.38" O.C. | 10 @ 5.06" O.C. |
| PRS | 10 @ 7.26" O.C. | 6 @ 7.03" O.C. |
| PRL | 12 @ 6.93" O.C. | 8 @ 6.86" O.C. |
| SLU180 | 14 @ 8.4" O.C. | 10 @ 8.67" O.C. |
| SLM1830 | 19 @ 6.68" O.C. | 13 @ 6.5" O.C. |
| SAV1518 | 13 @ 9.68" O.C. | 9 @ 9.39" O.C. |
| SAV2025 | 15 @ 9.29" O.C. | 9 @ 9.39" O.C. |
| SAV28 | 16 @ 9.77" O.C. | 9 @ 9.39" O.C. |



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




| | | |
|----------|-------------------|-----------------|
| Client: | ProVent PV2203 | Upper curb rail |
| Project: | CBISC-07 Iso Curb | CBISCSLU180 |
| Unit: | ZF180 | |

Upper Curb Information

| | | |
|---------------------|-----------|-----------------------------|
| Hcurb upper = | 5.5 in | (Height of upper curb rail) |
| Lcurb = | 114.75 in | (Length of upper curb) |
| wcurb = | 83.5 in | (Width of upper curb) |
| WGTupper = | 102 lbs | (Weight of upper curb) |
| # Clips long side = | 3 | # Clips short side = 3 |

Unit Information

| | | |
|-----------|------------|-----------------------------|
| WGTunit = | 2120 lbs | (Weight of Unit) |
| Wtmax = | 636 lbs | (Maximum corner weight) |
| Wtmin = | 530 lbs | (Minimum corner weight) |
| Hunit = | 48.625 in | (Height of unit above curb) |
| Hcm = | 24.3125 in | (Height to center of mass) |
| Lunit = | 125.25 in | (Length of unit) |
| Wunit = | 92 in | (Width of unit) |



Seismic Loading - 2018 IBC/2019 CBC

| | | |
|------------|----------|---|
| Ss = | 2.85 | (Worst case for majority of California) |
| Fa = | 1.20 | (Default Site Class D - Table 11.4-1 ASCE 7-16) |
| Ip = | 1.50 | (Importance Factor Category IV Building) |
| Sms = | 3.420 | (Fa*Ss) |
| Sds = | 2.280 | (2/3*Sms) |
| Fpmax = | 5.130 Wp | (0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp |
| FpmaxASD = | 7613 lbs | (unit only) |
| ap = | 2.5 | |
| Rp = | 2 | |
| FpmaxASD = | 7979 lbs | (unit + upper rail) |

Wind Loading - 2018 IBC/2019 CBC

| | | |
|----------------------------|----------|--|
| Kz = | 1.13 | (For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16) |
| Kzt = | 1.00 | (Max. assumed topographic factor) |
| Kd = | 0.85 | (Directionality factor Table 26.6-1 ASCE 7-16) |
| Ke = | 1.00 | (Ground Elevation Factor Table 26.9-1 ASCE 7-16) |
| V = | 110 | (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16) |
| GCr _(horiz) = | 1.9 | (Refer Sect 29.4.1 ASCE 7-16) |
| GCr _(vert) = | 1.5 | (Refer Sect 29.4.1 ASCE 7-16) |
| qz = | 29.8 psf | = 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16) |
| F _h ASD trans = | 1597 lbs | = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2) |
| F _h ASD long = | 1173 lbs | = 0.6*qz*GCr*Wunit*(Hunit+Hcurb) |
| F _{vert} ASD = | 2143 lbs | = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3) |

Upper Curb Loading

Transverse:

| | | |
|----------------------------------|----------|---|
| Compression _{SEISMIC} = | 3895 lbs | = [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb |
| Tension _{SEISMIC} = | 1919 lbs | = [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb |
| Compression _{WIND} = | 157 lbs | = [F _h ASD trans *Hcm + 2*0.6*Wtmax*wcurb - F _{vert} ASD*wcurb/2]/wcurb |
| Tension _{WIND} = | 900 lbs | = [F _h ASD trans *Hcm - 2*0.6*Wtmin*wcurb + F _{vert} ASD*wcurb/2]/wcurb |

---> Negative values indicate opposite load.

Longitudinal:

| | | |
|----------------------------------|----------|--|
| Compression _{SEISMIC} = | 3291 lbs | = [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb |
| Tension _{SEISMIC} = | 1315 lbs | = [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb |
| Compression _{WIND} = | -60 lbs | = [F _h ASD long *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert} ASD*Lcurb/2]/Lcurb |
| Tension _{WIND} = | 684 lbs | = [F _h ASD long *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert} ASD*Lcurb/2]/Lcurb |

---> Negative values indicate opposite load.

Governing Reactions:

| | | | |
|----------------------|-----------------------|----------|--------------------------------|
| Transverse: | Comp _{MAX} = | 3895 lbs | ---> Along long edge of curb. |
| (on long edge) | Tens _{MAX} = | 1919 lbs | ---> Along long edge of curb. |
| Longitudinal: | Comp _{MAX} = | 3291 lbs | ---> Along short edge of curb. |
| (on short edge) | Tens _{MAX} = | 1315 lbs | ---> Along short edge of curb. |

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

| | |
|--|--------------------------------------|
| A' = 5.500 in | a = 5.144 in = A' - (2r+t) |
| B' = 1.750 in | a' = 5.429 in = A' - t |
| C' = 0.000 in (0 if no lips) | b = 1.572 in = B' - [r+t/2+α(r+t/2)] |
| α = 0.000 (0 - no Lip; 1 w/ lip) | b' = 1.714 in = B' - (t/2+αt/2) |
| R = 0.1069 (Inside bend radius) | c = 0.000 in = α[C' - (r+t/2)] |
| t = 0.0713 in | c' = 0.000 in = α[C' - t/2] |
| r' = 0.143 in = R+t/2 | u = 0.224 in = πr/2 |
| x = 0.337 in (Distance between centroid and web centerline) | |
| I _x = 2.687 in ⁴ | r _x = 2.08 in |
| I _y = 0.169 in ⁴ | r _y = 0.521 in |
| A = 0.62 in ² | r _{min} = 0.521 in |



Axial Compression

Pa = 3.806 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 5.848 k
F_e = 19.27 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 1.61 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 16.90 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 80.00 in Lateral unbraced length (assume k=0.8)
k_yL_y/r_y = 123

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k
Long side: P_uTrans = 1.298 k **web stiffener REQ'D** # clips = 3
Short side: P_uLong = 1.117 k **web stiffener REQ'D** # clips = 3

(See table C3.4.1-2, fastened to support, two flange, end loading)

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 1-3/16in x 7in (C-channel) P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crn}max = 1995 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 1947 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.8
of Bolts required for Shear = 1.8
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.860 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 1.317 in



| | | |
|--|-----------------|---|
| Connection Unit to Curb Clip | #10 SMS screw | $\Omega = 3.0$ |
| $t_1 = 0.0713$ in (clip thickness) | $t_2/t_1 = 1.0$ | $F_{u1} = 65$ ksi |
| $t_2 = 0.0713$ in (unit base rail thickness) | | $F_{u2} = 65$ ksi |
| $d = 0.190$ in (screw diameter) | | $d_w = 0.375$ in (nom. washer diameter) |


For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755$ #
 $P_{ss}/\Omega = 540$ # <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249$ # <- Controls
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377$ #
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

| | Shear (k) | # clips | V_{clip} (k) | V_{allow} (lb) | # screws | spacing |
|-------------|-----------|---------|----------------|------------------|----------|---------|
| Long side: | 3.806 | 3 | 1.27 | 540 # | 4 | 2.00 in |
| Short side: | 3.806 | 3 | 1.27 | 540 # | 4 | 2.00 in |

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²




Curb Loads [copied from above]

| | |
|----------------------------------|---------------------------------|
| Transverse: (on long edge) | Comp _{MAX} = 4314 lbs |
| | Tens _{MAX} = 2537 lbs |
| | Shear _{MAX} = 7979 lbs |
| Longitudinal: (on short edge) | Comp _{MAX} = 3539 lbs |
| | Tens _{MAX} = 1761 lbs |
| | Shear _{MAX} = 7979 lbs |

Loads at each Isolator Type: CQA

| | |
|--|----------------------------------|
| Transverse loading: (on long edge) | Comp _{MAX} = 1438.2 lbs |
| | Tens _{MAX} = 845.6 lbs |
| | Shear _{MAX} = 664.9 lbs |
| Longitudinal loading: (on short edge) | Comp _{MAX} = 1179.6 lbs |
| | Tens _{MAX} = 587.0 lbs |
| | Shear _{MAX} = 664.9 lbs |

Max compression force on isolator: 1.438 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 0.846 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.665 k ≤ 1.163 k **O.K.**



Forces on top bolt:

Tension = 0.846 k $d_b = 0.375$
 Shear = 0.665 k $d_w = 0.375$
 per rail, $t = 0.0713$ in 7.0 in

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 7.66$ ksi $f_v = 6.02$ ksi **O.K.**
 $F'_{nt} = 28.27$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.388$ k **Combined O.K.**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



| | | |
|----------|-------------------------------|-----------|
| Client: | ProVent PV2203 | Base curb |
| Project: | CBISC-07 Iso Curb CBISCSLU180 | |
| Unit: | ZF180 | |

Base Curb Information

| | | |
|-----------------------|-----------|--------------------------|
| Hbase curb = | 25 in | (Height of base curb) |
| Lcurb = | 117.25 in | (Length of base curb) |
| wcurb = | 86 in | (Width of base curb) |
| WGtbase = | 473 lbs | (Weight of base curb) |
| # Springs long side = | 3 | # Springs short side = 3 |

Unit Information

| | | |
|----------------------|------------|-----------------------------|
| WGtunit = | 2120 lbs | (Weight of Unit) |
| Wt'max = | 662 lbs | (Wtmax+1/4*WGtUpper) |
| Wt'min = | 556 lbs | (Wtmin+1/4*WGtUpper) |
| Hunit = | 48.625 in | (Height of unit above curb) |
| H'cm = | 34.3125 in | (Hcm+10"*(upper+spring)) |
| Lunit = | 125.25 in | (Length of unit) |
| Wunit = | 92 in | (Width of unit) |
| WGtunit+upper+base = | 2695 lbs | (Total weight) |

Seismic Loading - 2018 IBC/2019 CBC

| | | |
|------------|---------------------|---|
| Ss = | 2.85 | (Worst case for majority of California) |
| Fa = | 1.20 | (Default Site Class D - Table 11.4-1 ASCE 7-16) |
| Ip = | 1.50 | (Importance Factor Category III Building) |
| Sms = | 3.420 | (Fa*Ss) |
| Sds = | 2.280 | (2/3*Sms) |
| Fpmax = | 5.130 Wp | (0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp |
| FpmaxASD = | 7979 lbs | (0.7*Fpmax) |
| | (unit + upper rail) | (unit + upper rail + base curb) |
| ap = | 2.5 | |
| Rp = | 2 | |
| FpmaxASD = | 9678 lbs | |

Wind Loading - 2018 IBC/2019 CBC

| | | |
|----------------|----------|--|
| Kz = | 1.13 | (For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16) |
| Kzt = | 1.00 | (Max. assumed topographic factor) |
| Kd = | 0.85 | (Directionality factor Table 26.6-1 ASCE 7-16) |
| Ke = | 1.00 | (Ground Elevation Factor Table 26.9-1 ASCE 7-16) |
| V = | 110 | (Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16) |
| GCr(horiz) = | 1.9 | (Refer Sect 29.4.1 ASCE 7-16) |
| GCr(vert) = | 1.5 | (Refer Sect 29.4.1 ASCE 7-16) |
| qz | 29.8 psf | = 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16) |
| Fh ASD trans = | 2467 lbs | = 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2) |
| Fh ASD long = | 1812 lbs | = 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10") |
| Fvert ASD = | 2143 lbs | = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3) |

Base Curb Loading

Transverse:

| | | |
|----------------------------------|----------|---|
| Compression _{SEISMIC} = | 4929 lbs | = [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb |
| Tension _{SEISMIC} = | 2872 lbs | = [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb |
| Compression _{WIND} = | 707 lbs | = [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb |
| Tension _{WIND} = | 1389 lbs | = [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb |

---> Negative values indicate opposite load.

Longitudinal:


| | | |
|----------------------------------|----------|---|
| Compression _{SEISMIC} = | 4080 lbs | = [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb |
| Tension _{SEISMIC} = | 2023 lbs | = [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb |
| Compression _{WIND} = | 253 lbs | = [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb |
| Tension _{WIND} = | 935 lbs | = [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb |

---> Negative values indicate opposite load.

Governing Reactions:

| | | | |
|---|-----------------------|----------|--------------------------------|
| <u>Transverse:</u> (on long edge) | Comp _{MAX} = | 4929 lbs | ---> Along long edge of curb. |
| | Tens _{MAX} = | 2872 lbs | ---> Along long edge of curb. |
| <u>Longitudinal:</u> (on short edge) | Comp _{MAX} = | 4080 lbs | ---> Along short edge of curb. |
| | Tens _{MAX} = | 2023 lbs | ---> Along short edge of curb. |


---> Negative values indicate opposite load.





Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 **12 Gauge**



Calculate Section Properties of Curb

| | |
|---|--|
| A' = 25.000 in | a = 24.492 in = A' - (2r + t) |
| B' = 1.750 in | a' = 24.898 in = A' - t |
| C' = 0.000 in (0 if no lips) | b = 1.496 in = B' - [r + t/2 + a(r + t/2)] |
| a = 0.000 in (0 - no Lip; 1 w/ lip) | b' = 1.699 in = B' - (t/2 + at/2) |
| R = 0.1525 (Inside bend radius) | c = 0.000 in = a[C' - (r + t/2)] |
| t = 0.1017 in | c' = 0.000 in = a[C' - t/2] |
| r' = 0.203 in = R + t/2 | u = 0.319 in = πr/2 |
| x = 0.103 in (Distance between centroid and web centerline) | |
| I _x = 181.709 in ⁴ | r _x = 7.97 in |
| I _y = 0.302 in ⁴ | r _y = 0.325 in |
| A = 2.86 in ² | r _{min} = 0.325 in |

Axial Compression

P_u = 3.990 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 5.415 k
F_e = 3.89 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 3.59 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 3.41 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 111.25 in Lateral unbraced length
k_yL_y/r_y = 274 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

| | | | |
|--------------------------|--------------------|-----------------------|--|
| h = 25 in | -- Check limits: | C = 4.00 | } (See table C3.4.1-2, fastened to support, one flange, end loading) |
| t = 0.1017 in | h/t = 245.82 ≤ 200 | C _R = 0.14 | |
| N = 7.00 | N/t = 68.83 ≤ 210 | C _N = 0.35 | |
| Ω _w = 1.75 | N/h = 0.28 ≤ 2.0 | C _n = 0.02 | |
| P _n = 4.106 k | R/t = 1.50 ≤ 9.0 | | |

P_n/Ω_w = 2.346 k
Long side: P_{uTrans} = 1.643 k **O.K.** # clips = 3
Short side: P_{uLong} = 1.360 k **O.K.** # clips = 3

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_n \sqrt{\frac{h}{t}}\right)$$

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 4.106 k
P_n = 16.181 k
P_n/Ω_c = 9.518 k **O.K.**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 2419 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 2464 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = **2480** lbs Vall = **1208** lbs
Threaded Insert: Tall = **2860** lbs Vall = **1536** lbs
of Bolts required for Tension = 1.0
of Bolts required for Shear = 2.0
of Bolts Used = **4.0**
Check Combined Stress in Bolts & Inserts: 0.754 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 2.543 in P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 1.168 in



Curb Loads [copied from upper rail calcs]

| | |
|---|---|
| Transverse: (on long edge) | Comp _{MAX} = 4314 lbs Tens _{MAX} = 2537 lbs Shear _{MAX} = 7979 lbs |
| Longitudinal: (on short edge) | Comp _{MAX} = 3539 lbs Tens _{MAX} = 1761 lbs Shear _{MAX} = 7979 lbs |

Max compression force on isolator: 1.438 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 0.846 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.665 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.1017$ in
 Tension = 0.423 k / bolt
 Shear = 0.332 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.966$ k $d/t = 4.92$
 $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 4.31$ ksi $f_v = 1.69$ ksi
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi
 $P'_{nt} = A_b F'_{nt}$ $P'_{nt}/\Omega = 3.927$ k **Combined Not Applicable -> F'nt = Fnt**

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14S_{DS})D + 0.7E WIND: 0.6D + W

| | | |
|----------------------------------|----------------------------------|--|
| Transverse: | Uplift _{MAX} = 6296 lbs | Shear _{MAX} = 4839 lbs |
| Compression _{SEISMIC} = | 8452 lbs | = [F _{pmaxASD} *(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb |
| Tension _{SEISMIC} = | 6296 lbs | = [F _{pmaxASD} *(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *wcurb/2]/wcurb |
| Compression _{WIND} = | 1439 lbs | = [F _{h ASD trans} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *wcurb/2-F _{vert ASD} *wcurb/2]/wcurb |
| Tension _{WIND} = | 1964 lbs | = [F _{h ASD trans} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *wcurb/2+F _{vert ASD} *wcurb/2]/wcurb |
| Longitudinal: | Uplift _{MAX} = 4517 lbs | Shear _{MAX} = 4839 lbs |
| Compression _{SEISMIC} = | 6673 lbs | = [F _{pmaxASD} *(H'cm+Hbase curb)+(1+0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb |
| Tension _{SEISMIC} = | 4517 lbs | = [F _{pmaxASD} *(H'cm+Hbase curb)-(0.6-0.14S _{DS})*WGT _{unit+upper+base} *Lcurb/2]/Lcurb |
| Compression _{WIND} = | 654 lbs | = [F _{h ASD long} *(H'cm+Hbase curb)+0.6*WGT _{unit+upper+base} *Lcurb/2-F _{vert ASD} *Lcurb/2]/Lcurb |
| Tension _{WIND} = | 1180 lbs | = [F _{h ASD long} *(H'cm+Hbase curb)-0.6*WGT _{unit+upper+base} *Lcurb/2+F _{vert ASD} *Lcurb/2]/Lcurb |



Wood Attachment: 1/4" φ x 4.5" Simpson SDS screw: w/ 2.75" threaded emt (SGmin = 0.43)

| | | |
|--------------------------------|----------------------------------|----------------------------------|
| Transverse: | Tall _{metal} = 1397 lbs | Vall _{metal} = 1230 lbs |
| | Tall _{wood} = 760 lbs | Vall _{wood} = 672 lbs |
| # of Screws Req'd for Uplift = | 8.28 | COMBINED LOADING: 0.892 O.K. |
| # of Screws Req'd for Shear = | 7.20 | Req'd Min Spacing = 8.40 in o.c. |
| Total # of screws required = | 14 | |

Use 14 - 1/4" φ x 4.5" Simpson SDS screws @ 8.4 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

| | |
|---|---|
| Transverse loading: (on long edge) | Comp _{MAX} = 1438.2 lbs Tens _{MAX} = 845.6 lbs Shear _{MAX} = 664.9 lbs |
| # isolators: 3 | |
| Longitudinal loading: (on short edge) | Comp _{MAX} = 1179.6 lbs Tens _{MAX} = 587.0 lbs Shear _{MAX} = 664.9 lbs |
| # isolators: 3 | |





Longitudinal:

of Screws Req'd for Uplift = 5.94 COMBINED LOADING: 0.894 O.K.
of Screws Req'd for Shear = 7.20 Screw Spacing = in o.c.
Total # of screws required =

Use 10 - 1/4" φ x 4.5" Simpson SDS screws @ 8.7 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Transverse: Tall_{bolt} = lbs Vall_{bolt} = lbs
Tall_{metal} = lbs Vall_{metal} = lbs
of Bolts Req'd for Uplift = 2.12 COMBINED LOADING: 0.842 O.K.
of Bolts Req'd for Shear = 2.19 Bolt Spacing = in o.c.
Total # of bolts required =

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 35.1 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.52 COMBINED LOADING: 0.693 O.K.
of Bolts Req'd for Shear = 2.19 Bolt Spacing = in o.c.
Total # of bolts required =

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 37 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = lbs Shear_{MAX} = lbs
Compression_{SEISMIC} = 15127 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 12971 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 9678 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 11.32 spacing = 9.57 in o.c. T_{applied} = 1080.9 lbs
Min Bolts Req'd Shear = 3.64 spacing = 35.08 in o.c. V_{applied} = 483.9 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.13$

Use 12 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 9.6 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = lbs Shear_{MAX} = lbs
Compression_{SEISMIC} = 11569 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 9413 lbs = [Ω_o*F_{pmaxASD}*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 9678 lbs = Ω_o*F_{pmaxASD}/2
Min Bolts Req'd Uplift = 8.22 spacing = 9.25 in o.c. T_{applied} = 941.3 lbs
Min Bolts Req'd Shear = 3.64 spacing = 24.67 in o.c. V_{applied} = 483.9 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.00$

Use 8 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 10.6 in o.c. max. along short side of curb w/ 4" embed

| | | | |
|--|---|---|--|
| CURB DESIGN SUMMARY: | | CBISC-07 CBISCSLU180 | Unit: ZF180 |
| UPPER CURB RAIL THICKNESS: 0.0713 in | | 14 Gauge | |
| UNIT CLIP THICKNESS: 0.0713 in | | 14 Gauge | |
| # OF CLIPS (LONG SIDE) - 3 clips with 4 - #10 SMS screws each clip | | | |
| WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip | | | |
| # OF CLIPS (SHORT SIDE) - 3 clips with 4 - #10 SMS screws each clip | | | |
| WEB STIFFENER: 16Ga x 1-3/16in x 7in (C-channel) stiffener at each clip | | | |
| VIBRATION ISOLATOR TYPE: CQA | | Top stud diameter: 3/8 | (3) - CQA Isolators long side |
| Anchor bolt diameter: 1/2 | | Anchor hole diameter: 9/16 | (3) - CQA Isolators short side |
| BASE CURB THICKNESS: 0.1017 in | | 12 Gauge | ---Bolt or Weld O.K.--- |
| WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb | | | |
| CORNER CONNECTION: Use minimum 4 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts | | | |
| CURB ANCHORAGE | WOOD | STEEL | CONCRETE |
| | 1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin = | 1/2" φ A307 Bolts to steel angle below deck | 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed |
| LONG DIRECTION | 14 @ 8.4 in o.c. | 4 @ 35.08 in o.c. | 12 @ 9.57 in o.c. |
| SHORT DIRECTION | 10 @ 8.67 in o.c. | 3 @ 37 in o.c. | 8 @ 10.57 in o.c. |