



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-03 Series
CBISCSUN3672 SERIES**



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: July 13, 2022

Project Number: PV2203

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-62.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURBS FOR YORK UNITS

ZR, XN, XP 036-060,
ZE, ZF 036-072

PROVENT P/N	A	B	EST. WEIGHT
CBISCSUN367218**	8"	18"	260 Lbs.
CBISCSUN367221**	11"	21"	280 Lbs.
CBISCSUN367224**	14"	24"	300 Lbs.

**Note: Spring configuration must be added to part number at time of order





Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FEATURES

- Roof curbs sides and ends are 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPd pre-approved seismic restraints. (OPM-0401-13), (CQA).

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBISC-03

DATE:
4/20/2022


PART NUMBER:
-

REV:
4

DRAWN BY:
FMM

WELDMENT AND BOLTING DETAIL

OPTIONAL
WELD I.L.O.
BOLTED STUD



BASE CURB SUPPORT


(3) 5/16" BOLTS
GRADE 5 EA SIDE
OF THE STIFFENER

(2) EA SIDE FOR
UPPER RAIL SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
3/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



HOLE FOR ISOLATOR STUD,
W/ FLAT WASHER REQUIRED
UNDER NUT
7/16" FOR JQA
9/16" FOR JQB/JQBX
11/16" FOR JQE/JQF

NEOPRENE CUP
UNDER SPRING

1/4" THICK NEOPRENE PAD
REQUIRED

FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	3 @ 19.25" O.C.	2 @ 23" O.C.
LXL	3 @ 19.25" O.C.	2 @ 33" O.C.
SUN3672	4 @ 21" O.C.	2 @ 27.25" O.C.
PRD3715	6 @ 14.28" O.C.	3 @ 20.75" O.C.
PRS	4 @ 20.46" O.C.	2 @ 31.13" O.C.
PRL	3 @ 36.13" O.C.	2 @ 44" O.C.
SLU180	4 @ 35.08" O.C.	3 @ 37" O.C.
SLM1830	5 @ 29.06" O.C.	4 @ 24.67" O.C.
SAV1518	4 @ 37.38" O.C.	3 @ 35.56" O.C.
SAV2025	4 @ 42.04" O.C.	3 @ 35.56" O.C.
SAV28	5 @ 35.63" O.C.	3 @ 35.56" O.C.

ASSUMES:

CONC SLAB
 $f_c = 4000\text{PSI}$ MINIMUM
 6" MIN THICKNESS
 NORMAL WEIGHT CONCRETE
 OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT




CURB	NO. OF ANCHORAGE BOLTS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	5 @ 8.25" O.C.
SUN3672	9 @ 7.88" O.C.	4 @ 9.08" O.C.
PRD3715	14 @ 5.49" O.C.	9 @ 5.19" O.C.
PRS	10 @ 6.82" O.C.	5 @ 7.78" O.C.
PRL	11 @ 7.23" O.C.	6 @ 8.8" O.C.
SLU180	12 @ 9.57" O.C.	8 @ 10.57" O.C.
SLM1830	18 @ 6.84" O.C.	11 @ 7.4" O.C.
SAV1518	12 @ 10.19" O.C.	6 @ 14.23" O.C.
SAV2025	14 @ 14.97" O.C.	6 @ 14.23" O.C.
SAV28	14 @ 10.96" O.C.	6 @ 14.23" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
 ** CENTERED.

ROOF ANCHORAGE DETAIL
CBISC Series
LXS
LXL
SUN3672
PRD3715
PRS
PRL
SLU180
SLM1830
SAV1518
SAV2025
SAV28

Meets seismic requirements for the following codes:
 CBC 2019
 IBC 2018

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

CURB	NO. OF ANCHORAGE SCREWS REQUIRED	
	LONG SIDE	SHORT SIDE
LXS	7 @ 7.08" O.C.	5 @ 6.75" O.C.
LXL	7 @ 7.08" O.C.	7 @ 6.17" O.C.
SUN3672	9 @ 8.38" O.C.	5 @ 7.81" O.C.
PRD3715	15 @ 5.38" O.C.	10 @ 5.06" O.C.
PRS	10 @ 7.26" O.C.	6 @ 7.03" O.C.
PRL	12 @ 6.93" O.C.	8 @ 6.86" O.C.
SLU180	14 @ 8.4" O.C.	10 @ 8.67" O.C.
SLM1830	19 @ 6.68" O.C.	13 @ 6.5" O.C.
SAV1518	13 @ 9.68" O.C.	9 @ 9.39" O.C.
SAV2025	15 @ 9.29" O.C.	9 @ 9.39" O.C.
SAV28	16 @ 9.77" O.C.	9 @ 9.39" O.C.



3847 WABASH DRIVE
 MIRA LOMA, CA 91752
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO:
 CB-62

DATE:
 6/30/2022

REV:
 2

DRAWN BY:
 FMM




Client:	ProVent PV2203	Upper curb rail
Project:	CBISC-03 Iso Curb	CBISCSUN3672
Unit:	ZR 036-060, XP 036-060, ZF 036-072	

Upper Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	72.5 in	(Length of upper curb)
wcurb =	36.75 in	(Width of upper curb)
WGTupper =	55 lbs	(Weight of upper curb)
# Clips long side =	2	# Clips short side = 1

Unit Information

WGTunit =	845 lbs	(Weight of Unit)
Wtmax =	254 lbs	(Maximum corner weight)
Wtmin =	169 lbs	(Minimum corner weight)
Hunit =	32.625 in	(Height of unit above curb)
Hcm =	16.3125 in	(Height to center of mass)
Lunit =	82.25 in	(Length of unit)
Wunit =	44.875 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3034 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 3232 lbs (unit + upper rail)
ap =	2.5	
Rp =	2	

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr _(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr _(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
F _{h ASD trans} =	739 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F _{h ASD long} =	403 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	686 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Upper Curb Loading

Transverse:

Compression _{SEISMIC} =	2016 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	1252 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	289 lbs	= [F _{h ASD trans} *Hcm + 2*0.6*Wtmax*wcurb - F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	468 lbs	= [F _{h ASD trans} *Hcm - 2*0.6*Wtmin*wcurb + F _{vert ASD} *wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	1352 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	588 lbs	= [FpmaxASD*Hcm - 2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	52 lbs	= [F _{h ASD long} *Hcm + 2*0.6*Wtmax*Lcurb - F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	231 lbs	= [F _{h ASD long} *Hcm - 2*0.6*Wtmin*Lcurb + F _{vert ASD} *Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 2016 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1252 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1352 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 588 lbs	---> Along short edge of curb.


---> Negative values indicate opposite load.

Curb Design

F_y = 50 ksi F_u = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.750 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.337 in (Distance between centroid and web centerline)	
I _x = 2.687 in ⁴	r _x = 2.08 in
I _y = 0.169 in ⁴	r _y = 0.521 in
A = 0.62 in ²	r _{min} = 0.521 in



Axial Compression

Pa = 1.517 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 14.341 k
F_e = 111.57 ksi $\lambda_c = \frac{F_y}{\sqrt{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 0.67 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 41.45 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 33.25 in Lateral unbraced length (assume k=0.8)
k_yL_y/r_y = 51

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.273 ≤ 2.0 C_h = 0.048
P_n = 1.947 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.112 k
Long side: P_{uTrans} = 1.008 k **O.K.** # clips = 2
Short side: P_{uLong} = 0.901 k **O.K.** # clips = 1

(See table C3.4.1-2, fastened to support, two flange, end loading)

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$$

Check Web Stiffener

N/A P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge P_{wc} = 1.947 k
web of stiff. w = 6.717 in R_s = 0.0849 in P_n = 14.669 k
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70 A_e = 0.380 in²
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2 P_n/Ω_c = 8.629 k **Not Req'd**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 808 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1008 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 0.9
of Bolts Used = 2.0
Check Combined Stress in Bolts & Inserts: 0.623 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.681 in



Connection Unit to Curb Clip	#10 SMS screw	$\Omega = 3.0$
$t_1 = 0.0713$ in (clip thickness)	$t_2/t_1 = 1.0$	$F_{u1} = 65$ ksi
$t_2 = 0.0713$ in (unit base rail thickness)		$F_{u2} = 65$ ksi
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)	


For $t_2/t_1 \leq 1.0$:
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k
Tension: $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755 \#$
 $P_{ss}/\Omega = 540 \#$ <- Controls
 $P_{not} = 0.748$ k (screw pull-out strength)
 $P_{nov} = 2.607$ k (screw pull-over strength)
 $P_{ts}/\Omega = 249 \#$ <- Controls
 $P_{ts}/\Omega = 820 \#$ (full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:
 $P_{ns} = 2377 \#$
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{not} = 0.85t_c d F_{u2}$
 $t_c = \min(t_1, t_2)$
 $P_{nov} = 1.5t_1 d_w F_{u1}$

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.517	2	0.76	540 #	4	2.00 in
Short side:	1.517	1	1.52	540 #	4	2.00 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.674$ k
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.416$ in²
 $A_{nt} = 0.082$ in²




Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 2512 lbs Tens _{MAX} = 1792 lbs Shear _{MAX} = 3232 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1566 lbs Tens _{MAX} = 846 lbs Shear _{MAX} = 3232 lbs

Loads at each Isolator Type: CQA

Transverse loading: (on long edge)	Comp _{MAX} = 1255.9 lbs Tens _{MAX} = 895.9 lbs Shear _{MAX} = 538.7 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1566.0 lbs Tens _{MAX} = 846.0 lbs Shear _{MAX} = 538.7 lbs

Max compression force on isolator: 1.566 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 0.896 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.539 k ≤ 1.163 k **O.K.**



Forces on top bolt:

Tension = 0.896 k $d_b = 0.375$
 Shear = 0.539 k $d_w = 0.375$
 per rail, $t = 0.0713$ in $t = 0.0713$ in

Shear on curb rail: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

Shear O.K. $P_n/\Omega = 4.635$ k $e = 1.0$ in

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$P_n/\Omega = 4.989$ k $A_n = 0.116$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n/\Omega = 2.086$ k $d/t = 5.26$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Shear and tension in bolt:

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 8.11$ ksi $f_v = 4.88$ ksi **O.K.**
 $F'_{nt} = 32.90$ ksi $F_{nv}/\Omega = 10.00$ ksi

$P'_{nt}/\Omega = 1.615$ k **Combined O.K.**

Longitudinal weld loading: $L = 1.5P_n/\Omega = \frac{1}{\Omega} \left(1 - \frac{0.01L}{t_2}\right) L t_2 F_{u2} \geq V_{req}$ $\Omega = 2.55$

If $L/t < 25$: $L/t = 21.04$ $t = 0.0713$ $P_n/\Omega = 2.153$ k

Transverse weld loading: $t = 0.0713$ $P_n/\Omega = \frac{1}{\Omega} t L F_u \geq T_{req}$ $\Omega = 2.35$
 $L = 1$ $F_u = 65$ ksi $P_n/\Omega = 1.972$ k



Client:	ProVent PV2203	Base curb
Project:	CBISC-03 Iso Curb CBISCSUN3672	
Unit:	ZR 036-060, XP 036-060, ZF 036-072	

Base Curb Information

Hbase curb =	25 in	(Height of base curb)
Lcurb =	75 in	(Length of base curb)
wcurb =	39.25 in	(Width of base curb)
WGtbase =	245 lbs	(Weight of base curb)
# Springs long side =	2	# Springs short side = 1

Unit Information

WGtunit =	845 lbs	(Weight of Unit)
Wt'max =	267 lbs	(Wtmax+1/4*WGtUpper)
Wt'min =	183 lbs	(Wtmin+1/4*WGtUpper)
Hunit =	32.625 in	(Height of unit above curb)
H'cm =	26.3125 in	(Hcm+10"*(upper+spring))
Lunit =	82.25 in	(Length of unit)
Wunit =	44.875 in	(Width of unit)
WGtunit+upper+base =	1145 lbs	(Total weight)

Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	5.130 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3232 lbs	(0.7*Fpmax)
	(unit + upper rail)	FpmaxASD = 4112 lbs
		(unit + upper rail + base curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz	29.8 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	1310 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hbase curb+10") (Eq. 29.4-2)
Fh ASD long =	715 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hbase curb+10")
Fvert ASD =	686 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Base Curb Loading

Transverse:

Compression _{SEISMIC} =	2872 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*wcurb]/wcurb
Tension _{SEISMIC} =	2064 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*wcurb]/wcurb
Compression _{WIND} =	856 lbs	= [Fh ASD trans*H'cm+2*0.6*Wt'max*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1002 lbs	= [Fh ASD trans*H'cm-2*0.6*Wt'min*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:


Compression _{SEISMIC} =	1839 lbs	= [FpmaxASD*H'cm+2*(1+0.14S _{DS})*Wt'max*Lcurb]/Lcurb
Tension _{SEISMIC} =	1031 lbs	= [FpmaxASD*H'cm-2*(0.6-0.14S _{DS})*Wt'min*Lcurb]/Lcurb
Compression _{WIND} =	228 lbs	= [Fh ASD long*H'cm+2*0.6*Wt'max*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	375 lbs	= [Fh ASD long*H'cm-2*0.6*Wt'min*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:


<u>Transverse:</u> (on long edge)	Comp _{MAX} =	2872 lbs	---> Along long edge of curb.
	Tens _{MAX} =	2064 lbs	---> Along long edge of curb.
<u>Longitudinal:</u> (on short edge)	Comp _{MAX} =	1839 lbs	---> Along short edge of curb.
	Tens _{MAX} =	1031 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.



Curb Design

F_y = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge



Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + a(r + t/2)]
a = 0.000 in (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I _x = 128.737 in ⁴	r _x = 8.00 in
I _y = 0.218 in ⁴	r _y = 0.329 in
A = 2.01 in ²	r _{min} = 0.329 in

Axial Compression

P_u = 1.616 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 8.576 k
F_e = 8.74 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 2.39 If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
F_n = 7.67 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 75.00 in Lateral unbraced length
k_yL_y/r_y = 182 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _n = 0.02	
P _n = 2.105 k	R/t = 1.50 ≤ 9.0		

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_n \sqrt{\frac{h}{t}}\right)$
Long side: P_{uTrans} = 1.436 k **web stiffener REQ'D** # clips = 2
Short side: P_{uLong} = 1.839 k **web stiffener REQ'D** # clips = 1
*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28VE/F_y Ω_c = 1.70
w/t_s = 118.675
1.28v(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k A_e = 0.380 in²
P_n = 14.780 k
P_n/Ω_c = 8.694 k **O.K.**

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 1028 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1436 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1096 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.3
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.575 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tL F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.971 in



Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 2512 lbs Tens _{MAX} = 1792 lbs Shear _{MAX} = 3232 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1566 lbs Tens _{MAX} = 846 lbs Shear _{MAX} = 3232 lbs

Max compression force on isolator: 1.566 k ≤ 3.176 k **O.K.**
 Max uplift on isolator: 0.896 k ≤ 3.176 k **O.K.**
 Max shear on isolator: 0.539 k ≤ 1.163 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
 base curb, $t = 0.0713$ in
 Tension = 0.448 k / bolt
 Shear = 0.269 k / bolt

Shear on base curb: $P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)

$P_n / \Omega = 2.781$ k

$d/t = 7.01$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²

$P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$

$P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

Combined Shear and tension in bolt:

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_t = 4.56$ ksi $f_v = 1.37$ ksi

$P'_{nt} = A_b F'_{nt}$ $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi

Combined Not Applicable -> F'nt = Fnt

Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6 - 0.14 S_{DS}) D + 0.7 E$ WIND: $0.6 D + W$

Transverse:	Uplift _{MAX} = 5215 lbs	Shear _{MAX} = 2056 lbs
Compression _{SEISMIC} =	6131 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Tension _{SEISMIC} =	5215 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * w_{curb} / 2] / w_{curb}$
Compression _{WIND} =	1713 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 - F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	1712 lbs	$= [F_{h ASD trans} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * w_{curb} / 2 + F_{vert ASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 2652 lbs	Shear _{MAX} = 2056 lbs
Compression _{SEISMIC} =	3568 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) + (1 + 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Tension _{SEISMIC} =	2652 lbs	$= [F_{pmaxASD} * (H'cm + H_{base curb}) - (0.6 - 0.14 S_{DS}) * WGT_{unit+upper+base} * L_{curb} / 2] / L_{curb}$
Compression _{WIND} =	489 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) + 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 - F_{vert ASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	489 lbs	$= [F_{h ASD long} * (H'cm + H_{base curb}) - 0.6 * WGT_{unit+upper+base} * L_{curb} / 2 + F_{vert ASD} * L_{curb} / 2] / L_{curb}$



Wood Attachment: **1/4" φ x 4.5" Simpson SDS screw w/ 2.75" threaded emt** (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	6.86	COMBINED LOADING: 0.981 O.K.
# of Screws Req'd for Shear =	3.06	Req'd Min Spacing = 8.38 in o.c.
Total # of screws required =	9	

Use 9 - 1/4" φ x 4.5" Simpson SDS screws @ 8.4 in o.c. along long side of curb w/ 2.75" threaded embed

Loads at each Isolator Type: **CQA**

Transverse loading: (on long edge)	Comp _{MAX} = 1255.9 lbs Tens _{MAX} = 895.9 lbs Shear _{MAX} = 538.7 lbs
# isolators: 2	
Longitudinal loading: (on short edge)	Comp _{MAX} = 1566.0 lbs Tens _{MAX} = 846.0 lbs Shear _{MAX} = 538.7 lbs
# isolators: 1	





Longitudinal:

of Screws Req'd for Uplift = 3.49 COMBINED LOADING: 0.917 O.K.
of Screws Req'd for Shear = 3.06 Screw Spacing = in o.c.
Total # of screws required =

Use 5 - 1/4" φ x 4.5" Simpson SDS screws @ 7.8 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Transverse:
Tall_{bolt} = lbs Vall_{bolt} = lbs
Tall_{metal} = lbs Vall_{metal} = lbs
of Bolts Req'd for Uplift = 2.50 COMBINED LOADING: 0.781 O.K.
of Bolts Req'd for Shear = 0.94 Bolt Spacing = in o.c.
Total # of bolts required =

Use 4 - 1/2" φ A307 Bolts to steel angle below deck @ 21 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 1.27 COMBINED LOADING: 0.474 O.K.
of Bolts Req'd for Shear = 0.94 Bolt Spacing = in o.c.
Total # of bolts required =

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 27.3 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14S_{DS})D + 0.7Ω_eE Ω_o = 2.0

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1957 lbs Vall_{LRFD} = 4540 lbs α = (1 + 0.2SDS)D + 2.5E = 1.708
Tall_{ASD} = Tall_{LRFD}/α = 1146 lbs Vall_{ASD} = Vall_{LRFD}/α = 2658 lbs (D = 0.758, E = 0.242)
Transverse: Uplift_{MAX} = lbs Shear_{MAX} = lbs
Compression_{SEISMIC} = 11506 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Tension_{SEISMIC} = 10590 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*wcurb/2]/wcurb
Shear_{SEISMIC} = 4112 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 9.24 spacing = 7.00 in o.c. T_{applied} = 1176.7 lbs
Min Bolts Req'd Shear = 1.55 spacing = 63.00 in o.c. V_{applied} = 316.3 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$

Use 9 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.9 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = lbs Shear_{MAX} = lbs
Compression_{SEISMIC} = 6381 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)+(1+0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Tension_{SEISMIC} = 5465 lbs = [Ω_o*FpmaxASD*(H'cm+Hbase curb)-(0.6-0.14S_{DS})*WGT_{unit+curb+base}*Lcurb/2]/Lcurb
Shear_{SEISMIC} = 4112 lbs = Ω_o*FpmaxASD/2
Min Bolts Req'd Uplift = 4.77 spacing = 6.81 in o.c. T_{applied} = 910.9 lbs
Min Bolts Req'd Shear = 1.55 spacing = 27.25 in o.c. V_{applied} = 316.3 lbs

Try using bolts spaced at in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.91$

Use 4 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 9.1 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY:		CBISC-03 CBISCSUN3672	Unit: ZR 036-060, XP 036-060, ZF 036-072
UPPER CURB RAIL THICKNESS: 0.0713 in		14 Gauge	
UNIT CLIP THICKNESS: 0.0713 in		14 Gauge	
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: CQA		Top stud diameter: 3/8	(2) - CQA Isolators long side
		Anchor bolt diameter: 1/2	Anchor hole diameter: 9/16
			(1) - CQA Isolators short side
BASE CURB THICKNESS: 0.0713 in		14 Gauge	---Bolt or Weld O.K.---
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed (SGmin =	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	9 @ 8.38 in o.c.	4 @ 21 in o.c.	9 @ 7.88 in o.c.
SHORT DIRECTION	5 @ 7.81 in o.c.	2 @ 27.25 in o.c.	4 @ 9.08 in o.c.