



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

**Structural Calculations
for
CBKDSAV2025 Curb**



Prepared for:

PROVENT


3847 Wabash Drive

Mira Loma, CA 91725

Date: December 19, 2022

Project Number: PV2206

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C.	2 @ 19" O.C.
LXL	2 @ 34.5" O.C.	2 @ 29" O.C.
SUN3672	2 @ 60.5" O.C.	2 @ 39" O.C.
PRD3715	2 @ 68.88" O.C.	2 @ 39" O.C.
PRS	2 @ 58.88" O.C.	2 @ 28.69" O.C.
PRL	2 @ 72" O.C.	2 @ 41.5" O.C.
SLU180	3 @ 51.38" O.C.	2 @ 71.5" O.C.
SLM1830	3 @ 56.88" O.C.	3 @ 35.75" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

ASSUMES:


CONC SLAB
f_c = 4000PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series
LXS	LXS
LXL	LXL
SUN3672	SUN3672
PRD3715	PRD3715
PRS	PRS
PRL	PRL
SLU180	SLU180
SLM1830	SLM1830
SAV1518	SAV1518
SAV2025	SAV2025
SAV28	SAV28

CONCRETE ATTACHMENT




5/8" Ø HAS ROD IN HILTI HIT-HY 200 V3 EPOXY WITH 4-1/2" EMBED MIN. 9-1/8" EDGE DISTANCE (FOR SAV SERIES ONLY)

NO. OF ANCHORAGE BOLTS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 11.5" O.C.	3 @ 9.5" O.C.
LXL	4 @ 11.5" O.C.	3 @ 14.5" O.C.
SUN3672	4 @ 20.17" O.C.	3 @ 12.38" O.C.
PRD3715	9 @ 8.61" O.C.	7 @ 6.5" O.C.
PRS	5 @ 14.72" O.C.	4 @ 9.56" O.C.
PRL	6 @ 14.4" O.C.	5 @ 10.38" O.C.
SLU180	8 @ 14.68" O.C.	7 @ 11.92" O.C.
SLM1830	12 @ 10.34" O.C.	10 @ 7.94" O.C.
SAV1518	3 @ 54.56" O.C.	2 @ 68.13" O.C.
SAV2025	3 @ 61.56" O.C.	2 @ 68.13" O.C.
SAV28	3 @ 69.75" O.C.	2 @ 68.13" O.C.

WOOD ATTACHMENT



FOUR INCHES FROM EACH CORNER EVENLY SPACED

NO. OF ANCHORAGE SCREWS REQUIRED

CURB	LONG SIDE	SHORT SIDE
LXS	4 @ 12.83" O.C.	3 @ 11.5" O.C.
LXL	4 @ 12.83" O.C.	3 @ 16.5" O.C.
SUN3672	4 @ 21.5" O.C.	3 @ 14.38" O.C.
PRD3715	9 @ 9.11" O.C.	8 @ 6.14" O.C.
PRS	4 @ 20.96" O.C.	3 @ 16.34" O.C.
PRL	5 @ 19" O.C.	4 @ 15.17" O.C.
SLU180	9 @ 13.34" O.C.	7 @ 12.58" O.C.
SLM1830	13 @ 9.81" O.C.	12 @ 6.86" O.C.
SAV1518	5 @ 28.28" O.C.	4 @ 24.04" O.C.
SAV2025	6 @ 25.43" O.C.	5 @ 18.03" O.C.
SAV28	7 @ 23.92" O.C.	5 @ 18.03" O.C.



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____








FORM NO:

CB-60

DATE: 11/05/2022

REV: 8

DRAWN BY: FMM

FEATURES <ul style="list-style-type: none"> • Roof curb perimeter made of galvanized steel. • Gasketing package provided. • Heat treated wood nailer provided. • Corner flanges are pre-threaded for easy bolt on assembly. • Pitched, adjustable height, welded, different height, isolation and calculated curbs are available. 		HOLD DOWN CLIPS FOR SUNCHOICE UNITS		ProVent P/N	A	Est. Weight	SEISMIC CLIP P/N:	Est. Weight
NOTES Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb. For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60				CBKDSAV202508	8"	335 Lbs.	KDKITSAV2025	15 Lbs.
				CBKDSAV202511	11"	380 Lbs.		
				CBKDSAV202514	14"	425 Lbs.		
				CBKDSAV202518	18"	525 Lbs.	Meets seismic requirements for the following codes: CBC 2019 IBC 2018	
								
HOLD DOWN DETAIL 		CORNER & HOLD DOWN DETAIL 		<div> <div> SUBMITTED TO: _____ COMPANY: _____ JOB NAME: _____ EQUIPMENT: _____ NOTES: _____ </div> <div> PART NUMBER: KDKITSAV2025 <div> DATE: 11/4/2022 REV: - DRAWN BY: JG </div> </div> </div>				
		3847 WABASH DR. MIRA LOMA, CA 91752 PHONE (951) 685-1101 FAX (619) 872-9799						




Client:	ProVent PV2206
Description:	CBKDSA2025 18"
Unit:	Sunchoice AV20-25

Curb Information

Hcurb =	18 in	(Height of curb)
Lcurb =	135.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	525 lbs	(Weight of curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGUnit =	2640 lbs	(Oper. Weight of Unit)
Wtmax =	726 lbs	(Maximum corner weight)
Wtmin =	561 lbs	(Minimum corner weight)
Hunit =	57.23 in	(Height of unit above curb)
Hcm =	28.615 in	(Height to center of mass)
Lunit =	143.81 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp*3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3160 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 3789 lbs
		(unit and curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr[horiz] =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr[vert] =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2548 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1573 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2373 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	3044 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	814 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	595 lbs	= [Fh ASD trans*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1424 lbs	= [Fh ASD trans*Hcm-2*0.6*Wtmin*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	2585 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	354 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	18 lbs	= [Fh ASD long*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	846 lbs	= [Fh ASD long*Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 3044 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1424 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2585 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 846 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.1017 12 Gauge

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.492 in = A' - (2r+t)
B' = 1.500 in	a' = 17.898 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.246 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.449 in = B' - (t/2+αt/2)
R = 0.1525 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.000 in = α[C' - t/2]
r' = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.102 in (Distance between centroid and web centerline)	
Ix = 70.803 in ⁴	rx = 5.81 in
Iy = 0.185 in ⁴	ry = 0.297 in
A = 2.10 in ²	rmin = 0.297 in



Axial Compression

Pu = 1.580 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 6.875 k
Fe = 6.73 ksi
λc = 2.73
Fn = 5.90 ksi
Ly = 77 in
kyLy/ry = 208

$$\text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$$

$$\text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}}$$

$$F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Lateral unbraced length
(assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 18 in -- Check limits: C = 4.00
t = 0.1017 in h/t = 176.99 ≤ 200 CR = 0.14
N = 7.00 N/t = 68.83 ≤ 210 CN = 0.35
Ωw = 1.75 N/h = 0.388889 ≤ 2.0 Ch = 0.02
Pn = 4.390 k R/t = 1.50 ≤ 9.0
Pn/Ωw = 2.509 k
Long side: PuTrans = 1.015 k **O.K.** # clips = 3
Short side: PuLong = 1.292 k **O.K.** # clips = 2

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]

width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys Ωc = 1.70
w/ts = 118.675
1.28√(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc
Pwc = 4.390 k Ae = 0.380 in²
Pn = 16.379 k Pn/Ω = 9.635 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 947 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1522 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.3
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.547 **O.K.**

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25*t = 2.543 in Pn/Ω = 1/Ω 0.75tLFu ≥ Vreq
Lreq'd = 0.721 in Lreq'd = VreqΩ / 0.75tFu



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.1017$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.0$

For $t_2/t_1 \leq 1.0$:

$P_{ns} = 3391$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 3391$ #

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_1dF_{u1}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 1130$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 3.718$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.160	3	1.05	540 #	2	6.00 in
Short side:	3.160	2	1.58	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.1017 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.661$ in²


$A_{nv} = 0.613$ in²

$A_{nt} = 0.060$ in²

$R_n/\Omega = 10.697$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$
(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 1760 lbs	Shear _{MAX} = 1894 lbs
Compression _{SEISMIC} =	4292 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1760 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1245 lbs	$= [F_{h ASD trans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vert ASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1720 lbs	$= [F_{h ASD trans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vert ASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 863 lbs	Shear _{MAX} = 1894 lbs
Compression _{SEISMIC} =	3395 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	863 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	305 lbs	$= [F_{h ASD long} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vert ASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	780 lbs	$= [F_{h ASD long} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vert ASD} * L_{curb}/2] / L_{curb}$

Wood Attachment:

1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	2.86	COMBINED LOADING: 0.946 O.K.
# of Screws Req'd for Shear =	2.82	Screw Spacing = 25.4 in o.c.
Total # of screws Required =	6	

1/4" ϕ x 3.5" Simpson SDS screws @ 25.4 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift =	1.4	COMBINED LOADING: 0.844 O.K.
# of Screws Req'd for Shear =	2.8	Screw Spacing = 18.0 in o.c.
Total # of screws Required =	5	

1/4" ϕ x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 2086 lbs	Vall _{metal} = 2192 lbs
# of Bolts Req'd for Uplift =	0.84	COMBINED LOADING: 0.246 O.K.
# of Bolts Req'd for Shear =	0.86	Bolt Spacing = 61.6 in o.c.
Total # of Bolts Required =	3	

1/2" ϕ A307 Bolts to steel angle below deck @ 61.6 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.41	COMBINED LOADING: 0.319 O.K.
# of Bolts Req'd for Shear =	0.86	Req'd Min Spacing = 68.1 in o.c.
Total # of Bolts Required =	2	

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7\Omega_o E$ $\Omega_o = 2.0$

Concrete Attachment: 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 4000$ psi
 $h = 6$ in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.
 $h_{ef} = 4.5$ in (effective embedment)
 $d_a = 0.625$ in (anchor diameter) $d_o = 0.75$ in (hole diameter)
 $n = 3$ (number of dummy anchors to check capacity with spacing effect)
 $s = 20$ in (initial spacing estimate)
 $\tau_{k,cr}/uncr = 1170$ 2220 psi (from ESR 4868, Table 14, Temp range B)
 $\tau_{k,cr}/uncr = 1226$ 2327 psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$
 $c_{Na} = 9.0625$ in [min. edge distance for full capacity]; $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 985.55 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 10727 \text{ lbs} \quad N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$N_{ag} = 32181 \text{ lbs (group)} \quad \lambda_a = 1.0$$

$$\phi N_{ag} = 15688 \text{ lbs (group)} \quad \text{CONTROLS} \quad \lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightweight}$$

Breakout
strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b \quad N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 722.25 \text{ in}^2$$

$$N_b = 10264 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 182.25 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 40674 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 22879 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$T_{all,LRFD} = 5229 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.708$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 3062 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1796 \text{ lbs} \quad (D = 0.758, E = 0.242)$$

Transverse: Uplift_{MAX} = 3964 lbs Shear_{MAX} = 3789 lbs

$$\text{Compression}_{SEISMIC} = 6496 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3964 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3789 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.29 \text{ spacing} = 61.56 \text{ in o.c.} \quad \text{Tapplied} = 1321.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.11 \text{ spacing} = 61.56 \text{ in o.c.} \quad \text{Vapplied} = 757.7 \text{ lbs}$$

$$\text{Try using } 3 \text{ bolts spaced at } 61.56 \text{ in o.c.} \quad \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.85 \quad \text{O.K.}$$

Use 3 - 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 61.6 in o.c. max. along long side of curb w/ 4.5in embed

Longitudinal: Uplift_{MAX} = 2170 lbs Shear_{MAX} = 3789 lbs

$$\text{Compression}_{SEISMIC} = 4702 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 2170 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$$


$$\text{Shear}_{SEISMIC} = 3789 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 0.71 \text{ spacing} = 34.06 \text{ in o.c.} \quad \text{Tapplied} = 1084.8 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.11 \text{ spacing} = 34.06 \text{ in o.c.} \quad \text{Vapplied} = 757.7 \text{ lbs}$$

$$\text{Try using } 2 \text{ bolts spaced at } 68.13 \text{ in o.c.} \quad \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.78 \quad \text{O.K.}$$

Use 2 - 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 4.5in embed



CURB DESIGN SUMMARY:		CBKDSAV2025	Unit:	Sunchoice AV20-25
CURB RAIL THICKNESS:		0.1017 in	12 Gauge	
UNIT CLIP THICKNESS:		0.1017 in	12 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts				
CURB ANCHORAGE	WOOD	STEEL	CONCRETE	
	1/4" ϕ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" ϕ A307 Bolts to steel angle below deck	5/8" ϕ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed	
	6 @ 25.43 in o.c.	3 @ 61.56 in o.c.	3 @ 61.56 in o.c.	
LONG DIRECTION	5 @ 18.03 in o.c.	2 @ 68.13 in o.c.	2 @ 68.13 in o.c.	
SHORT DIRECTION				




Client:	ProVent PV2206
Description:	CBKDSA2025 14"
Unit:	Sunchoice AV20-25

Curb Information

Hcurb =	14 in	(Height of curb)
Lcurb =	135.125 in	(Length of curb)
wcurb =	80.125 in	(Width of curb)
WGTCurb =	425 lbs	(Weight of curb)
# Clips long side =	3	# Clips short side = 2

Unit Information

WGUnit =	2640 lbs	(Oper. Weight of Unit)
Wtmax =	726 lbs	(Maximum corner weight)
Wtmin =	561 lbs	(Minimum corner weight)
Hunit =	57.23 in	(Height of unit above curb)
Hcm =	28.615 in	(Height to center of mass)
Lunit =	143.81 in	(Length of unit)
Wunit =	88.75 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.85	(Worst case for majority of California)
Fa =	1.20	(Default Site Class D - Table 11.4-1 ASCE 7-16)
Ip =	1.50	(Importance Factor Category III Building)
Sms =	3.420	(Fa*Ss)
Sds =	2.280	(2/3*Sms)
Fpmax =	1.710 Wp	(0.4*ap*Sds*Ip)*Wp/3/Rp <= 1.6*Sds*Ip*Wp
FpmaxASD =	3160 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 3669 lbs
		(unit and curb)

Wind Loading - 2018 IBC/2019 CBC

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 26.10-1 ASCE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	110	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 25.5-1D, ASCE7-16)
GCr[horiz] =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr[vert] =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	29.8 psf	= 0.00256*Kz*Kzt*Kd*V ² (Eq. 26.10-1 ASCE 7-16)
Fh ASD trans =	2413 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	1489 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	2373 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	3044 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	814 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*wcurb]/wcurb
Compression _{WIND} =	546 lbs	= [Fh ASD trans*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	1375 lbs	= [Fh ASD trans*Hcm-2*0.6*Wtmin*wcurb+Fvert ASD*wcurb/2]/wcurb

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	2585 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	354 lbs	= [FpmaxASD*Hcm-2*(0.6-0.14S _{DS})*Wtmin*Lcurb]/Lcurb
Compression _{WIND} =	0 lbs	= [Fh ASD long*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	829 lbs	= [Fh ASD long*Hcm-2*0.6*Wtmin*Lcurb+Fvert ASD*Lcurb/2]/Lcurb

---> Negative values indicate opposite load.

Governing Reactions:

Transverse:	Comp _{MAX} = 3044 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1375 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2585 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 829 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

Fy = 50 ksi Fu = 65 ksi
E = 29500 ksi t = 0.0713 14 Gauge

Calculate Section Properties of Curb

A' = 14.000 in	a = 13.644 in = A' - (2r+t)
B' = 1.500 in	a' = 13.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.128 in (Distance between centroid and web centerline)	
Ix = 25.770 in ⁴	rx = 4.65 in
Iy = 0.130 in ⁴	ry = 0.330 in
A = 1.19 in ²	rmin = 0.330 in



Axial Compression

Pu = 1.580 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 4.830 k
Fe = 8.31 ksi
λc = 2.45
Fn = 7.29 ksi
Ly = 77 in
kyLy/ry = 187

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Lateral unbraced length
(assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 196.35 ≤ 200 CR = 0.14
N = 7.00 N/t = 98.18 ≤ 210 CN = 0.35
Ωw = 1.75 N/h = 0.5 ≤ 2.0 Ch = 0.02
Pn = 2.422 k R/t = 1.50 ≤ 9.0
Pn/Ωw = 1.384 k
Long side: PuTrans = 1.015 k
Short side: PuLong = 1.292 k

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

O.K. # clips = 3
O.K. # clips = 2

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]

width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys Ωc = 1.70
w/ts = 118.675
1.28√(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc
Pwc = 2.422 k Ae = 0.380 in²
Pn = 15.002 k Pn/Ω = 8.825 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 917 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1522 lbs Max(Tens/2 -OR- Comp/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1208 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1536 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.3
of Bolts Used = 3.0
Check Combined Stress in Bolts & Inserts: 0.543 **O.K.**

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25*t = 1.783 in Pn/Ω = 1/Ω 0.75tLu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu

Lreq'd = 1.029 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.160	3	1.05	540 #	2	6.00 in
Short side:	3.160	2	1.58	540 #	3	3.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²


$A_{nv} = 0.430$ in²

$A_{nt} = 0.042$ in²

$R_n/\Omega = 7.500$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$
(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 1550 lbs	Shear _{MAX} = 1834 lbs
Compression _{SEISMIC} =	3973 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Tension _{SEISMIC} =	1521 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$
Compression _{WIND} =	1016 lbs	$= [F_{h ASD trans} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * w_{curb}/2 - F_{vert ASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1550 lbs	$= [F_{h ASD trans} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * w_{curb}/2 + F_{vert ASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 737 lbs	Shear _{MAX} = 1834 lbs
Compression _{SEISMIC} =	3179 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Tension _{SEISMIC} =	727 lbs	$= [F_{pmax} ASD * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$
Compression _{WIND} =	202 lbs	$= [F_{h ASD long} * (H_{cm} + H_{curb}) + 0.6 * WGT_{unit+curb} * L_{curb}/2 - F_{vert ASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	737 lbs	$= [F_{h ASD long} * (H_{cm} + H_{curb}) - 0.6 * WGT_{unit+curb} * L_{curb}/2 + F_{vert ASD} * L_{curb}/2] / L_{curb}$

Wood Attachment:

1/4" ϕ x 3.5" Simpson SDS screw w/ 2.25" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 997 lbs	Vall _{metal} = 1097 lbs
	Tall _{wood} = 616 lbs	Vall _{wood} = 672 lbs
# of Screws Req'd for Uplift =	2.52	COMBINED LOADING: 0.874 O.K.
# of Screws Req'd for Shear =	2.73	Screw Spacing = 25.4 in o.c.
Total # of screws Required =	6	

1/4" ϕ x 3.5" Simpson SDS screws @ 25.4 in o.c. along long side of curb w/ 2.25" threaded embed

Longitudinal:

# of Screws Req'd for Uplift =	1.2	COMBINED LOADING: 0.785 O.K.
# of Screws Req'd for Shear =	2.7	Screw Spacing = 18.0 in o.c.
Total # of screws Required =	5	

1/4" ϕ x 3.5" Simpson SDS screws @ 18 in o.c. along short side of curb w/ 2.25" threaded embed

Steel Deck Attachment:

1/2" ϕ A307 Bolts to steel angle below deck

Transverse:	Tall _{bolt} = 3927 lbs	Vall _{bolt} = 2209 lbs
	Tall _{metal} = 2086 lbs	Vall _{metal} = 2192 lbs
# of Bolts Req'd for Uplift =	0.74	COMBINED LOADING: 0.217 O.K.
# of Bolts Req'd for Shear =	0.84	Bolt Spacing = 61.6 in o.c.
Total # of Bolts Required =	3	

1/2" ϕ A307 Bolts to steel angle below deck @ 61.6 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift =	0.35	COMBINED LOADING: 0.290 O.K.
# of Bolts Req'd for Shear =	0.84	Req'd Min Spacing = 68.1 in o.c.
Total # of Bolts Required =	2	

1/2" ϕ A307 Bolts to steel angle below deck @ 68.1 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7\Omega_o E$ $\Omega_o = 2.0$

Concrete Attachment: 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed

Epoxy: Hilti HIT-HY 200 V3 (ICC ESR 4868)

$f'_c = 4000$ psi

$h = 6$ in (concrete thickness, $t_{min} = h_{ef} + 2d_o$) O.K.

$h_{ef} = 4.5$ in (effective embedment)

$d_a = 0.625$ in (anchor diameter) $d_o = 0.75$ in (hole diameter)

$n = 3$ (number of dummy anchors to check capacity with spacing effect)

$s = 20$ in (initial spacing estimate)

$\tau_{k,cr} / \text{uncr} = 1170$ 2220 psi (from ESR 4868, Table 14, Temp range B)

$\tau_{k,cr} / \text{uncr} = 1226$ 2327 psi If $f'_c > 2500$, multiply by $(f'_c/2500)^{0.1}$

$c_{Na} = 9.0625$ in (min. edge distance for full capacity); $c_{Na} = 10d_a \sqrt{\frac{\tau_{uncr}}{1100}}$

Tension:

Bond strength

***Bond strength
will govern over
concrete breakout

$$N_{ag} = \frac{A_{Na}}{A_{Na0}} \phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} N_{ba} \quad (\text{ACI318-14, 17.4.5.1b})$$

$$\phi_{ec,Na} \phi_{ed,Na} \phi_{cp,Na} = 1.0$$

$$A_{Na} = 985.55 \text{ in}^2$$

$$A_{Na0} = 328.52 \text{ in}^2$$

$$N_{ba} = 10727 \text{ lbs} \quad N_{ba} = \lambda_a \tau_{cr} \pi d_a h_{ef} \alpha_{n,seismic} \quad \alpha_{n,seismic} = 0.99$$

$$N_{ag} = 32181 \text{ lbs (group)} \quad \lambda_a = 1.0$$

$$\phi N_{ag} = 15688 \text{ lbs (group)} \quad \text{CONTROLS} \quad \lambda_a = 1.0 \text{ for normal weight conc; } 0.6 \text{ for lightweight}$$

Breakout
strength

$$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \phi_{ec,N} \phi_{ed,N} \phi_{cp,N} N_b \quad N_b = \lambda_a k_c \sqrt{f'_c} h_{ef}^{1.5}$$

$$A_{Nc} = 722.25 \text{ in}^2$$

$$N_b = 10264 \text{ lbs}$$

$$\phi_{conc} = 0.75$$

$$A_{Nco} = 182.25 \text{ in}^2$$

$$k_c = 17$$

$$\phi_{bond} = 0.65$$

$$N_{cbg} = 40674 \text{ lbs (group)}$$

$$\phi_{seis} = 0.75$$

$$\phi N_{cbg} = 22879 \text{ lbs (group)}$$

$$\phi_{steel} = 0.65$$

Shear:

Steel strength

$$V_{sa,eq} = 7865 \text{ (from ESR4868, Table 11)}$$

$$\alpha_{v,seismic} = 0.6$$

$$\phi V_{sa,eq} = 3067$$

$$T_{all,LRFD} = 5229 \text{ lbs (anchor)}$$

$$V_{all,LRFD} = 3067 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.708$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 3062 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1796 \text{ lbs} \quad (D = 0.758, E = 0.242)$$

$$\text{Transverse: } Uplift_{MAX} = 3472 \text{ lbs} \quad Shear_{MAX} = 3669 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 5924 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3472 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * w_{curb}/2] / w_{curb}$$

$$\text{Shear}_{SEISMIC} = 3669 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.13 \text{ spacing} = 61.56 \text{ in o.c.} \quad T_{applied} = 1157.4 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.04 \text{ spacing} = 61.56 \text{ in o.c.} \quad V_{applied} = 733.8 \text{ lbs}$$

Try using 3 bolts

spaced at 61.56 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.79 \quad \text{O.K.}$$

Use 3 - 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 61.6 in o.c. max. along long side of curb w/ 4.5in embed

$$\text{Longitudinal: } Uplift_{MAX} = 1884 \text{ lbs} \quad Shear_{MAX} = 3669 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 4336 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 1884 \text{ lbs} = [\Omega_o * F_{pmaxASD} * (H_{cm} + H_{curb}) - (0.6 - 0.14S_{DS}) * WGT_{unit+curb} * L_{curb}/2] / L_{curb}$$

$$\text{Shear}_{SEISMIC} = 3669 \text{ lbs} = \Omega_o * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 0.62 \text{ spacing} = 34.06 \text{ in o.c.} \quad T_{applied} = 941.9 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.04 \text{ spacing} = 34.06 \text{ in o.c.} \quad V_{applied} = 733.8 \text{ lbs}$$

Try using 2 bolts

spaced at 68.13 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.72 \quad \text{O.K.}$$

Use 2 - 5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy @ 68.1 in o.c. max. along short side of curb w/ 4.5in embed

CURB DESIGN SUMMARY:		CBKDSAV2025	Unit:	Sunchoice AV20-25
CURB RAIL THICKNESS:		0.0713 in	14 Gauge	
UNIT CLIP THICKNESS:		0.0713 in	14 Gauge	
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip				
WEB STIFFENER: NOT REQUIRED				
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts				
CURB ANCHORAGE	WOOD	STEEL	CONCRETE	
	1/4"φ x 3.5" Simpson SDS screws w/ 2.25" threaded embed	1/2" φ A307 Bolts to steel angle below deck	5/8"φ HAS rods in Hilti HIT-HY 200 V3 epoxy w/ 4.5in embed	
LONG DIRECTION	6 @ 25.43 in o.c.	3 @ 61.56 in o.c.	3 @ 61.56 in o.c.	
SHORT DIRECTION	5 @ 18.03 in o.c.	2 @ 68.13 in o.c.	2 @ 68.13 in o.c.	

