




MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

Structural Calculations
for
CBKD Series Roof Curbs
CBKD-95A (80-265-29)
2020 Florida Building Code requirements



Exp. 02 / 28 / 2023


Prepared for:

PROVENT
3847 Wabash Drive
Mira Loma, CA 91725

Date: May 19, 2021
Project Number: PV2101

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.




WIND LOAD ROOF ANCHORAGE DETAIL

Meets wind requirements for the following codes:
FBC 2020
based on ASCE 7-16.

Wind:
190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max

CONCRETE ATTACHMENT

WELDED CURB
CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D ROD IN HILTI HIT-HY 200 EPOXY, 4" MIN. EMBED INTO CONCRETE.




- NORMAL WEIGHT CONC SLAB
- f_c=4000 PSI MIN
- 6" MIN THICK CONC.
- SPECIAL INSPECTION REQUIRED (ESR-3187)

CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE *	
80-265-49	2 @ 34.5" o.c.	2 @ 19" o.c.	LXS
80-265-50	2 @ 34.5" o.c.	2 @ 29" o.c.	LXL
80-265-13	2 @ 61" o.c.	2 @ 25.25" o.c.	SUNLINE 3-6 TON
80-265-45	2 @ 58.38" o.c.	2 @ 28.19" o.c.	PRESTIGE SMALL
80-265-46	2 @ 72" o.c.	2 @ 41" o.c.	PRESTIGE LARGE
80-265-29	3 @ 34.69" o.c.	2 @ 39.5" o.c.	PREDATOR
80-265-19	3 @ 51.63" o.c.	2 @ 72" o.c.	SUNLINE ULTRA
80-265-18	3 @ 57.13" o.c.	2 @ 72" o.c.	SUNLINE MAGNA

CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE **	
80-265-49	5 @ 8.63" o.c.	3 @ 9.5" o.c.	LXS
80-265-50	5 @ 8.63" o.c.	4 @ 9.67" o.c.	LXL
80-265-13	5 @ 15.25" o.c.	3 @ 12.63" o.c.	SUNLINE 3-6 TON
80-265-45	5 @ 14.59" o.c.	3 @ 14.09" o.c.	PRESTIGE SMALL
80-265-46	5 @ 18" o.c.	4 @ 13.67" o.c.	PRESTIGE LARGE
80-265-29	9 @ 8.67" o.c.	5 @ 9.88" o.c.	PREDATOR
80-265-19	8 @ 14.75" o.c.	6 @ 14.4" o.c.	SUNLINE ULTRA
80-265-18	12 @ 10.39" o.c.	8 @ 10.29" o.c.	SUNLINE MAGNA

WOOD ATTACHMENT




CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø WOOD LAG SCREWS (3.5" MIN. EMBED. INTO WOOD FRAMING)

STEEL AND CONCRETE ANCHORS ARE 6" FROM EACH CORNER EVENLY SPACED


CURB KIT	NO. OF ANCHORAGE SCREWS REQUIRED		UNIT
	LONG SIDE	SHORT SIDE	
80-265-49	6 @ 7.7" o.c.	3 @ 11.5" o.c.	LXS
80-265-50	5 @ 9.63" o.c.	5 @ 8.25" o.c.	LXL
80-265-13	6 @ 13" o.c.	3 @ 14.63" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 12.48" o.c.	3 @ 16.09" o.c.	PRESTIGE SMALL
80-265-46	6 @ 15.2" o.c.	4 @ 15" o.c.	PRESTIGE LARGE
80-265-29	10 @ 8.15" o.c.	6 @ 8.7" o.c.	PREDATOR
80-265-19	8 @ 15.32" o.c.	6 @ 15.2" o.c.	SUNLINE ULTRA
80-265-18	14 @ 9.1" o.c.	8 @ 10.86" o.c.	SUNLINE MAGNA

FOUR INCHES FROM EACH CORNER EVENLY SPACED.

CONCRETE OVER METAL DECK



NOTE: FOR CONC OVER METAL DECK OVER STEEL FRAMING USE STEEL ATTACHMENT



Exp. 02 / 28 / 2023



1625 DIPLOMAT DRIVE
CARROLTON, TX 75006

PHONE (972) 247-7447
FAX (972) 243-0940

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:

CB-25A

DATE:
3/29/2021

REV:
2

DRAWN BY:
ALL

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-25A.

Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)







CALCULATED WIND ROOF CURBS FOR YORK UNITS

**ZT, ZH, ZJ, ZR 037-150
ZF, XP, ZB 078-150**

ProVent P/N	A	WEIGHT
80-265-2914	14"	270 Lbs
80-265-2918	18"	350 Lbs

Meets wind requirements for the following codes:
FBC 2020
based on ASCE 7-16.

Wind:
190 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.00 max



1625 DIPLOMAT DRIVE
CARROLTON, TX 75006

PHONE (972) 247-7447
FAX (972) 243-0940

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBKD-95A

DATE:
3/29/2021

PART NUMBER:
80-265-29

REV:
2

DRAWN BY:
ALL




Client:	ProVent PV2101	Previous:	PV1807
Description:	CBKD-95	80-265-29**	
Unit:	ZT,ZH,ZJ,ZR 037-061; ZF,ZH,ZJ,ZR,XP 078-150		

Curb Information

Hcurb =	18 in	(Height of curb)
Lcurb =	81.375 in	(Length of curb)
wcurb =	51.5 in	(Width of curb)
WGTcurb =	350 lbs	(Weight of curb)
# Clips long side =	2	# Clips short side = 2

Unit Information

WGTunit =	1253 lbs	(Weight of Unit)
Wtmax =	381 lbs	(Maximum corner weight)
Wtmin =	251 lbs	(Minimum corner weight)
Hunit =	50.75 in	(Height of unit above curb)
Hcm =	25.375 in	(Height to center of mass)
Lunit =	119.5 in	(Length of unit)
Wunit =	59 in	(Width of unit)



Seismic Loading - 2020 FBC/2018 IBC

Ss =	0.15	(Worst Case for state of Florida)
Fa =	2.4	(Worst case Site class E from Table 11.4-1 ASCE 7-16)
Sms =	0.360	(Fa*Ss)
Sds =	0.240	(2/3*Sms)
Ip =	1.5	(Importance Factor Category III or IV Building)
Fpmax =	0.576 WGTunit	(1.6*Sds*Ip)*WGTunit (Eq 13.3-2 ASCE 7-16)
FpmaxASD =	505 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 646 lbs (unit and curb)

Wind Loading - 2020 FBC/2018 IBC

Kz =	1.31	*** Exposure Category D *** (For 60 ft roof height, Exposure D - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	190	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr(horiz) =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	102.9 psf	= 0.00256*Kz*Kzt*Kd*Ke*V ² (Eq. 26.10-1 ASCE 7-10)
Fh ASD trans =	6693 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
Fh ASD long =	3304 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	4535 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	1037 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	327 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	1488 lbs	= [Fh trans ASD *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension _{WIND} =	5270 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Longitudinal:

Compression _{SEISMIC} =	945 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	235 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	-780 lbs	= [Fh trans ASD *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension _{WIND} =	3003 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

---> Negative values indicate opposite load.

Governing Reactions:

<u>Transverse:</u>	Comp _{MAX} = 1488 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 5270 lbs	---> Along long edge of curb.
<u>Longitudinal:</u>	Comp _{MAX} = 945 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 3003 lbs	---> Along short edge of curb.

---> Negative values indicate opposite load.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.644 in = A' - (2r+t)
B' = 1.813 in	a' = 17.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.634 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.777 in = B' - [t/2+at/2]
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.148 in (Distance between centroid and web centerline)	
I _x = 53.924 in (Moment of Inertia about X-Axis)	
I _y = 0.233 in (Moment of Inertia about Y-Axis)	
A = 1.52 in ²	
r _x = 5.95 in	
r _y = 0.391 in	
r _{min} = 0.391 in	



Axial Compression

P _u = 3.346 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 19.078 k		
F _e = 26.28 ksi		
λ _c = 1.38		
F _n = 22.55 ksi		
L _y = 52 in		
k _y L _y /r _y = 105		

Lateral unbraced length (assume k=0.8)

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Compression Check = O.K.

Check Web Crippling

h = 18 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 252.45 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.388889 ≤ 2.0	C _h = 0.02	
P _n = 2.296 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 1.312 k			
Long side: P _{uTrans} = 0.744 k	O.K. # clips = 2		
Short side: P _{uLong} = 0.473 k	O.K. # clips = 2		

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$$

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/F _y	Ω _c = 1.70
w/ts = 118.675	
1.28√(E/F _y) = 31.091	--> w/ts over limit Use C3.7.2
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}	
P _{wc} = 2.296 k	A _e = 0.380 in ²
P _n = 14.913 k	P _n /Ω = 8.773 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 1673 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
V _{crnmax} = 2635 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.7	
# of Bolts required for Shear = 2.4	
# of Bolts Used = 3.0	
Check Combined Stress in Bolts & Inserts: 1.026 N.G.	StressComb = 0.770 O.K.

***If combined fails: USE --> 4.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in P_n/Ω = 1/Ω * 0.75tL F_u ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u

L_{req'd} = 1.782 in



Connection Unit to Curb Clip

#14 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.242$ in (screw diameter)

$d_w = 0.500$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3028 # $P_{ns} = 4.36$ k

$P_{ns} = 2.7t_1dF_{u1}$ 3.03 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{ns}/\Omega = 1009$ # <- Controls

$P_{ss}/\Omega = 1045$ #

Tension:

$P_{not} = 1.360$ k (screw pull-out strength)

$P_{nov} = 3.476$ k (screw pull-over strength)

$P_{ts}/\Omega = 453$ # <- Controls

$P_{ts}/\Omega = 1220$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 3028$ # $P_{ns} = 3028$ #

$P_{ns} = 2.7t_1dF_{u1}$ 3.03 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.652	2	0.83	1009 #	2	6.00 in
Short side:	3.346	2	1.67	1009 #	2	6.00 in

clip width (in) = 7.00

min spacing = 0.73 in

clip height = 2.5 in

edge distance = 0.5 in (min. 1.5d)

thinnest part = 0.0713 AISI BSR applies

Check Block shear rupture: O.K.

$F_y = 50$ ksi

$A_{gv} = 0.463$ in²

$R_n/\Omega = 8.620$ k

$\Omega = 2.22$ bolt/screw connection


$A_{nv} = 0.438$ in²

$A_{nt} = 0.080$ in²

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 7423 lbs	Shear _{MAX} = 3346 lbs
Compression _{SEISMIC}	1373 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}
Tension _{SEISMIC}	465 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND}	3851 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*w _{curb} -F _{vertASD} *w _{curb}]/2/w _{curb}
Tension _{WIND}	7423 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*w _{curb} +F _{vertASD} *w _{curb}]/2/w _{curb}
Longitudinal:	Uplift _{MAX} = 3548 lbs	Shear _{MAX} = 1652 lbs
Compression _{SEISMIC}	1173 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}
Tension _{SEISMIC}	265 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND}	-25 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*L _{curb} -F _{vertASD} *L _{curb}]/2/L _{curb}
Tension _{WIND}	3548 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*L _{curb} +F _{vertASD} *L _{curb}]/2/L _{curb}

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Transverse:	Tall _{metal} = 946.67 lbs	Vall _{metal} = 1043.33 lbs
	Tall _{wood} = 1195.95 lbs	Vall _{wood} = 1024 lbs
	# of Screws Req'd for Uplift = 7.84	COMBINED LOADING: 0.988 O.K.
	# of Screws Req'd for Shear = 3.27	Screw Spacing = 8.2 in o.c.
	Total # of screws Required = 10	

Use 5/8" ϕ wood lag screws @ 8.2 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

	# of Screws Req'd for Uplift = 3.7	COMBINED LOADING: 0.725 O.K.
	# of Screws Req'd for Shear = 1.6	Screw Spacing = 8.7 in o.c.
	Total # of screws Required = 6	

Use 5/8" ϕ wood lag screws @ 8.7 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Transverse:	Tall _{bolt} = 6903 lbs	Vall _{bolt} = 3682 lbs
	6903 lbs	3682 lbs
	# of Bolts Req'd for Uplift = 1.08	COMBINED LOADING: 0.318 O.K.
	# of Bolts Req'd for Shear = 0.91	Bolt Spacing = 34.7 in o.c.
	Total # of Bolts Required = 3	

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 34.7 in o.c. along long side of curb

Longitudinal:

	# of Bolts Req'd for Uplift = 0.51	COMBINED LOADING: 0.187 O.K.
	# of Bolts Req'd for Shear = 0.45	Req'd Min Spacing = 39.5 in o.c.
	Total # of Bolts Required = 2	

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 39.5 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)
Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed
 $T_{all,LRFD} = 1722 \text{ lbs}$ $V_{all,LRFD} = 2032 \text{ lbs}$ $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 $T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs}$ $V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs}$ ($D = 0.465, E = 0.535$)

Transverse: Uplift_{MAX} = 7423 lbs Shear_{MAX} = 3346 lbs
 Compression_{SEISMIC} = 2189 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$
 Tension_{SEISMIC} = 1281 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
 Shear_{SEISMIC} = 808 lbs = $2.5 * F_{pmaxASD} / 2$
 Min Bolts Req'd Uplift = 8.06 spacing = 7.17 in o.c. T_{applied} = 824.8 lbs
 Min Bolts Req'd Shear = 3.08 spacing = 19.125 in o.c. V_{applied} = 239.0 lbs
 Try using 9 bolts spaced at 8.67 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12$

Use 9 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 8.7 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 3548 lbs Shear_{MAX} = 3346 lbs
 Compression_{SEISMIC} = 1690 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$
 Tension_{SEISMIC} = 782 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
 Shear_{SEISMIC} = 808 lbs = $2.5 * F_{pmaxASD} / 2$
 Min Bolts Req'd Uplift = 3.85 spacing = 9.166667 in o.c. T_{applied} = 709.6 lbs
 Min Bolts Req'd Shear = 3.08 spacing = 9.166667 in o.c. V_{applied} = 239.0 lbs

Try using 5 bolts spaced at 9.88 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.99$

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 9.9 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-95 80-265-29**		Unit: ZT,ZH,ZI,ZR 037-061;	
CURB RAIL THICKNESS: 0.0713 in 14 Gauge		ZF,ZH,ZI,ZR,XP 078-150	
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 4 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD 5/8" φ lag screw w/ min. 3.5" embed (SGmin=0.43)	STEEL 5/8" φ A307 bolts to steel angle below	CONCRETE 3/4" φ thr'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	10 @ 8.15 in o.c.	3 @ 34.69 in o.c.	9 @ 8.67 in o.c.
SHORT DIRECTION	6 @ 8.7 in o.c.	2 @ 39.5 in o.c.	5 @ 9.88 in o.c.