




MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

Structural Calculations
for
Sunline Magna Series
ISCALSLM1830 Roof Curb**
Form No. ISCAL-129



Prepared for:

PROVENT

3847 Wabash Drive
Mira Loma, CA 91725

Date: November 14, 2019

Project Number: PV1907

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-24A.

Welded isolation spring housings are standard. For bolted spring housings, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. ISCAL-131.

FEATURES

- Roof curb sides and ends are 14 ga. galvanized steel.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPD pre-approved 2" or 3" deflection seismic restraints. (OPA-0070), (JQB).
- Optional bottom bumper CalDyn #KT-382B, with a 1/2" washer and nut installed on seismic restraints.



NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.


CORNER	ZF	XP 180-240	ZJ, ZR	180-300	ZF	210-300	ZJ, ZR	180-300	WITH PE	WITH PE
A	348-171	241-241	348	348	348	348	348	348	348	348
B	590	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171
C	453	453-171	348-171	453-171	348-171	453-171	348-171	453-171	453-171	453-171
D	453-171	241-241	348-171	348-171	348-171	348-171	348-171	348-171	348-171	348-171
E	348	453-171	348	453-171	348	453-171	453-171	453-171	453-171	453-171
F	348	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171
G	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171	453-171
H	348	241	348	348	348	348	348	348	348	348

STRUCTURALLY CALCULATED VIBRATION ISOLATION CURBS FOR YORK UNITS

Z/J/ZR 180-300: ZF 210-300: XP 180-240



PROFILE DETAIL



ProVent P/N (2" Deflection)	A	B	WEIGHT	ProVent P/N (3" Deflection)	A	B	WEIGHT
ISCALSLM183019**	8"	19"	825 Lbs	ISCALSLM1830193**	8"	19"	825 Lbs
ISCALSLM183022**	11"	22"	855 Lbs	ISCALSLM1830223**	11"	22"	855 Lbs
ISCALSLM183025**	14"	25"	885 Lbs	ISCALSLM1830253**	14"	25"	885 Lbs

**Note: Spring configuration must be added to part number at time of order.

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

FORM NO: ISCAL-129
PART NUMBER: ISCALSLM1830 SERIES

DATE: 11/13/19
REV: 7


SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799



STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS TO STEEL ANGLE BELOW.



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	2 @ 62.13 in o.c.	2 @ 24.75 in o.c.
PRD3715	2 @ 68.38 in o.c.	2 @ 38.50 in o.c.
SLM1830	3 @ 56.88 in o.c.	3 @ 35.75 in o.c.


* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

Meets seismic requirements for the following codes:
CBC 2019
IBC 2018

ASSUMES:
CONC SLAB
f_c = 4000PSI MINIMUM
5 1/2" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT

WELDED CURB



CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D RODS IN HILTI HIT-HY 200 EPOXY W/ 4" EMBED INTO CONCRETE.

NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	13 @ 5.18 in o.c.	8 @ 3.54 in o.c.
PRD3715	19 @ 3.8 in o.c.	14 @ 2.96 in o.c.
SLM1830	23 @ 5.17 in o.c.	17 @ 4.47 in o.c.

ROOF ANCHORAGE DETAIL

CBKD Series	CBWC Series	ISCAL Series
SUN3672	SUN3672	SUN3672
PRD3715	PRD3715	PRD3715
SLM1830	SLM1830	SLM1830


WOOD ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø SIMPSON SDS SCREWS W/3" MIN. EMBED INTO WOOD (SG MIN = 0.43)



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
SUN3672	14 @ 5.09 in o.c.	10 @ 3.19 in o.c.
PRD3715	17 @ 4.52 in o.c.	12 @ 3.86 in o.c.
SLM1830	19 @ 6.54 in o.c.	16 @ 5.03 in o.c.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 665-1101
FAX (619) 872-0789

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-24A

DATE: 11/15/19
REV: 15
DRAWN BY: ALL




Client:	ProVent PV1907	Upper curb tube
Curb:	ISCAL-129 Iso Curb (ISCALSLM1830**)	
Unit:	ZJ/ZR 180-300; ZF 210-300; XP 180-240	

Curb Information

Hcurb upper =	6 in	(Height of upper curb tube)
Lcurb =	125.75 in	(Length of curb)
wcurb =	83.5 in	(Width of curb)
WGTcurb top =	244 lbs	(Weight of upper curb)
# Clips long side =	4	# Clips short side = 3

Unit Information

WGTunit =	3930 lbs	(Weight of Unit)
Wtmax =	2116 lbs	(Maximum corner weight)
Wtmin =	1110 lbs	(Minimum corner weight)
Hunit =	52.625 in	(Height of unit above curb)
Hcm =	26.3125 in	(Height to center of mass)
Lunit =	180.5 in	(Length of unit)
Wunit =	92 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.000	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-16)
Sms =	2.000	(Fa*Ss)
Sds =	1.333	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	3.200 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	8803 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 9350 lbs
		(unit and upper curb)

Wind Loading - 2018 IBC/2019 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr _(horiz) =	1.9	
GCr _(vert) =	1.5	
qz =	32.5 psf	$= 0.00256 * Kz * Kzt * Kd * V^2$
F _{h ASD trans} =	2724 lbs	$= 0.6 * qz * GCr * Lunit * (Hunit + Hcurb upper)$
F _{h ASD long} =	1389 lbs	$= 0.6 * qz * GCr * Wunit * (Hunit + Hcurb upper)$
F _{vert ASD} =	3375 lbs	$= 0.6 * qz * GCr * Lunit * Wunit$

Curb Loading

Transverse:

Compression _{SEISMIC} =	7796 lbs	$= [FpmaxASD * Hcm + 2 * (1 + 0.14 * Sds) * Wtmax * wcurb] / wcurb$
Tension _{SEISMIC} =	6172 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14 * Sds) * WGTunit$
Compression _{WIND} =	1710 lbs	$= [F_{h trans ASD} * Hcm + 2 * 0.6 * Wtmax * wcurb - F_{vert ASD} * wcurb / 2] / wcurb$
Tension _{WIND} =	2727 lbs	$= Comp_{WIND} + F_{vert} - 0.6 * WGTunit$

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	6864 lbs	$= [FpmaxASD * Hcm + 2 * (1 + 0.14 * Sds) * Wtmax * Lcurb] / Lcurb$
Tension _{SEISMIC} =	5240 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14 * Sds) * WGTunit$
Compression _{WIND} =	1142 lbs	$= [F_{h trans ASD} * Hcm + 2 * 0.6 * Wtmax * Lcurb - F_{vert ASD} * Lcurb / 2] / Lcurb$
Tension _{WIND} =	2159 lbs	$= Comp_{WIND} + F_{vert} - 0.6 * WGTunit$

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 7796 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 6172 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 6864 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 5240 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.



Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.1242 **10 Gauge**
E = 29500 ksi

Tube Curb Design

Section Properties of Tube - 6.5x1.5x10Ga

Fy = 55 ksi Fu = 65 ksi Ag = 1.871 in² R = 0.1875 d = 5.625
E = 29500 ksi Ix = 3.742 in⁴ Iy = 0.412 in⁴ wt = 218.908
height = 6 in Sx = 1.247 in³ Sy = 0.550 in³
width = 1.5 in rx = 1.414 in ry = 0.469 in b/t = 12.07729
t = 0.1242 in Zx = 1.625 in³ Zy = 0.595 in³ d/t = 45.28986

Check weak axis bending of tube:

<u>Long side</u>		<u>Short side</u>	
# clips = 4		# clips = 3	
compression = 70.006 lb/in		compression = 105.428 lb/in	
clip spacing = 39.25 in		clip spacing = 35.75 in	
Mmax = 13.5 k-in		Mmax = 16.84 k-in	
Yielding My = 30.24 k-in		Mp/Ω = 18.11 k-in	D.K.
Flange local buckling Mn = 30.24 k-in	<--Section is compact, FLB does not apply		
Web local buckling Mn = 30.24 k-in	<--Section is compact, WLB does not apply		

Axial Compression

Pa = 4.402 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 8.272 k
Fe = 16.01 ksi
λc = 1.767
Fn = 14.04 ksi
Ly = 70.13 in
k_yL_y/r_y = 135

$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

λ_c = $\sqrt{\frac{F_y}{F_c}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = **D.K.**

Check Web Crippling

h = 6 in t = 0.1242 in N = 7.00 Ω_w = 1.75 P_n = 5.907 k P_n/Ω_w = 3.375 k
Long side: Pa_{Trans} = 1.949 k Short side: Pa_{Long} = 2.288 k

-- Check limits: C = 7.50 C_R = 0.08 C_N = 0.12 C_h = 0.048

(See table C3.4.1-2, fastened to support, two flange, end loading)

$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \frac{R}{\sqrt{t}}\right) \left(1 + C_N \frac{N}{\sqrt{t}}\right) \left(1 - C_h \frac{h}{\sqrt{t}}\right)$

D.K. # clips = 4
D.K. # clips = 3

Check Web Stiffener

N/A
width of stiffener = 7.000 in ts = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 118.675
1.28√E/F_y = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_cF_y) ≥ P_{wc} Ae = 0.380 in²
P_{wc} = 5.907 k P_n = 17.441 k
P_n/Ω_c = 10.259 k **Not Req'd**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crn}max = 2201 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crn}max = 3086 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = **2480** lbs Vall = **1096** lbs
Threaded Insert: Tall = **2860** lbs Vall = **1714** lbs
of Bolts required for Tension = 0.9
of Bolts required for Shear = 2.8
of Bolts Used = **3.0** ***If combined fails: USE --> 4.0
Check Combined Stress in Bolts & Inserts: 1.234 **N.G.** StressComb = 0.926 **D.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 3.105 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 1.198 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$


$t_1 = 0.1017$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.1242$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.2$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 3391$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 3391$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 5.21 k $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k
 $P_{ns} = 2.7t_1dF_{u1}$ 3.39 k $P_{ns} = 2.7t_2dF_{u2}$ 4.14 k
 $P_{ns} = 2.7t_2dF_{u2}$ 4.14 k

Tension: $P_{not} = 1.304$ k (screw pull-out strength) $P_{not} = 0.85t_c dF_{u2}$
 $P_{nov} = 3.718$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 435$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	8.803	4	2.20	540 #	5	1.50 in
Short side:	8.803	3	2.93	540 #	6	1.20 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.57 in edge distance = 0.5 in [min. 1.5d]
thinnest part = 0.1017 AISI BSR applies
 $\Omega = 2.22$ bolt/screw connection
Check Block shear rupture: O.K. $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{gv} + F_u A_{nt}$ (AISI Sect. E5.3)
 $F_y = 50$ ksi $A_{nt} = 0.117$ in²
 $A_{gv} = 0.661$ in² $R_n/\Omega = 12.372$ k



Curb Loads (copied from above)


Transverse: (on long edge)	Comp _{MAX} = 7796 lbs
	Tens _{MAX} = 6172 lbs
	Shear _{MAX} = 4402 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 6864 lbs
	Tens _{MAX} = 5240 lbs
	Shear _{MAX} = 4402 lbs

Loads at each Isolator Type: JQB (OPM-0401-13)

Transverse loading: (on long edge)*	Comp _{MAX} = 1299.3 lbs
	Tens _{MAX} = 1028.6 lbs
	Shear _{MAX} = 400.1 lbs
Longitudinal loading: (on short edge)*	Comp _{MAX} = 1372.8 lbs
	Tens _{MAX} = 1047.9 lbs
	Shear _{MAX} = 400.1 lbs

Max compression force on isolator: 1.373 k ≤ 1.600 k O.K.
Max uplift on isolator: 1.048 k ≤ 1.600 k O.K.
Max shear on isolator: 0.400 k ≤ 1.000 k O.K.

*each case utilizes capacity of isolators at end of adjacent edge.



Forces on top bolt:

$d_b = 0.5$ in
upper rail, $t = 0.1242$ in
Tension = 1.048 k
Shear = 0.400 k

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 8.073$ k $e = 1.0$ in
Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 10.293$ k $A_n = 0.186$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$ ksi

Bolt Bearing Strength: $P_n = Cm_f dt F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 4.844$ k $d/t = 4.03$
Bearing O.K. $C = 3.00$ $mf = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k Bolt tension O.K. $\Omega t = 2.25$ (Table E3.4-1, AISI)
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 2.209$ k Bolt shear O.K.

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 2.04$ ksi O.K.
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi

Combined Not Applicable




Client:	ProVent PV1907	Base curb
Project:	ISCAL-129 Iso Curb (ISCALSLM1830**)	
Unit:	ZJ/ZR 180-300; ZF 210-300; XP 180-240	

Curb Information

Hcurb =	24 in	(Height of curb)
Lcurb =	125.75 in	(Length of curb)
wcurb =	83.5 in	(Width of curb)
WGTcurb =	641 lbs	(Weight of curb)
# springs long side =	4	# springs short side = 3

Unit Information

WGTunit =	3930 lbs	(Weight of Unit)
Wtmax =	2116 lbs	(Maximum corner weight)
Wtmin =	1110 lbs	(Minimum corner weight)
Hunit =	52.625 in	(Height of unit above curb)
Hcm =	37.3125 in	(Ht to ctr mass + 11")
Lunit =	180.5 in	(Length of unit)
Wunit =	92 in	(Width of unit)



Seismic Loading - 2018 IBC/2019 CBC

Ss =	2.000	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-16)
Sms =	2.000	(Fa*Ss)
Sds =	1.333	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	3.200 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	9350 lbs	(0.7*Fpmax)
FpmaxASD =	10239 lbs	(unit and curb)

(unit + upper curb only - from upper rail calc)

Wind Loading - 2018 IBC/2019 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) =	1.9	
GCr(vert) =	1.5	
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ²
Fh ASD trans =	3561 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb)
Fh ASD long =	1815 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	3375 lbs	= 0.6*qz*GCr*Lunit*Wunit

Curb Loading

Transverse:

Compression _{SEISMIC} =	9200 lbs	= [FpmaxASD*Hcm + 2*(1+0.14SDS)*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	7576 lbs	= Comp _{SEISMIC} - (0.6-0.14SDS)*WGTunit
Compression _{WIND} =	2443 lbs	= [Fh transASD*Hcm + 2*0.6*Wtmax*wcurb - FvertASD*wcurb/2]/wcurb
Tension _{WIND} =	3460 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	7796 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	6172 lbs	= Comp _{SEISMIC} - (0.6-0.14SDS)*WGTunit
Compression _{WIND} =	1390 lbs	= [Fh transASD*Hcm + 2*0.6*Wtmax*Lcurb - FvertASD*Lcurb/2]/Lcurb
Tension _{WIND} =	2407 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 9200 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 7576 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 7796 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 6172 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 [14 Gauge]
E = 29500 ksi

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.644 in = A' - (2r+t)
B' = 1.750 in	a' = 23.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
σ = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2+at/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = a[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.108 in (Distance between centroid and web centerline)	
Ix = 115.211 in (Moment of Inertia about X-Axis)	
Iy = 0.217 in (Moment of Inertia about Y-Axis)	
A = 1.94 in ²	
rx = 7.70 in	
ry = 0.334 in	
rmin = 0.334 in	



Axial Compression

Pa = 4.675 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 8.927 k		
Fe = 9.44 ksi		
λc = 2.30		
Fn = 8.28 ksi		
Ly = 73.38 in		
kyLy/ry = 176		

$P_n = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658\lambda_c^2) F_y$
 If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$ $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 24 in	Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 336.61 ≤ 200	CR = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.291667 ≤ 2.0	Ch = 0.02	
Pn = 2.130 k	R/t = 1.50 ≤ 9.0		

$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \frac{N}{t}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

Long side: Pa_{Trans} = 2.300 k **web stiffener REQ'D** # clips = 4
 Short side: Pa_{Long} = 2.599 k **web stiffener REQ'D** # clips = 3
 ***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in	ts = 0.0566 [16 Gauge]
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28vE/Fys	Ωc = 1.70

w/ts = 118.675
1.28v(E/Fys) = 31.091 → w/ts over limit Use C3.7.2

$P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
 Pwc = 2.130 k Ae = 0.380 in²
 Pn = 14.798 k
 Pn/Ωc = 8.704 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcnmax = 2337 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
Vcnmax = 3788 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.9	
# of Bolts required for Shear = 3.5	
# of Bolts Used = 4.0	
Check Combined Stress in Bolts & Inserts: 1.100 N.G.	***If combined fails: USE --> 5.0 StressComb = 0.880 O.K.




Check 1/8" welded connection --- USE WELD $\Omega = 2.35$
 Assume L/t > 25: 25*t = 1.783 in $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$
 Lreq'd = 2.561 in $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$

Curb Loads	
Transverse: (on long edge)	Comp _{MAX} = 9200 lbs
	Tens _{MAX} = 7576 lbs
	Shear _{MAX} = 9350 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 7796 lbs
	Tens _{MAX} = 6172 lbs
	Shear _{MAX} = 9350 lbs

Loads at each Isolator		Type:	IQB
Transverse loading: (on long edge)*	Comp _{MAX} = 1533.3 lbs		
	Tens _{MAX} = 1262.6 lbs		
	# isolators: 6	Shear _{MAX} = 425.0 lbs	
Longitudinal loading: (on short edge)*	Comp _{MAX} = 1559.2 lbs		
	Tens _{MAX} = 1234.4 lbs		
	# isolators: 5	Shear _{MAX} = 425.0 lbs	

Max compression force on isolator: 1.559 k ≤ 1.600 k **O.K.**
 Max uplift on isolator: 1.263 k ≤ 1.600 k **O.K.**
 Max shear on isolator: 0.425 k ≤ 1.000 k **O.K.**

*each case utilizes capacity of isolators at end of adjacent edge.



Forces on bottom bolts:

$d_b = 0.625$ in
 base curb, t = 0.0713 in
 Tension = 0.631 k/bolt
 Shear = 0.212 k/bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k $e = 1.0$ in
Shear O.K.


Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 6.372$ k $A_n = 0.098$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 65.000$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.476$ k $d/t = 8.77$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.3068$ in²
 $P_{nt}/\Omega = 6.136$ k **Bolt tension O.K.** $\Omega = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega = 2.40$
 $P_{nv}/\Omega = 3.451$ k **Bolt shear O.K.** ***[Table E3.4-1, AISI]***

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 0.69$ ksi
 $F'_{nt} = 45.0$ ksi $F_{nv}/\Omega = 11.25$ ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading	SEISMIC: (0.6-0.14SDSID + 0.7E)	WIND: 0.6D + W
Transverse:	Uplift _{MAX} = 8341 lbs	Shear _{MAX} = 5120 lbs
Compression _{SEISMIC}	10230 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}
Tension _{SEISMIC}	8341 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND}	2298 lbs	= [F _{htransASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*w _{curb} -F _{vertASD} *w _{curb} /2]/w _{curb}
Tension _{WIND}	2931 lbs	= [F _{htransASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*w _{curb} +F _{vertASD} *w _{curb} /2]/w _{curb}
Longitudinal:	Uplift _{MAX} = 5815 lbs	Shear _{MAX} = 5120 lbs
Compression _{SEISMIC}	7704 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}
Tension _{SEISMIC}	5815 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND}	569 lbs	= [F _{htransASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*L _{curb} -F _{vertASD} *L _{curb} /2]/L _{curb}
Tension _{WIND}	1201 lbs	= [F _{htransASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*L _{curb} +F _{vertASD} *L _{curb} /2]/L _{curb}

Wood Attachment: 1/4"φ x 4.5" Simpson SDS screw w/ 2.75" threaded emt (SGmin = 0.43)

Transverse:	Tall _{metal} = 946.67 lbs	Vall _{metal} = 1043.33 lbs
	Tall _{wood} = 760 lbs	Vall _{wood} = 672 lbs
	# of Screws Req'd for Uplift = 10.98	COMBINED LOADING: 0.979 O.K.
	# of Screws Req'd for Shear = 7.62	Req'd Min Spacing = 6.5 in o.c.
	Total # of screws required = 19	

Use 19 - 1/4"φ x 4.5" Simpson SDS screws @ 6.5 in o.c. along long side of curb w/ 2.75" threaded embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page 10 of 10

Longitudinal:

of Screws Req'd for Uplift = 7.65
of Screws Req'd for Shear = 7.62
Total # of screws required = 16

COMBINED LOADING: 0.954 O.K.
Screw Spacing = 5.0 in o.c.

Use 16 - 1/4" φ x 4.5" Simpson SDS screws @ 5 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall_{bolt} = 6903 lbs
Vall_{bolt} = 3682 lbs

Transverse: Tall_{bolt} = 6903 lbs
Vall_{bolt} = 3682 lbs

of Bolts Req'd for Uplift = 1.21
of Bolts Req'd for Shear = 1.39
Total # of bolts required = 3

COMBINED LOADING: 0.866 O.K.
Bolt Spacing = 56.9 in o.c.

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 56.9 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.84
of Bolts Req'd for Shear = 1.39
Total # of bolts required = 3

COMBINED LOADING: 0.744 O.K.
Bolt Spacing = 35.8 in o.c.

Use 3 - 1/2" φ A307 Bolts to steel angle below deck @ 35.8 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_pE (Ω_p = 2.5)

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs
Vall_{LRFD} = 3188 lbs
α = (1 + 0.2SDS)D + 2.5E = 1.87

Tall_{ASD} = Tall_{LRFD}/α = 1026.2 lbs
Vall_{ASD} = Vall_{LRFD}/α = 1704.8 lbs
(D = 0.465, E = 0.535)

Transverse: Uplift_{MAX} = 19619 lbs
Shear_{MAX} = 12799 lbs

Compression_{SEISMIC} = 21508 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb
Tension_{SEISMIC} = 19619 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})
Shear_{SEISMIC} = 12799 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 19.12 spacing = 5.36 in o.c. T_{applied} = 853.0 lbs
Min Bolts Req'd Shear = 7.51 spacing = 14.53571 in o.c. V_{applied} = 556.5 lbs

Try using 23 bolts spaced at 5.17 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$

Use 23 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.2 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 13304 lbs
Shear_{MAX} = 12799 lbs

Compression_{SEISMIC} = 15193 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb
Tension_{SEISMIC} = 13304 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})
Shear_{SEISMIC} = 12799 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 12.96 spacing = 4.958333 in o.c. T_{applied} = 782.6 lbs
Min Bolts Req'd Shear = 7.51 spacing = 8.5 in o.c. V_{applied} = 752.9 lbs

Try using 17 bolts spaced at 4.47 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.20$

Use 17 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 4.5 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: ISCAL-129 (ISCALS1M1830**)		Unit: ZJZR 180-300; ZF 210-300; XP 180-240	
UPPER CURB TUBE THICKNESS: 0.1242 in 10 Gauge			
UNIT CLIP THICKNESS: 0.1017 in 12 Gauge			
# OF CLIPS (LONG SIDE) - 4 clips with 5 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 3 clips with 6 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQB		Top stud diameter: 1/2	
Anchor bolt diameter: 5/8		Anchor hole diameter: 11/16	
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 1/8" welded connection			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	19 @ 6.54 in o.c.	3 @ 56.88 in o.c.	23 @ 5.17 in o.c.
SHORT DIRECTION	16 @ 5.03 in o.c.	3 @ 35.75 in o.c.	17 @ 4.47 in o.c.